



2499

# EMISSIONS MONITORING SURVEY

Prepared for:

**Selibon N.V.**

**ACL Lagun Waste Disposal Site**

**Kaminda Lagun**

**Bonaire**

**C.N.**

<b>Permit Number</b>	: ...
<b>Variation Number</b>	: ...
<b>Installation</b>	: Incinerator Exhaust
<b>Visit Details</b>	: Emissions Survey – February 2024
<b>Job Number</b>	: P5632
<b>Report Number</b>	: R001
<b>Report Issue Date</b>	: 20 <sup>th</sup> December 2024
<b>Survey Dates</b>	: 12 <sup>th</sup> – 16 <sup>th</sup> February 2024

Prepared by:

**Environmental Compliance Limited**

Unit G1

Main Avenue

Treforest Industrial Estate

Pontypridd

CF37 5BF.

Tel: 01443 801215

<b>Report Issue:</b>		<b>FINAL</b>	
<b>Report Prepared by:</b>		<b>Report Reviewed &amp; Approved by</b> MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
<b>Name:</b>	Scott Hackett	<b>Name:</b>	Andy Barnes
		<b>MCERTS No:</b>	MM 03 235
		<b>Signature:</b>	
<b>Date:</b>	06/11/2024	<b>Date:</b>	20/12/2024

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".

Environmental Compliance Limited

Selibon N.V.		Installation Name	: Incinerator Exhaust
Permit No	: ...	Visit Details	: Emissions Survey – February 2024
Variation No	: ...	Survey Dates	: 12th – 16th February 2024
Report Ref	: P5632	Report Issue Date.	: 20th December 2024
	: R001		

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECL's duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Any operating information and CEMS data used in this report has been supplied by the client.

**This report should not be reproduced, (except in full) without the written approval of the laboratory.**

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

**MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## TABLE OF CONTENTS

Section	Description	Page Number
<b>PART 1</b>	<b>EXECUTIVE SUMMARY</b>	<b>4</b>
<b>1</b>	<b>MONITORING OBJECTIVES</b>	<b>4</b>
<b>1.1</b>	<b>Monitoring Results</b>	<b>5</b>
<b>1.2</b>	<b>Operating Information</b>	<b>22</b>
<b>2</b>	<b>MONITORING DEVIATIONS</b>	<b>23</b>
<b>PART 2</b>	<b>SUPPORTING INFORMATION</b>	<b>25</b>
<b>3</b>	<b>SAMPLING STAFF DETAILS</b>	<b>25</b>
<b>4</b>	<b>SAMPLING PROTOCOLS / METHODOLOGIES</b>	<b>26</b>
<b>5</b>	<b>SAMPLE POINT DESCRIPTIONS</b>	<b>27</b>
	<b>EQUIPMENT IDs</b>	<b>28</b>
	<b>FIGURES</b>	<b>30</b>
	<b>TABLES</b>	<b>35</b>
	<b>VELOCITY TRAVERSE PROFILES</b>	<b>52</b>
	<b>FIELD CALIBRATION AND SAMPLING DATA</b>	<b>56</b>
	<b>LABORATORY ANALYSIS RESULTS</b>	<b>67</b>
	<b>UNCERTAINTY CALCULATIONS</b>	<b>73</b>

## PART 1 - EXECUTIVE SUMMARY

### 1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Selibon N.V.** to undertake an emission monitoring survey at their **ACL Lagun site, Bonaire**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **DHFB/P5632/Q002**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
	Incinerator Exhaust
Velocity / Flowrate	● U
Particulates	● U
Oxides of Nitrogen (as NO <sub>2</sub> )	● U
Sulphur Dioxide	● U
Carbon Monoxide	● U
Carbon Dioxide	● U
Oxygen	● U
Hydrogen Chloride	● U
Hydrogen Fluoride	● U
Dioxins / Furans (PCDDs & PCDFs)	● U
Heavy Metals (Cd, Tl, Sb, As, Pb, Cr, Co, Cu, Mn, Ni & V)	● U
Mercury	● U

● Denotes the substances to be monitored.

U Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

Special Requirements: “During normal operation – with various waste types.”

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date: : 20th December 2024

### 1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission <b>NOTE UNITS</b>	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Volumetric Flowrate	...	1.15933	m <sup>3</sup> /sec	...	5	Stack	13/02/2024	09:30 – 09:54	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Light Medical Waste
	Volumetric Flowrate	...	0.10289	m <sup>3</sup> /sec	...	23	Dry & 3% O <sub>2</sub>			BS EN 16911-1:2013 & MID	UKAS / MCERTS		
	Particulates <sup>§</sup>	3.6	778.40	mg/m <sup>3</sup>	343.88 <b>g/hr</b>	5	Dry & 3% O <sub>2</sub>	13/02/2024	10:15 – 11:15	BS EN 13284-1:2017 & MID	NU	✓	
	Hydrogen Chloride <sup>§</sup>	30	648.46	mg/m <sup>3</sup>	286.48 <b>g/hr</b>	14	Dry & 3% O <sub>2</sub>			BS EN 1911:2010	NU	✓	
	Hydrogen Fluoride <sup>§</sup>	10	3.64	mg/m <sup>3</sup>	1.61 <b>g/hr</b>	14	Dry & 3% O <sub>2</sub>			PD CEN/TS 17340:2020	NU	✓	
	Sulphur Dioxide <sup>§</sup>	20.7	54.85	mg/m <sup>3</sup>	19.44 <b>g/hr</b>	14	Dry & 3% O <sub>2</sub>	13/02/2024	12:25 – 13:25	BS EN 14791:2017	NU	✓	
	Heavy Metals* <sup>§</sup>	0.15	0.93	mg/m <sup>3</sup>	0.43 <b>g/hr</b>	6	Dry & 3% O <sub>2</sub>	13/02/2024	13:55 – 15:55	BS EN 14385:2004 & MID	NU	✓	
	Cadmium / Thallium <sup>§</sup>	0.015	0.0052	mg/m <sup>3</sup>	0.0025 <b>g/hr</b>	5	Dry & 3% O <sub>2</sub>			BS EN 14385:2004 & MID	NU	✓	
	Mercury <sup>§</sup>	0.02	0.00083	mg/m <sup>3</sup>	0.00039 <b>g/hr</b>	7	Dry & 3% O <sub>2</sub>			BS EN 13211:2001	NU	✓	
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	281.36	mg/m <sup>3</sup>	0.1042 <b>Kg/hr</b>	2	Dry & 3% O <sub>2</sub>	13/02/2024	09:45 – 15:44	BS EN 14792: 2017	UKAS / MCERTS		
	Carbon Monoxide	3.6	8084.20	mg/m <sup>3</sup>	2.9944 <b>Kg/hr</b>	2	Dry & 3% O <sub>2</sub>			BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Dioxide	214.1	249.37	g/m <sup>3</sup>	92.37 <b>Kg/hr</b>	4	Dry & 3% O <sub>2</sub>			PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.80	%	...	4	& Dry Gas			PD CEN/TS 17405:2020	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	17.03	%	...	4	& Dry Gas			BS EN 14789: 2017	UKAS / MCERTS		

(\* Sum of Sb, As, Pb, Cr, Co, Cu, Mn, Ni & V)

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date: : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	243.87	mg/m <sup>3</sup>	0.0903	2	Dry & 3% O <sub>2</sub>	13/02/2024	09:45 – 10:14	BS EN 14792: 2017	UKAS / MCERTS		Light Medical Waste
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	249.17	mg/m <sup>3</sup>	0.0923	2	Dry & 3% O <sub>2</sub>		10:15 – 10:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	426.76	mg/m <sup>3</sup>	0.1581	2	Dry & 3% O <sub>2</sub>		10:45 – 11:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	287.67	mg/m <sup>3</sup>	0.1066	2	Dry & 3% O <sub>2</sub>		11:15 – 11:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	111.16	mg/m <sup>3</sup>	0.0412	2	Dry & 3% O <sub>2</sub>		11:45 – 12:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	238.78	mg/m <sup>3</sup>	0.0884	2	Dry & 3% O <sub>2</sub>		12:15 – 12:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	175.14	mg/m <sup>3</sup>	0.0649	2	Dry & 3% O <sub>2</sub>		12:45 – 13:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	318.26	mg/m <sup>3</sup>	0.1179	2	Dry & 3% O <sub>2</sub>		13:15 – 13:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	522.31	mg/m <sup>3</sup>	0.1935	2	Dry & 3% O <sub>2</sub>		13:45 – 14:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	184.70	mg/m <sup>3</sup>	0.0684	2	Dry & 3% O <sub>2</sub>		14:15 – 14:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	349.72	mg/m <sup>3</sup>	0.1295	2	Dry & 3% O <sub>2</sub>		14:45 – 15:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	323.22	mg/m <sup>3</sup>	0.1197	2	Dry & 3% O <sub>2</sub>		15:15 – 15:44	BS EN 14792: 2017	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Monoxide	1.6	11732.38	mg/m <sup>3</sup>	4.3457	2	Dry & 3% O <sub>2</sub>	13/02/2024	09:45 – 10:14	BS EN 15058: 2017	UKAS / MCERTS	✓	Light Medical Waste
	Carbon Monoxide	1.6	9992.12	mg/m <sup>3</sup>	3.7011	2	Dry & 3% O <sub>2</sub>		10:15 – 10:44	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	5219.24	mg/m <sup>3</sup>	1.9332	2	Dry & 3% O <sub>2</sub>		10:45 – 11:14	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	8676.88	mg/m <sup>3</sup>	3.2140	2	Dry & 3% O <sub>2</sub>		11:15 – 11:44	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	6174.06	mg/m <sup>3</sup>	2.2869	2	Dry & 3% O <sub>2</sub>		11:45 – 12:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	9186.91	mg/m <sup>3</sup>	3.4029	2	Dry & 3% O <sub>2</sub>		12:15 – 12:44	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	6525.19	mg/m <sup>3</sup>	2.4170	2	Dry & 3% O <sub>2</sub>		12:45 – 13:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	9316.88	mg/m <sup>3</sup>	3.4510	2	Dry & 3% O <sub>2</sub>		13:15 – 13:44	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	5254.88	mg/m <sup>3</sup>	1.9464	2	Dry & 3% O <sub>2</sub>		13:45 – 14:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	7743.34	mg/m <sup>3</sup>	2.8682	2	Dry & 3% O <sub>2</sub>		14:15 – 14:44	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	2277.23	mg/m <sup>3</sup>	0.8435	2	Dry & 3% O <sub>2</sub>		14:45 – 15:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	6611.16	mg/m <sup>3</sup>	2.4488	2	Dry & 3% O <sub>2</sub>		15:15 – 15:44	BS EN 15058: 2017	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Dioxide	214.1	333.98	g/m <sup>3</sup>	123.71	4	Dry & 3% O <sub>2</sub>	13/02/2024	09:45 – 10:14	PD CEN/TS 17405:2020	UKAS / MCERTS		Light Medical Waste
	Carbon Dioxide	214.1	357.13	g/m <sup>3</sup>	132.28	4	Dry & 3% O <sub>2</sub>		10:15 – 10:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	219.98	g/m <sup>3</sup>	81.48	4	Dry & 3% O <sub>2</sub>		10:45 – 11:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	45.42	g/m <sup>3</sup>	16.82	4	Dry & 3% O <sub>2</sub>		11:15 – 11:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	19.59	g/m <sup>3</sup>	7.26	4	Dry & 3% O <sub>2</sub>		11:45 – 12:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	257.39	g/m <sup>3</sup>	95.34	4	Dry & 3% O <sub>2</sub>		12:15 – 12:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	31.17	g/m <sup>3</sup>	11.55	4	Dry & 3% O <sub>2</sub>		12:45 – 13:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	545.94	g/m <sup>3</sup>	202.22	4	Dry & 3% O <sub>2</sub>		13:15 – 13:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	163.87	g/m <sup>3</sup>	60.70	4	Dry & 3% O <sub>2</sub>		13:45 – 14:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	694.67	g/m <sup>3</sup>	257.31	4	Dry & 3% O <sub>2</sub>		14:15 – 14:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	236.01	g/m <sup>3</sup>	87.42	4	Dry & 3% O <sub>2</sub>		14:45 – 15:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	86.39	g/m <sup>3</sup>	32.00	4	Dry & 3% O <sub>2</sub>		15:15 – 15:44	PD CEN/TS 17405:2020	UKAS / MCERTS		



Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)2	Operating Status
Incinerator Exhaust	Carbon Dioxide	...	3.75	%	4	& Dry Gas	13/02/2024	09:45 – 10:14	PD CEN/TS 17405:2020	UKAS / MCERTS		Light Medical Waste
	Carbon Dioxide	...	4.01	%	4	& Dry Gas		10:15 – 10:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.47	%	4	& Dry Gas		10:45 – 11:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	0.51	%	4	& Dry Gas		11:15 – 11:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	0.22	%	4	& Dry Gas		11:45 – 12:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.89	%	4	& Dry Gas		12:15 – 12:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	0.35	%	4	& Dry Gas		12:45 – 13:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	6.13	%	4	& Dry Gas		13:15 – 13:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	1.84	%	4	& Dry Gas		13:45 – 14:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	7.80	%	4	& Dry Gas		14:15 – 14:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.65	%	4	& Dry Gas		14:45 – 15:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	0.97	%	4	& Dry Gas		15:15 – 15:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	15.72	%	4	& Dry Gas		09:45 – 10:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	15.26	%	4	& Dry Gas		10:15 – 10:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	17.71	%	4	& Dry Gas		10:45 – 11:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	19.99	%	4	& Dry Gas		11:15 – 11:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	20.35	%	4	& Dry Gas		11:45 – 12:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.87	%	4	& Dry Gas		12:15 – 12:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	20.16	%	4	& Dry Gas		12:45 – 13:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	12.59	%	4	& Dry Gas		13:15 – 13:44	BS EN 14789: 2017	UKAS / MCERTS		
Oxygen (Paramagnetic)	...	18.28	%	4	& Dry Gas	13:45 – 14:14	BS EN 14789: 2017	UKAS / MCERTS				
Oxygen (Paramagnetic)	...	10.64	%	4	& Dry Gas	14:15 – 14:44	BS EN 14789: 2017	UKAS / MCERTS				
Oxygen (Paramagnetic)	...	17.38	%	4	& Dry Gas	14:45 – 15:14	BS EN 14789: 2017	UKAS / MCERTS				
Oxygen (Paramagnetic)	...	19.42	%	4	& Dry Gas	15:15 – 15:44	BS EN 14789: 2017	UKAS / MCERTS				

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission <b>NOTE UNITS</b>	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Volumetric Flowrate	...	3.01701	m³/sec	...	9	Stack Conditions	14/02/2024	09:11 – 09:21	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Medium (Bins) Medical Waste
	Volumetric Flowrate	...	0.19765	m³/sec	...	19	Dry & 3% O <sub>2</sub>			BS EN 16911-1:2013 & MID	UKAS / MCERTS		
	Particulates \$	3.6	436.00	mg/m³	391.09 <b>g/hr</b>	5	Dry & 3% O <sub>2</sub>	14/02/2024	09:25 – 10:25	BS EN 13284-1:2017 & MID	NU	✓	
	Hydrogen Chloride \$	30	315.64	mg/m³	283.13 <b>g/hr</b>	14	Dry & 3% O <sub>2</sub>			BS EN 1911:2010	NU	✓	
	Hydrogen Fluoride \$	10	5.91	mg/m³	5.30 <b>g/hr</b>	14	Dry & 3% O <sub>2</sub>			PD CEN/TS 17340:2020	NU	✓	
	Sulphur Dioxide \$	20.7	31.04	mg/m³	27.93 <b>g/hr</b>	14	Dry & 3% O <sub>2</sub>	14/02/2024	11:20 – 12:20	BS EN 14791:2017	NU	✓	
	Heavy Metals* \$	0.15	0.65	mg/m³	0.50 <b>g/hr</b>	4	Dry & 3% O <sub>2</sub>	14/02/2024	13:33 – 15:43	BS EN 14385:2004 & MID	NU	✓	
	Cadmium / Thallium \$	0.015	0.0063	mg/m³	0.0049 <b>g/hr</b>	4	Dry & 3% O <sub>2</sub>			BS EN 14385:2004 & MID	NU	✓	
	Mercury \$	0.02	0.0016	mg/m³	0.0012 <b>g/hr</b>	7	Dry & 3% O <sub>2</sub>			BS EN 13211:2001	NU	✓	
	PCDDs & PCDFs \$	0.1	20.86	ng/m³	28.19 <b>µg/hr</b>	15	Dry & 3% O <sub>2</sub>	15/02/2024	09:40 – 14:50	BS EN 1948-1:2006 & MID	NU	✓	
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	283.59	mg/m³	0.2016 <b>Kg/hr</b>	2	Dry & 3% O <sub>2</sub>	14/02/2024	09:15 – 15:44	BS EN 14792: 2017	UKAS / MCERTS		
	Carbon Monoxide	3.6	3414.59	mg/m³	2.4296 <b>Kg/hr</b>	2	Dry & 3% O <sub>2</sub>			BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Dioxide	214.1	251.25	g/m³	178.77 <b>Kg/hr</b>	5	Dry & 3% O <sub>2</sub>			PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.75	%	...	5	& Dry Gas			PD CEN/TS 17405:2020	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	17.13	%	...	2	& Dry Gas			BS EN 14789: 2017	UKAS / MCERTS		

(\* Sum of Sb, As, Pb, Cr, Co, Cu, Mn, Ni & V)

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	203.19	mg/m <sup>3</sup>	0.1446	2	Dry & 3% O <sub>2</sub>	14/02/2024	09:15 – 09:44	BS EN 14792: 2017	UKAS / MCERTS		Medium (Bins) Medical Waste
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	299.80	mg/m <sup>3</sup>	0.2133	2	Dry & 3% O <sub>2</sub>		09:45 – 10:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	281.86	mg/m <sup>3</sup>	0.2006	2	Dry & 3% O <sub>2</sub>		10:15 – 10:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	260.49	mg/m <sup>3</sup>	0.1854	2	Dry & 3% O <sub>2</sub>		10:45 – 11:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	332.26	mg/m <sup>3</sup>	0.2364	2	Dry & 3% O <sub>2</sub>		11:15 – 11:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	247.68	mg/m <sup>3</sup>	0.1762	2	Dry & 3% O <sub>2</sub>		11:45 – 12:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	221.73	mg/m <sup>3</sup>	0.1578	2	Dry & 3% O <sub>2</sub>		12:15 – 12:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	176.70	mg/m <sup>3</sup>	0.1257	2	Dry & 3% O <sub>2</sub>		12:45 – 13:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	146.44	mg/m <sup>3</sup>	0.1042	2	Dry & 3% O <sub>2</sub>		13:15 – 13:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	218.01	mg/m <sup>3</sup>	0.1551	2	Dry & 3% O <sub>2</sub>		13:45 – 14:14	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	419.14	mg/m <sup>3</sup>	0.2982	2	Dry & 3% O <sub>2</sub>		14:15 – 14:44	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	461.92	mg/m <sup>3</sup>	0.3287	2	Dry & 3% O <sub>2</sub>		14:45 – 15:14	BS EN 14792: 2017	UKAS / MCERTS		
Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	493.87	mg/m <sup>3</sup>	0.3514	2	Dry & 3% O <sub>2</sub>	15:15 – 15:44	BS EN 14792: 2017	UKAS / MCERTS				

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Monoxide	1.6	4956.53	mg/m <sup>3</sup>	3.5268	2	Dry & 3% O <sub>2</sub>	14/02/2024	09:15 – 09:44	BS EN 15058: 2017	UKAS / MCERTS	✓	Medium (Bins) Medical Waste
	Carbon Monoxide	1.6	6416.43	mg/m <sup>3</sup>	4.5656	2	Dry & 3% O <sub>2</sub>		09:45 – 10:14	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	4614.66	mg/m <sup>3</sup>	3.2835	2	Dry & 3% O <sub>2</sub>		10:15 – 10:44	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	4179.21	mg/m <sup>3</sup>	2.9737	2	Dry & 3% O <sub>2</sub>		10:45 – 11:14	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	2757.03	mg/m <sup>3</sup>	1.9618	2	Dry & 3% O <sub>2</sub>		11:15 – 11:44	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	2751.77	mg/m <sup>3</sup>	1.9580	2	Dry & 3% O <sub>2</sub>		11:45 – 12:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	2357.00	mg/m <sup>3</sup>	1.6771	2	Dry & 3% O <sub>2</sub>		12:15 – 12:44	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1848.96	mg/m <sup>3</sup>	1.3156	2	Dry & 3% O <sub>2</sub>		12:45 – 13:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	3694.55	mg/m <sup>3</sup>	2.6288	2	Dry & 3% O <sub>2</sub>		13:15 – 13:44	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	2458.14	mg/m <sup>3</sup>	1.7491	2	Dry & 3% O <sub>2</sub>		13:45 – 14:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1920.76	mg/m <sup>3</sup>	1.3667	2	Dry & 3% O <sub>2</sub>		14:15 – 14:44	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	2747.17	mg/m <sup>3</sup>	1.9547	2	Dry & 3% O <sub>2</sub>		14:45 – 15:14	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	2957.75	mg/m <sup>3</sup>	2.1046	2	Dry & 3% O <sub>2</sub>		15:15 – 15:44	BS EN 15058: 2017	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Dioxide	214.1	264.04	g/m <sup>3</sup>	187.88	5	Dry & 3% O <sub>2</sub>	14/02/2024	09:15 – 09:44	PD CEN/TS 17405:2020	UKAS / MCERTS		Medium (Bins) Medical Waste
	Carbon Dioxide	214.1	267.69	g/m <sup>3</sup>	190.47	5	Dry & 3% O <sub>2</sub>		09:45 – 10:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	314.29	g/m <sup>3</sup>	223.63	5	Dry & 3% O <sub>2</sub>		10:15 – 10:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	306.98	g/m <sup>3</sup>	218.43	5	Dry & 3% O <sub>2</sub>		10:45 – 11:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	280.48	g/m <sup>3</sup>	199.57	5	Dry & 3% O <sub>2</sub>		11:15 – 11:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	315.20	g/m <sup>3</sup>	224.28	5	Dry & 3% O <sub>2</sub>		11:45 – 12:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	162.62	g/m <sup>3</sup>	115.71	5	Dry & 3% O <sub>2</sub>		12:15 – 12:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	159.88	g/m <sup>3</sup>	113.76	5	Dry & 3% O <sub>2</sub>		12:45 – 13:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	256.73	g/m <sup>3</sup>	182.67	5	Dry & 3% O <sub>2</sub>		13:15 – 13:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	260.38	g/m <sup>3</sup>	185.27	5	Dry & 3% O <sub>2</sub>		13:45 – 14:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	221.10	g/m <sup>3</sup>	157.32	5	Dry & 3% O <sub>2</sub>		14:15 – 14:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	244.85	g/m <sup>3</sup>	174.22	5	Dry & 3% O <sub>2</sub>		14:45 – 15:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
Carbon Dioxide	214.1	216.53	g/m <sup>3</sup>	154.07	5	Dry & 3% O <sub>2</sub>	15:15 – 15:44	PD CEN/TS 17405:2020	UKAS / MCERTS				

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Dioxide	...	2.89	%	5	& Dry Gas	14/02/2024	09:15 – 09:44	PD CEN/TS 17405:2020	UKAS / MCERTS		Medium (Bins) Medical Waste
	Carbon Dioxide	...	2.93	%	5	& Dry Gas		09:45 – 10:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	3.44	%	5	& Dry Gas		10:15 – 10:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	3.36	%	5	& Dry Gas		10:45 – 11:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	3.07	%	5	& Dry Gas		11:15 – 11:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	3.45	%	5	& Dry Gas		11:45 – 12:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	1.78	%	5	& Dry Gas		12:15 – 12:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	1.75	%	5	& Dry Gas		12:45 – 13:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.81	%	5	& Dry Gas		13:15 – 13:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.85	%	5	& Dry Gas		13:45 – 14:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.42	%	5	& Dry Gas		14:15 – 14:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.68	%	5	& Dry Gas		14:45 – 15:14	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	2.37	%	5	& Dry Gas		15:15 – 15:44	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.79	%	2	& Dry Gas		09:15 – 09:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.87	%	2	& Dry Gas		09:45 – 10:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.31	%	2	& Dry Gas		10:15 – 10:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.37	%	2	& Dry Gas		10:45 – 11:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.67	%	2	& Dry Gas		11:15 – 11:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.13	%	2	& Dry Gas		11:45 – 12:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	18.52	%	2	& Dry Gas		12:15 – 12:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	18.45	%	2	& Dry Gas		12:45 – 13:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.89	%	2	& Dry Gas		13:15 – 13:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	16.94	%	2	& Dry Gas		13:45 – 14:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	17.64	%	2	& Dry Gas		14:15 – 14:44	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	17.45	%	2	& Dry Gas		14:45 – 15:14	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	17.68	%	2	& Dry Gas		15:15 – 15:44	BS EN 14789: 2017	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date: : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission NOTE UNITS	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Volumetric Flowrate	...	3.11712	m <sup>3</sup> /sec	...	9	Stack Conditions	15/02/2024	15:38 – 15:50	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Dead Animal Waste
	Volumetric Flowrate	...	0.49087	m <sup>3</sup> /sec	...	14	Dry & 3% O <sub>2</sub>			BS EN 16911-1:2013 & MID	UKAS / MCERTS		
	Particulates <sup>§</sup>	3.6	233.26	mg/m <sup>3</sup>	135.67 <u>g/hr</u>	8	Dry & 3% O <sub>2</sub>	15/02/2024	16:00 – 17:00	BS EN 13284-1:2017 & MID	NU	✓	
	Hydrogen Chloride <sup>§</sup>	30	41.82	mg/m <sup>3</sup>	24.33 <u>g/hr</u>	15	Dry & 3% O <sub>2</sub>			BS EN 1911:2010	NU	✓	
	Hydrogen Fluoride <sup>§</sup>	10	16.70	mg/m <sup>3</sup>	9.71 <u>g/hr</u>	15	Dry & 3% O <sub>2</sub>			PD CEN/TS 17340:2020	NU	✓	
	Sulphur Dioxide <sup>§</sup>	20.7	1008.11	mg/m <sup>3</sup>	3322.07 <u>g/hr</u>	13	Dry & 3% O <sub>2</sub>	15/02/2024	17:45 – 18:45	BS EN 14791:2017	NU	✓	
	Heavy Metals* <sup>§</sup>	0.15	0.24	mg/m <sup>3</sup>	0.48 <u>g/hr</u>	4	Dry & 3% O <sub>2</sub>	15/02/2024	19:45 – 20:45	BS EN 14385:2004 & MID	NU	✓	
	Cadmium / Thallium <sup>§</sup>	0.015	0.0044	mg/m <sup>3</sup>	0.0088 <u>g/hr</u>	3	Dry & 3% O <sub>2</sub>			BS EN 14385:2004 & MID	NU	✓	
	Mercury <sup>§</sup>	0.02	0.00085	mg/m <sup>3</sup>	0.0017 <u>g/hr</u>	6	Dry & 3% O <sub>2</sub>			BS EN 13211:2001	NU	✓	
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	423.27	mg/m <sup>3</sup>	0.7480 <u>Kg/hr</u>	2	Dry & 3% O <sub>2</sub>	15/02/2024	16:00 – 20:59	BS EN 14792: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1241.74	mg/m <sup>3</sup>	2.1943 <u>Kg/hr</u>	2	Dry & 3% O <sub>2</sub>			BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Dioxide	214.1	264.25	g/m <sup>3</sup>	466.96 <u>Kg/hr</u>	5	Dry & 3% O <sub>2</sub>			PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	5.68	%	...	5	& Dry Gas			PD CEN/TS 17405:2020	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	13.40	%	...	2	& Dry Gas			BS EN 14789: 2017	UKAS / MCERTS		

(\* Sum of Sb, As, Pb, Cr, Co, Cu, Mn, Ni & V)

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission <b>NOTE UNITS</b>	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	PCDDs & PCDFs §	0.1	2.81	ng/m <sup>3</sup>	4.64 <u>µg/hr</u>	15	Dry & 3% O <sub>2</sub>	16/02/2024	10:40 – 11:40	BS EN 1948-1:2006 & MID	NU	✓	Dead Animal Waste
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	304.85	mg/m <sup>3</sup>	0.5387 <u>Kg/hr</u>	2	Dry & 3% O <sub>2</sub>		10:40 – 11:39	BS EN 14792: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	97.85	mg/m <sup>3</sup>	0.1729 <u>Kg/hr</u>	2	Dry & 3% O <sub>2</sub>		BS EN 15058: 2017	UKAS / MCERTS			
	Carbon Dioxide	214.1	264.77	g/m <sup>3</sup>	467.88 <u>Kg/hr</u>	4	Dry & 3% O <sub>2</sub>		PD CEN/TS 17405:2020	UKAS / MCERTS			
	Carbon Dioxide	...	8.17	%	...	4	& Dry Gas		PD CEN/TS 17405:2020	UKAS / MCERTS			
	Oxygen (Paramagnetic)	...	10.09	%	...	2	& Dry Gas		BS EN 14789: 2017	UKAS / MCERTS			



Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	347.09	mg/m <sup>3</sup>	0.6134	2	Dry & 3% O <sub>2</sub>	15/02/2024	16:00 – 16:29	BS EN 14792: 2017	UKAS / MCERTS		Dead Animal Waste
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	334.02	mg/m <sup>3</sup>	0.5903	2	Dry & 3% O <sub>2</sub>		16:30 – 16:59	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	342.12	mg/m <sup>3</sup>	0.6046	2	Dry & 3% O <sub>2</sub>		17:00 – 17:29	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	391.55	mg/m <sup>3</sup>	0.6919	2	Dry & 3% O <sub>2</sub>		17:30 – 17:59	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	318.54	mg/m <sup>3</sup>	0.5629	2	Dry & 3% O <sub>2</sub>		18:00 – 18:29	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	427.28	mg/m <sup>3</sup>	0.7550	2	Dry & 3% O <sub>2</sub>		18:30 – 18:59	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	740.55	mg/m <sup>3</sup>	1.3087	2	Dry & 3% O <sub>2</sub>		19:00 – 19:29	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	486.63	mg/m <sup>3</sup>	0.8599	2	Dry & 3% O <sub>2</sub>		19:30 – 19:59	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	329.60	mg/m <sup>3</sup>	0.5824	2	Dry & 3% O <sub>2</sub>		20:00 – 20:29	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	704.51	mg/m <sup>3</sup>	1.2450	2	Dry & 3% O <sub>2</sub>		20:30 – 20:59	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	262.39	mg/m <sup>3</sup>	0.4637	2	Dry & 3% O <sub>2</sub>	16/02/2024	10:40 – 11:09	BS EN 14792: 2017	UKAS / MCERTS		
	Oxides of Nitrogen (as NO <sub>2</sub> )	241.2	363.66	mg/m <sup>3</sup>	0.6426	2	Dry & 3% O <sub>2</sub>		11:10 – 11:39	BS EN 14792: 2017	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Monoxide	1.6	5317.99	mg/m <sup>3</sup>	9.3976	2	Dry & 3% O <sub>2</sub>	15/02/2024	16:00 – 16:29	BS EN 15058: 2017	UKAS / MCERTS		Dead Animal Waste
	Carbon Monoxide	1.6	2288.80	mg/m <sup>3</sup>	4.0446	2	Dry & 3% O <sub>2</sub>		16:30 – 16:59	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1011.91	mg/m <sup>3</sup>	1.7882	2	Dry & 3% O <sub>2</sub>		17:00 – 17:29	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1770.92	mg/m <sup>3</sup>	3.1294	2	Dry & 3% O <sub>2</sub>		17:30 – 17:59	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	181.55	mg/m <sup>3</sup>	0.3208	2	Dry & 3% O <sub>2</sub>		18:00 – 18:29	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1950.34	mg/m <sup>3</sup>	3.4465	2	Dry & 3% O <sub>2</sub>		18:30 – 18:59	BS EN 15058: 2017	UKAS / MCERTS	✓	
	Carbon Monoxide	1.6	279.74	mg/m <sup>3</sup>	0.4943	2	Dry & 3% O <sub>2</sub>		19:00 – 19:29	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1912.88	mg/m <sup>3</sup>	3.3803	2	Dry & 3% O <sub>2</sub>		19:30 – 19:59	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	506.42	mg/m <sup>3</sup>	0.8949	2	Dry & 3% O <sub>2</sub>		20:00 – 20:29	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	1353.35	mg/m <sup>3</sup>	2.3915	2	Dry & 3% O <sub>2</sub>		20:30 – 20:59	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	130.32	mg/m <sup>3</sup>	0.2303	2	Dry & 3% O <sub>2</sub>	16/02/2024	10:40 – 11:09	BS EN 15058: 2017	UKAS / MCERTS		
	Carbon Monoxide	1.6	52.88	mg/m <sup>3</sup>	0.0934	2	Dry & 3% O <sub>2</sub>		11:10 – 11:39	BS EN 15058: 2017	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (Kg/hr)	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Dioxide	214.1	264.25	g/m <sup>3</sup>	466.96	5	Dry & 3% O <sub>2</sub>	15/02/2024	16:00 – 16:29	PD CEN/TS 17405:2020	UKAS / MCERTS		Dead Animal Waste
	Carbon Dioxide	214.1	59.08	g/m <sup>3</sup>	104.40	5	Dry & 3% O <sub>2</sub>		16:30 – 16:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	95.37	g/m <sup>3</sup>	168.53	5	Dry & 3% O <sub>2</sub>		17:00 – 17:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	291.7	g/m <sup>3</sup>	515.47	5	Dry & 3% O <sub>2</sub>		17:30 – 17:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	312.17	g/m <sup>3</sup>	551.65	5	Dry & 3% O <sub>2</sub>		18:00 – 18:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	518.73	g/m <sup>3</sup>	916.66	5	Dry & 3% O <sub>2</sub>		18:30 – 18:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	504.77	g/m <sup>3</sup>	892.00	5	Dry & 3% O <sub>2</sub>		19:00 – 19:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	221.45	g/m <sup>3</sup>	391.33	5	Dry & 3% O <sub>2</sub>		19:30 – 19:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	209.82	g/m <sup>3</sup>	370.78	5	Dry & 3% O <sub>2</sub>		20:00 – 20:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	274.95	g/m <sup>3</sup>	485.87	5	Dry & 3% O <sub>2</sub>		20:30 – 20:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	305.28	g/m <sup>3</sup>	539.47	4	Dry & 3% O <sub>2</sub>	16/02/2024	10:40 – 11:09	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	214.1	224.26	g/m <sup>3</sup>	396.30	4	Dry & 3% O <sub>2</sub>		11:10 – 11:39	PD CEN/TS 17405:2020	UKAS / MCERTS		

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date: : 20th December 2024

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Incinerator Exhaust	Carbon Dioxide	...	1.27	%	5	& Dry Gas	15/02/2024	16:00 – 16:29	PD CEN/TS 17405:2020	UKAS / MCERTS		Dead Animal Waste
	Carbon Dioxide	...	2.05	%	5	& Dry Gas		16:30 – 16:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	6.27	%	5	& Dry Gas		17:00 – 17:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	6.71	%	5	& Dry Gas		17:30 – 17:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	11.15	%	5	& Dry Gas		18:00 – 18:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	10.85	%	5	& Dry Gas		18:30 – 18:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	4.76	%	5	& Dry Gas		19:00 – 19:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	4.51	%	5	& Dry Gas		19:30 – 19:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	5.91	%	5	& Dry Gas		20:00 – 20:29	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	3.35	%	5	& Dry Gas		20:30 – 20:59	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	9.42	%	4	& Dry Gas	16/02/2024	10:40 – 11:09	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Carbon Dioxide	...	6.92	%	4	& Dry Gas		11:10 – 11:39	PD CEN/TS 17405:2020	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	19.13	%	2	& Dry Gas	15/02/2024	16:00 – 16:29	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	18.03	%	2	& Dry Gas		16:30 – 16:59	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	12.36	%	2	& Dry Gas		17:00 – 17:29	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	12.17	%	2	& Dry Gas		17:30 – 17:59	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	6.10	%	2	& Dry Gas		18:00 – 18:29	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	6.90	%	2	& Dry Gas		18:30 – 18:59	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	14.70	%	2	& Dry Gas		19:00 – 19:29	BS EN 14789: 2017	UKAS / MCERTS		
	Oxygen (Paramagnetic)	...	14.91	%	2	& Dry Gas		19:30 – 19:59	BS EN 14789: 2017	UKAS / MCERTS		
Oxygen (Paramagnetic)	...	13.22	%	2	& Dry Gas	20:00 – 20:29		BS EN 14789: 2017	UKAS / MCERTS			
Oxygen (Paramagnetic)	...	16.53	%	2	& Dry Gas	20:30 – 20:59		BS EN 14789: 2017	UKAS / MCERTS			
Oxygen (Paramagnetic)	...	8.34	%	2	& Dry Gas	16/02/2024	10:40 – 11:09	BS EN 14789: 2017	UKAS / MCERTS			
Oxygen (Paramagnetic)	...	11.83	%	2	& Dry Gas		11:10 – 11:39	BS EN 14789: 2017	UKAS / MCERTS			

## Environmental Compliance Limited

Selibon N.V.		Installation Name	: Incinerator Exhaust
Permit No	: ...	Visit Details	: Emissions Survey – February 2024
Variation No	: ...	Survey Dates	: 12th – 16th February 2024
Report Ref	: P5632	Report Issue Date.	: 20th December 2024
	: R001		

The volumetric flowrate shown above is that from the initial pitot traverse.

Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

### Notes

The uncertainty figures presented in Table 1.1 for NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub> are “measurement uncertainty” figures, which do not take into account the variability of the measured sample values. The “uncertainty of measurement results” figures, which do include this contribution, are presented in the appendices of the report for these determinands.

Emission Limit Value	The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
Periodic Monitoring Result	The result given is expressed in the same terms and units as the emission limit value.
Uncertainty	The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results <b>DO NOT</b> take into account the effect of the sample location limitations.
Reference Conditions	All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
Monitoring Method Reference	The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
Accreditation for use of Method	<b>The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited " NA" is stated.</b>
Operating Status	The details indicate the feedstock and the loading rate of the plant during monitoring.
\$	Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
NU	UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
NA	<b>Method is NOT UKAS Accredited.</b>

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## 1.2 Operating Information

**Any operating information and CEMS data below has been supplied by the client.**

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Incinerator Exhaust	Batch	Various	Diesel	Medical & Animal Waste (See Table 1.1)	None	Primary Chamber 500 -600c Secondary Chamber 650 – 850c	...	...	...	NP	...	...

**Notes:**

- Process Type State whether the process is a continuous or batch process.
- Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
- Fuel If applicable, state the fuel type If not applicable state "NA"
- Feedstock State the feedstock type
- Abatement State the type and whether operational during monitoring. If not applicable state "NA"
- Load State the normal load, throughput or rating of the plant
- CEMS Data Enter this data for each CEM installed if it has been provided by operator otherwise state “NP” (NOT PROVIDED)

---

## 2 Monitoring Deviations

---

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1.

**There were modifications** to the sampling procedures (TPDs) listed in section 4. These are as follows:

Due to air freight restrictions on transporting hazardous solutions, it was not possible to ship the impinger and rinse solutions for sampling Heavy Metals and Mercury (all contain Nitric Acid). DI H<sub>2</sub>O was substituted instead as the capture and rinsing solution for the sampling of Heavy Metals & Mercury. This is likely to mean that the results for these parameters are underestimates of the true emissions concentrations.

Due to high duct gas velocity, in order to maintain isokinetic sampling, it was necessary to use a nozzle with diameter smaller than the recommended minimum of 8mm minimum stated in BS EN 13284-1:2017. Note that there is no absolute minimum nozzle size stated in the standard, as long as the uncertainty of the nozzle area is <5%. **So this does not need to be described as a non-conforming test.**

**There were substance deviations** from the original and agreed emissions monitoring schedule. These are as follows:

Due to high particulate loading on the filter for Dioxins & Furans during sampling on medium medical waste, the sample time was reduced from 6 hours to 5 hours.

Due to limited dead animal & meat feedstock availability during this testing phase, sample time was reduced for Heavy Metals & Mercury from 2 hours to 1 hour. Additionally, Dioxins & Furans sample time was reduced from 6 hours to 1 hour.

**Non-conforming tests** are as follows:

**The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.**

Environmental Compliance Limited

Selibon N.V.  
Permit No  
Variation No  
Report Ref

: ...  
: ...  
: P5632 : R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

Due to customs delays for samples returning from site and back to the UK, holding times between sampling and analysis exceeded the maximum allowed in the sampling standards for the following determinands – HF, Mercury, Heavy Metals, HCl, SO<sub>2</sub> and Dioxins & Furans, consequently, these tests cannot hold UKAS/MCERTS accreditation.

Due to customs holding times, and transportation of samples, the sample temperature storage requirements stated in the sampling standards for Dioxins & Furans, Heavy Metals & Mercury, HF, HCl & SO<sub>2</sub> could not be achieved from the time of sampling until ECL received the samples back in the UK, consequently, these tests cannot hold UKAS/MCERTS accreditation.

During the sampling of Carbon Monoxide (CO), at various operating conditions, data values recorded for CO exceeded the maximum linearised range of the sampling analyser.

Heavy Metals & Mercury were sampled into the same sampling train, this is a deviation from the sampling standards, but as DI water was used instead of the standard impinger and rinse solutions for these parameters, then it is appropriate to combine them in the same test, consequently, these tests cannot hold UKAS/MCERTS accreditation.

Due to a delay on site, resulting in temporary postponement and redeployment, the hydrogen peroxide sampling solution transported to site for sampling sulphur dioxide exceeded the 1-month expiry date before sampling took place.

Due to more samples being taken than was originally planned in Q001 (before sampling solutions were shipped), there was insufficient sampling solution for a daily blank for TPM, HCl, HF and SO<sub>2</sub>. Consequently, the second and third samples for these parameters share a blank taken on the second day.

Due to high oxygen content in the stack, it was not possible (within the practical limitations of the sampling equipment and when using the maximum nozzle size available at which isokinetic sampling could be maintained) to achieve the minimum particulate sampling volume (V<sub>min</sub>) as calculated using Annex E of BS EN 13284-1:2017. This means that particulate samples must be described as non-conforming tests. Furthermore, again due to elevated oxygen content, the oxygen corrected sample volumes are much reduced and the blank values for TPM, Heavy Metals and Cadmium & Thallium have exceeded 10% of the ELV, consequently, these tests cannot hold UKAS/MCERTS accreditation.

**Homogeneity tests** have not been completed for pollutants at the following locations: **Incinerator Exhaust**. Such tests are not applicable to this location (as the duct area is <1m<sup>2</sup>) and were not requested by the client.



Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632

: R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## PART 2 – SUPPORTING INFORMATION

### 3 SAMPLING STAFF DETAILS

#### Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Scott Hackett	12 <sup>th</sup> – 16 <sup>th</sup> February 2024	MM 07 889	2	TE1, TE2, TE3, TE4
Llion Preskett Hughes		MM 22 1689	1	...

#### Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

#### Technical Endorsement Key:-

- TE1 – Isokinetic** Particulates, Temperature & Velocity Profiles, Oxygen.
- TE2 – Isokinetic** Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.
- TE3 – Non-Isokinetic** Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.
- TE4 – Continuous Analysers** (Combustion Gases):- TVOC, CO, NO<sub>x</sub>, SO<sub>2</sub>.

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## 4 SAMPLING PROTOCOLS / METHODOLOGIES

Details of the substances monitored, the standard methods used and the Environmental Compliance Limited Technical Procedures used during this survey are shown in the table below. Detailed sampling protocols are included in a separate document which will be sent with the report.

In all cases, where analysis of collected samples was required, the analysis was by a subcontract laboratory. Details of the sub-contract laboratory are shown on the analysis certificates in this report. The UKAS/MCERTS accreditation status of the analysis is also indicated on the certificates.

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Determinand	External Reference Method	ECL Technical Procedure Number
Velocity and Flowrate	BS EN 16911-1:2013 & MID	ECL/ TPD/ 022A
Particulates (MST)	BS EN 13284-1:2017 & MID	ECL / TPD / 027
Heavy Metals	BS EN 14385:2004 & MID	ECL / TPD / 028
Mercury	BS EN 13211:2001	ECL / TPD / 030
PCDDs & PCDFs	BS EN 1948-1 to 3:2006 & MID	ECL / TPD / 031
Oxygen (PG350 E)	BS EN 14789: 2017	ECL / TPD / 033D
Carbon Monoxide (PG350E)	BS EN 15058: 2017	ECL / TPD / 033D
Oxides of Nitrogen (PG350 E)	BS EN 14792: 2017	ECL / TPD / 033D
Carbon Dioxide (PG350 E)	PD CEN/TS 17405:2020	ECL / TPD / 033D
Hydrogen Chloride	BS EN 1911:2010	ECL / TPD / 081
Sulphur Dioxide	BS EN 14791:2017	ECL / TPD / 039
Moisture	BS EN 14790: 2017	ECL / TPD / 082
Hydrogen Fluoride	PD CEN/TS 17340:2020	ECL / TPD / 081

Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632

: R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

---

## 5 SAMPLE POINT DESCRIPTIONS

---

The homogeneity test is applicable to combustion processes, but may also be requested by the regulator for non-combustion processes.

Homogeneity testing has not been completed at this location.

The test is not usually required for stacks with sampling plane areas of  $<1\text{m}^2$  (below 1.13m in diameter for circular ducts).

**The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.**

---

**The sample location that was monitored is detailed below:**

---

### **Incinerator Exhaust**

---

The stack diameter is 0.30m and the sample platform width back from the sample port is 1.4m.

A single 4-inch BSP sample port is location in a straight section of duct, approximately 1.3m from the working temporary platform.

**Environmental Compliance Limited**

Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

**EQUIPMENT IDs  
(Pre site checklist from SSP)**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:
MST console/pump	E001	U010							
MST Nozzle set		402							
MST “S” Type Pitot		602							
MST Probe		1328							
MST Probe Thermocouple		1329							
MST Hot Box		978							
MST Impinger Arm		660							
Barometer		204							
Site Balance		368							
Site Check weights		598							
		599							
Horiba	E002	1264							
Heated Probe / Filter		1348							
Chiller		971							
MFC									
Heated Line		1346	1347						
FID	E003								
Heated Line									
Heated Probe / Filter									
Testo	E004								
FTIR	E005								
Heated Probe / Filter									
Heated Line									
Stackmite	E006								
“L” Type Pitot									
Digital Manometer									
Stack Thermocouple									
Thermocouple Reader									
Nozzle Set									
Workhorse Pumps	E007								
Stack Thermocouple									
Tube Thermocouple									
Meter Thermocouple									
High Vac Gauge									
Dioxin Thermocouple		938							

Quantity of Ice Required / Used for Survey	30	Bags (2kg bags)
--	----	-----------------

Environmental Compliance Limited

Selibon N.V.

Permit No : ...

Variation No : ...

Report Ref : P5632 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date.

: Incinerator Exhaust

: Emissions Survey – February 2024

: 12th – 16th February 2024


: 20th December 2024

## FIGURES


Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Figure 1 – Combustion Gases**




**Figure 2 – Carbon Dioxide**




Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Figure 3 – Combustion Gases**



**Figure 4 – Carbon Dioxide**







Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date : 20th December 2024

### Figure 5 – Combustion Gases




### Figure 6 – Carbon Dioxide




Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date : 20th December 2024

### Figure 7 – Combustion Gases



### Figure 8 – Carbon Dioxide



**Environmental Compliance Limited**

Selibon N.V.  
Permit No  
Variation No  
Report Ref

: ...  
: ...  
: P5632 : R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

## **TABLES**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 1 – Particulates & HCl/HF Light Medical Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator Exhaust - Incinerator

Emission Parameter	Units	TPM / HCL & HF 1	Blank
Stack Diameter	metres	0.30	...
Area of Sample Plane	m <sup>2</sup>	0.071	...
Moisture Content	%	4.66	...
Oxygen Content	%	16.53	...
Stack Temperature	°C	264	...
Gas Velocity (as Measured. Adjusted for Smooth Walls)	m/sec	14.6343	...
Gas Velocity (Reference Conditions)	m/sec*	1.7361	...
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	1.0344	...
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.1227	...
Dry Gas Molecular Weight	g/gmole	29.1749	
Sample Date	...	13/02/2024	...
Sample Period	...	10:15 - 11:15	...
Sample Volume (reference Conditions)	m <sup>3</sup> *	0.249	0.249
Isokinetic Sampling Rate	%	99.13	...
Sample Reference (ECL ID)	ECL/24/	0411 & 0412	0417 & 0418
Mass of Particulate Matter Collected	mg	194.10	4.00
Concentration of Particulate Matter	mg/m <sup>3</sup> *	<b>778.40</b>	16.04
Emission Rate of Particulate Matter	g/hr	343.88	...
Expanded Uncertainty (% Relative)	%	5	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	3.6	...
Blank Concentration as Percentage of ELV	%	...	445.59
Sample Reference (ECL ID)	ECL/24/	0437 & 0438	0441
Mass of Hydrogen Chloride Collected	mg	161.70	0.01
Concentration of Hydrogen Chloride	mg/m <sup>3</sup> *	<b>648.46</b>	0.06
Emission Rate of Hydrogen Chloride	g/hr	286.48	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	30	...
Impinger Collection Efficiency	%	100	...
Blank Concentration as Percentage of ELV	%	...	<1.00%
Sample Reference	ECL/24/	0437 & 0438	0441
Mass of Hydrogen Fluoride Collected	mg	0.91	0.01
Concentration of Hydrogen Fluoride	mg/m <sup>3</sup> *	<b>3.64</b>	0.06
Emission Rate of Hydrogen Fluoride	g/hr	1.61	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	10	...
Impinger Collection Efficiency	%	99	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

\*Reference Conditions ( 273K, 101.3kPa, 3% Oxygen, Dry Gas )

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 2 – Sulphur Dioxide Light Medical Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator Exhaust - Incinerator

Emission Parameter	Units	Sulphur Dioxide 1	Blank
Stack Diameter	metres	0.30	
Area of Sample Plane	m <sup>2</sup>	0.071	
Moisture Content	%	4.97	
Oxygen Content	%	17.19	
Stack Temperature	°C	250	
Gas Velocity (as Measured)	m/sec	16.40	
Gas Velocity (Reference Conditions)	m/sec*	1.39	
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	1.16	
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.10	
Dry Gas Molecular Weight	g/gmole	29.09543165	
Sample Date	...	13/02/2024	
Sample Period	...	12:25 - 13:25	
Sample Volume (reference Conditions)	m <sup>3</sup> *	0.181	0.181
Sample Reference	ECL/24/	0443 & 0444	0447
Mass of Sulphur Dioxide Collected	mg	9.95	0.18
Concentration of Sulphur Dioxide	mg/m <sup>3</sup> *	54.85	0.99
Emission Rate of Sulphur Dioxide	g/hr	19.44	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	20.7	...
Impinger Collection Efficiency	%	99	...
Blank Concentration as Percentage of ELV	%	...	4.81

\*Reference Conditions ( 273K, 101.3kPa, 3% Oxygen, Dry Gas )

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Table 3 – Heavy Metals & Mercury Light Medical Waste (3% Oxygen & Dry Gas)

Sampling Location: Incinerator Incinerator Exhaust

Test Heavy Metals & Hg											
Stack Profile:	Circular	Units	Gas velocity (as Measured. Adjusted for Smooth Walls):				13.7056	m/sec			
Diameter:	0.30	m	Gas velocity ( Reference Conditions):				1.8370	m/sec *			
			Volumetric Flowrate ( as Measured):				0.9688	m <sup>3</sup> /sec			
Area of sample plane:	0.071	m <sup>2</sup>	Volumetric Flowrate ( Reference Conditions):				0.1298	m <sup>3</sup> /sec *			
Moisture Content:	4.42	%	Sample Date:				13/02/2024				
Stack Temperature:	198	°C	Sample Period:				13:55 - 15:55				
Barometric Pressure:	1015	mbar	Sample Volume:				0.516	m <sup>3</sup>			
Measured Oxygen:	16.65	%	Isokinetic Rate ( 95% < ISOKx > 115%):				98.62	%			
*Reference Conditions: (273K, 101.3kPa, 3% Oxygen, Dry Gas)											
Trace Element	Symbol	Mass ( mg )			ECL/24/421 - 424 Concentration ( mg/m <sup>3</sup> )*			Emission Rate ( g/hr )*	Uncertainty (%) Total Element Phase	ECL/24/433 - 436	
		Particulate Phase	Vapour Phase	Total Element Phase	Particulate Phase	Vapour Phase	Total Element Phase			Blank	
										Mass ( mg )	Conc. ( mg/m <sup>3</sup> )
Antimony	Sb	0.065	0.012	0.077	0.13	0.023	0.15	0.069	15	0.00070	0.0014
Arsenic	As	0.0012	0.00015	0.0014	0.0023	0.00030	0.0026	0.0012	13	0.00076	0.0015
Cadmium	Cd	0.0016	0.00010	0.0017	0.0031	0.00020	0.0043	0.0020	14	0.0022	0.0043
Chromium	Cr	0.011	0.00030	0.011	0.020	0.00059	0.021	0.0098	14	0.0015	0.0029
Cobalt	Co	0.00070	0.00010	0.00080	0.0014	0.00020	0.0016	0.00073	14	0.00060	0.0012
Copper	Cu	0.31	0.0013	0.31	0.61	0.0025	0.61	0.28	15	0.0013	0.0025
Lead	Pb	0.027	0.0019	0.029	0.052	0.0037	0.055	0.026	15	0.0039	0.0076
Manganese	Mn	0.022	0.00061	0.022	0.042	0.0012	0.043	0.020	18	0.0066	0.013
Mercury	Hg	0.00017	0.00026	0.00043	0.00034	0.00050	0.00083	0.00039	12	0.00037	0.00072
Nickel	Ni	0.023	0.00062	0.023	0.044	0.0012	0.045	0.021	14	0.00086	0.0017
Thallium	Tl	0.00040	0.00010	0.00050	0.00077	0.00020	0.00098	0.00046	14	0.00050	0.00098
Vanadium	V	0.00080	0.000085	0.00088	0.0015	0.00016	0.0022	0.0010	14	0.0012	0.0022
Mercury		0.00017	0.00026	0.00043	0.00034	0.00050	0.00083	0.00039	7	0.00037	0.00072
Cadmium & Thallium		0.0020	0.00020	0.0022	0.0039	0.00040	0.0052	0.0025	5	0.0027	0.0052
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium		0.46	0.017	0.48	0.89	0.033	0.93	0.43	6	0.017	0.034

Blank<10% of ELV  
 Blank>10% of ELV!  
 Blank>10% of ELV!

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m<sup>3</sup>) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

**Table 3b – Heavy Metals Efficiencies & Mercury  
 Light Medical Waste (3% Oxygen & Dry Gas)**

<b>Metals groups have been selected. Efficiencies will only be displayed for individual elements if the group total concentration is greater than 30% of the associated ELV.</b>				
<b>Recovery in the final impinger must be &lt;10% of the total combined element mass (i.e. filter, probe rinse &amp; impingers) to pass - ONLY if the element makes up &gt;1% of the total mass of all metals collected</b>				
Trace Element	Symbol	Final Impinger (%)	<10%?	<1% of Total?
Antimony	Sb	N/A	N/A	NO
Arsenic	As	N/A	N/A	YES
Cadmium	Cd	N/A	N/A	NO
Chromium	Cr	N/A	N/A	NO
Cobalt	Co	N/A	N/A	YES
Copper	Cu	N/A	N/A	NO
Lead	Pb	N/A	N/A	NO
Manganese	Mn	N/A	N/A	NO
Mercury	Hg	N/A	N/A	NO
Nickel	Ni	N/A	N/A	NO
Thallium	Tl	N/A	N/A	NO
Vanadium	V	N/A	N/A	YES

Combined Groups	ELV mg/m <sup>3</sup>	Result <30% ELV?
Mercury	0.02	YES
Cadmium & Thallium	0.015	NO
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium	0.15	NO

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 4 – Particulates & HCl/HF Medium Bin Medical Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator Exhaust - Incinerator

Emission Parameter	Units	TPM / HCL & HF 2	Blank
Stack Diameter	metres	0.30	...
Area of Sample Plane	m <sup>2</sup>	0.071	...
Moisture Content	%	4.39	...
Oxygen Content	%	16.26	...
Stack Temperature	°C	480	...
Gas Velocity (as Measured. Adjusted for Smooth Walls)	m/sec	39.0171	...
Gas Velocity (Reference Conditions)	m/sec*	3.5250	...
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	2.7580	...
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.2492	...
Dry Gas Molecular Weight	g/gmole	29.1830	
Sample Date	...	14/02/2024	...
Sample Period	...	09:25 - 10:25	...
Sample Volume (reference Conditions)	m <sup>3</sup> *	0.266	0.266
Isokinetic Sampling Rate	%	97.53	...
Sample Reference (ECL ID)	ECL/24/	0413 & 0414	0419 & 0420
Mass of Particulate Matter Collected	mg	116.10	4.51
Concentration of Particulate Matter	mg/m <sup>3</sup> *	436.00	16.94
Emission Rate of Particulate Matter	g/hr	391.09	...
Expanded Uncertainty (% Relative)	%	5	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	3.6	...
Blank Concentration as Percentage of ELV	%	...	470.46
Sample Reference (ECL ID)	ECL/24/	0439	0442
Mass of Hydrogen Chloride Collected	mg	84.05	0.01
Concentration of Hydrogen Chloride	mg/m <sup>3</sup> *	315.64	0.05
Emission Rate of Hydrogen Chloride	g/hr	283.13	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	30	...
Blank Concentration as Percentage of ELV	%	...	<1.00%
Sample Reference	ECL/24/	0439	0442
Mass of Hydrogen Fluoride Collected	mg	1.57	0.01
Concentration of Hydrogen Fluoride	mg/m <sup>3</sup> *	5.91	0.05
Emission Rate of Hydrogen Fluoride	g/hr	5.30	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	10	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

\*Reference Conditions ( 273K, 101.3kPa, 3% Oxygen, Dry Gas )



Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 5 – Sulphur Dioxide Medium Bin Medical Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator Exhaust - Incinerator

Emission Parameter	Units	Sulphur Dioxide 2	Blank
Stack Diameter	metres	0.30	
Area of Sample Plane	m <sup>2</sup>	0.071	
Moisture Content	%	4.68	
Oxygen Content	%	16.13	
Stack Temperature	°C	508	
Gas Velocity (as Measured)	m/sec	42.68	
Gas Velocity (Reference Conditions)	m/sec*	3.54	
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	3.02	
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.25	
Dry Gas Molecular Weight	g/gmole	29.19861109	
Sample Date	...	14/02/2024	
Sample Period	...	11:20 - 12:20	
Sample Volume (reference Conditions)	m <sup>3</sup> *	0.221	0.221
Sample Reference	ECL/24/	0445	0448
Mass of Sulphur Dioxide Collected	mg	6.86	0.18
Concentration of Sulphur Dioxide	mg/m <sup>3</sup> *	31.04	0.82
Emission Rate of Sulphur Dioxide	g/hr	27.93	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	20.7	...
Blank Concentration as Percentage of ELV	%	...	3.94

\*Reference Conditions ( 273K, 101.3kPa, 3% Oxygen, Dry Gas )

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 6 – Heavy Metals & Mercury Medium Bin Medical Waste (3% Oxygen & Dry Gas)

Sampling Location: Incinerator Incinerator Exhaust

Test Heavy Metals & Hg 2												
Stack Profile:	Circular	Units	Gas velocity (as Measured. Adjusted for Smooth Walls):						40.4285	m/sec		
Diameter:	0.30	m	Gas velocity ( Reference Conditions):						3.0184	m/sec *		
			Volumetric Flowrate ( as Measured):						2.8577	m <sup>3</sup> /sec		
Area of sample plane:	0.071	m <sup>2</sup>	Volumetric Flowrate ( Reference Conditions):						0.2134	m <sup>3</sup> /sec *		
Moisture Content:	4.29	%	Sample Date:						14/02/2024			
Stack Temperature:	440	°C	Sample Period:						13:33 - 15:43			
Barometric Pressure:	1016	mbar	Sample Volume:						0.442	m <sup>3</sup>		
Measured Oxygen:	17.35	%	Isokinetic Rate ( 95% < ISOKx > 115%):						96.00	%		
*Reference Conditions: (273K, 101.3kPa, 3% Oxygen, Dry Gas)												
Trace Element	Symbol	Mass ( mg )			ECL/24/425 - 428			Emission Rate ( g/hr )*	Uncertainty (%)	ECL/24/433 - 436		
					Concentration ( mg/m <sup>3</sup> )*					Blank		
		Particulate Phase	Vapour Phase	Total Element Phase	Particulate Phase	Vapour Phase	Total Element Phase			Mass ( mg )	Conc. ( mg/m <sup>3</sup> )	
Antimony	Sb	0.046	0.0015	0.047	0.10	0.0034	<b>0.11</b>	<b>0.083</b>	18	0.00070	0.0016	
Arsenic	As	0.00090	0.00082	0.0017	0.0020	0.0019	<b>0.0039</b>	<b>0.0030</b>	13	0.00076	0.0017	
Cadmium	Cd	0.0012	0.00019	0.0014	0.0027	0.00043	<b>0.0050</b>	<b>0.0038</b>	14	0.0022	0.0050	
Chromium	Cr	0.099	0.00081	0.10	0.22	0.0018	<b>0.23</b>	<b>0.17</b>	15	0.0015	0.0034	
Cobalt	Co	0.0014	0.00019	0.0016	0.0032	0.00043	<b>0.0036</b>	<b>0.0028</b>	14	0.00060	0.0014	
Copper	Cu	0.056	0.0022	0.058	0.13	0.0049	<b>0.13</b>	<b>0.10</b>	15	0.0013	0.0030	
Lead	Pb	0.011	0.0019	0.013	0.025	0.0043	<b>0.029</b>	<b>0.022</b>	15	0.0039	0.0088	
Manganese	Mn	0.023	0.00096	0.024	0.052	0.0022	<b>0.054</b>	<b>0.042</b>	18	0.0066	0.015	
Mercury	Hg	0.00022	0.00048	0.00070	0.00050	0.0011	<b>0.0016</b>	<b>0.0012</b>	13	0.00037	0.00084	
Nickel	Ni	0.038	0.00090	0.039	0.087	0.0020	<b>0.089</b>	<b>0.068</b>	15	0.00086	0.0019	
Thallium	Tl	0.00040	0.00019	0.00059	0.00091	0.00043	<b>0.0013</b>	<b>0.0010</b>	14	0.00050	0.0011	
Vanadium	V	0.0029	0.00017	0.0031	0.0066	0.00039	<b>0.0070</b>	<b>0.0053</b>	15	0.0012	0.0026	
Mercury		0.00022	0.00048	0.00070	0.00050	0.0011	<b>0.0016</b>	<b>0.0012</b>	7	0.00037	0.00084	
Cadmium & Thallium		0.0016	0.00038	0.0020	0.0036	0.00087	<b>0.0063</b>	<b>0.0049</b>	4	0.0027	0.0061	
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium		0.28	0.0094	0.29	0.63	0.021	<b>0.65</b>	<b>0.50</b>	4	0.017	0.039	

Blank<10% of ELV  
 Blank>10% of ELV!  
 Blank>10% of ELV!

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m<sup>3</sup>) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 6b – Heavy Metals Efficiencies & Mercury Medium Bin Medical Waste (3% Oxygen & Dry Gas)

<b>Metals groups have been selected. Efficiencies will only be displayed for individual elements if the group total concentration is greater than 30% of the associated ELV.</b>				
Recovery in the final impinger must be <10% of the total combined element mass (i.e. filter, probe rinse & impingers) to pass - ONLY if the element makes up >1% of the total mass of all metals collected				
Trace Element	Symbol	Final Impinger (%)	<10%?	<1% of Total?
Antimony	Sb	N/A	N/A	NO
Arsenic	As	N/A	N/A	YES
Cadmium	Cd	N/A	N/A	NO
Chromium	Cr	N/A	N/A	NO
Cobalt	Co	N/A	N/A	YES
Copper	Cu	N/A	N/A	NO
Lead	Pb	N/A	N/A	NO
Manganese	Mn	N/A	N/A	NO
Mercury	Hg	N/A	N/A	NO
Nickel	Ni	N/A	N/A	NO
Thallium	Tl	N/A	N/A	NO
Vanadium	V	N/A	N/A	NO

Combined Groups	ELV mg/m <sup>3</sup>	Result <30% ELV?
Mercury	0.02	YES
Cadmium & Thallium	0.015	NO
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium	0.15	NO

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632

: Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Table 7 – Chlorinated Dioxins & Furans Medium Bin Medical Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator - Stack Incinerator Exhaust

Emission Parameter	Units	Chlorinated D & F		
Stack Diameter	metres	0.3		
-	-	-		
Area of sample plane	m <sup>2</sup>	0.071		
Moisture Content	%	3.26		
Moisture Expanded Uncertainty	%(Relative)	5.42		
Stack Temperature	°C	497		
Oxygen Concentration	%	15.19		
Gas velocity (as Measured)	m/sec	47.8223		
Gas velocity (Reference Conditions)	m/sec*	5.3104		
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	3.3804		
Volumetric Flowrate (Reference)	m <sup>3</sup> /sec*	0.3754		
Sample Date	15/02/2024			
Sample Period	09:40 - 14:50			
Sample Reference	ECL/24/0402 - 0404			
Sample Volume (Reference Conditions)	m <sup>3</sup> *	1.98		
Isokinetic Sampling Rate	%	97.61		
Species	Sample Reference: ECL/24/0402 - 0404		Blank Reference: ECL/24/0408 - 0410	
	Conc. ng/m <sup>3</sup> *	TEQ ng/m <sup>3</sup> *	Conc. ng/m <sup>3</sup> *	TEQ ng/m <sup>3</sup> *
Chlorinated Dioxins 2,3,7,8 Isomers	16.39	6.27	0.0016	0.00017
Total Chlorinated Dioxins Non – Targeted Isomers	0.00	...	0.00	...
Chlorinated Furans 2,3,7,8 Isomers	91.17	14.59	0.0018	0.00025
Total Chlorinated Furans Non – Targeted Isomers	0.00	...	0.00	...
<b>TOTAL</b>	...	<b>20.86</b>	...	<b>0.00042</b>
<b>Range</b>	...	<b>20.86 - 20.86</b>	Blank <10% of ELV?	YES
<b>% Uncertainty</b>	...	15		

\*Reference Conditions 273K, 101.3kPa, 3% Oxygen, Dry Gas. NB: For each congener, where the blank concentration exceeds or equals the measured concentration, the blank value has been substituted. Refer to the table of individual congeners for more detailed information.

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Table 7b – Chlorinated Dioxins & Furans Medium Bin Medical Waste (3% Oxygen & Dry Gas)

Data Recorded from Incinerator - Stack Incinerator Exhaust on the 15/02/24, 09:40 - 14:50

Species	Blank Reference: ECL/24/0408 - 0410 TEQ ng/m <sup>3</sup> *	EEC Toxic Equivalent Factor (TEF)	Sample Ref.: ECL/24/0402 - 0404		WHO Humans & Mammals (TEF)	Humans & Mammals TEQ ng/m <sup>3</sup> *	WHO Fish (TEF)	Fish TEQ ng/m <sup>3</sup> *	WHO Birds (TEF)	Birds TEQ ng/m <sup>3</sup> *
			Concentration ng/m <sup>3</sup> *	TEQ ng/m <sup>3</sup> *						
<b>Chlorinated Dioxins - 2,3,7,8 Isomers</b>										
2,3,7,8 - TCDD	0.000071	1	3.23	3.23	1	3.23	1	3.23	1	3.23
1,2,3,7,8 - PCDD	0.000048	0.5	5.06	2.53	1	5.06	1	5.06	1	5.06
1,2,3,4,7,8 - HxCDD	0.000016	0.1	1.34	0.13	0.1	0.13	0.5	0.67	0.05	0.067
1,2,3,6,7,8 - HxCDD	0.000018	0.1	1.44	0.14	0.1	0.14	0.01	0.014	0.01	0.014
1,2,3,7,8,9 - HxCDD	0.000019	0.1	2.05	0.20	0.1	0.20	0.01	0.020	0.1	0.20
1,2,3,4,6,7,8 - HpCDD	0.000002	0.01	2.39	0.024	0.01	0.024	0.001	0.0024	0.001	0.0024
OCDD	0.000001	0.001	0.88	0.00088	0.0001	0.00088	0	...	0	...
<b>Total Chlorinated Dioxins - Non - Targeted Isomers</b>										
TCDD	...	0	0.000000	...	0	...	0	...	0	...
PCDD	...	0	0.000000	...	0	...	0	...	0	...
HxCDD	...	0	0.000000	...	0	...	0	...	0	...
HpCDD	...	0	0.000000	...	0	...	0	...	0	...
<b>Chlorinated Furans - 2,3,7,8 Isomers</b>										
2,3,7,8 - TCDF	0.000014	0.1	20.44	2.04	0.1	2.04	0.05	1.02	1	20.44
1,2,3,7,8 - PCDF	0.000007	0.05	19.23	0.96	0.05	0.96	0.05	0.96	0.1	1.92
2,3,4,7,8 - PCDF	0.00019	0.5	18.07	9.03	0.5	9.03	0.5	9.03	1	18.07
1,2,3,4,7,8 - HxCDF	0.000010	0.1	9.11	0.91	0.1	0.91	0.1	0.91	0.1	0.91
1,2,3,6,7,8 - HxCDF	0.000008	0.1	9.62	0.96	0.1	0.96	0.1	0.96	0.1	0.96
2,3,4,6,7,8 - HxCDF	0.000008	0.1	5.52	0.55	0.1	0.55	0.1	0.55	0.1	0.55
1,2,3,7,8,9 - HxCDF	0.000009	0.1	0.44	0.044	0.1	0.044	0.1	0.044	0.1	0.044
1,2,3,4,6,7,8 - HpCDF	0.000002	0.01	6.88	0.069	0.01	0.069	0.01	0.069	0.01	0.069
1,2,3,4,7,8,9 - HpCDF	0.000003	0.01	0.99	0.0099	0.01	0.0099	0.01	0.0099	0.01	0.0099
OCDF	0.000000	0.001	0.87	0.00087	0.0001	0.00087	0.0001	0.00087	0.0001	0.00087
<b>Total Chlorinated Furans - Non - Targeted Isomers</b>										
TCDF	...	0	0.000000	...	0	...	0	...	0	...
PCDF	...	0	0.000000	...	0	...	0	...	0	...
HxCDF	...	0	0.000000	...	0	...	0	...	0	...
HpCDF	...	0	0.000000	...	0	...	0	...	0	...
<b>TOTAL</b>	<b>0.00042</b>	...	...	<b>20.86</b>	...	<b>23.39</b>	...	<b>22.56</b>	...	<b>51.56</b>
<b>Range</b>	...	...	...	<b>20.86 - 20.86</b>	...	<b>23.39 - 23.39</b>	...	<b>22.56 - 22.56</b>	...	<b>51.56 - 51.56</b>
<b>% Uncertainty</b>	...	...	...	<b>15</b>	...	<b>15</b>	...	<b>15</b>	...	<b>17</b>

\*Reference Conditions 273K, 101.3kPa, 3% Oxygen, Dry Gas. NB: For each congener, where the blank concentration exceeds or equals the measured concentration, the blank value has been substituted. This is presented as shaded cells. Where the Limit of Detection applies, concentrations are presented in italics.

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 8 – Particulates & HCl/HF Dead Animal Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator Exhaust - Incinerator

Emission Parameter	Units	TPM / HCL & HF 3	Blank
Stack Diameter	metres	0.30	...
Area of Sample Plane	m <sup>2</sup>	0.071	...
Moisture Content	%	11.54	...
Oxygen Content	%	18.42	...
Stack Temperature	°C	367	...
Gas Velocity (as Measured. Adjusted for Smooth Walls)	m/sec	43.4559	...
Gas Velocity (Reference Conditions)	m/sec*	2.2856	...
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	3.0717	...
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.1616	...
Dry Gas Molecular Weight	g/gmole	29.0246	
Sample Date	...	15/02/2024	...
Sample Period	...	16:00 - 17:00	...
Sample Volume (reference Conditions)	m <sup>3</sup> *	0.198	0.198
Isokinetic Sampling Rate	%	109.86	...
Sample Reference (ECL ID)	ECL/24/	0415 & 0416	0419 & 0420
Mass of Particulate Matter Collected	mg	46.20	4.51
Concentration of Particulate Matter	mg/m <sup>3</sup> *	233.26	22.77
Emission Rate of Particulate Matter	g/hr	135.67	...
Expanded Uncertainty (% Relative)	%	8	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	3.6	...
Blank Concentration as Percentage of ELV	%	...	632.51
Sample Reference (ECL ID)	ECL/24/	0440	0442
Mass of Hydrogen Chloride Collected	mg	8.28	0.01
Concentration of Hydrogen Chloride	mg/m <sup>3</sup> *	41.82	0.07
Emission Rate of Hydrogen Chloride	g/hr	24.33	...
Expanded Uncertainty (% Relative)	%	15	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	30	...
Blank Concentration as Percentage of ELV	%	...	<1.00%
Sample Reference	ECL/24/	0440	0442
Mass of Hydrogen Fluoride Collected	mg	3.31	0.01
Concentration of Hydrogen Fluoride	mg/m <sup>3</sup> *	16.70	0.07
Emission Rate of Hydrogen Fluoride	g/hr	9.71	...
Expanded Uncertainty (% Relative)	%	15	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	10	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

\*Reference Conditions ( 273K, 101.3kPa, 3% Oxygen, Dry Gas )

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 9 – Sulphur Dioxide Dead Animal Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator Exhaust - Incinerator

Emission Parameter	Units	Sulphur Dioxide 3	Blank
Stack Diameter	metres	0.30	
Area of Sample Plane	m <sup>2</sup>	0.071	
Moisture Content	%	13.29	
Oxygen Content	%	6.71	
Stack Temperature	°C	766	
Gas Velocity (as Measured)	m/sec	44.10	
Gas Velocity (Reference Conditions)	m/sec*	12.95	
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	3.12	
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.92	
Dry Gas Molecular Weight	g/gmole	29.99809191	
Sample Date	...	15/02/2024	
Sample Period	...	17:45 - 18:45	
Sample Volume (reference Conditions)	m <sup>3</sup> *	0.624	0.624
Sample Reference	ECL/24/	0446	0448
Mass of Sulphur Dioxide Collected	mg	629.10	0.18
Concentration of Sulphur Dioxide	mg/m <sup>3</sup> *	1008.11	0.29
Emission Rate of Sulphur Dioxide	g/hr	3322.07	...
Expanded Uncertainty (% Relative)	%	13	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	20.7	...
Blank Concentration as Percentage of ELV	%	...	1.40

\*Reference Conditions ( 273K, 101.3kPa, 3% Oxygen, Dry Gas )

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 10 – Heavy Metals & Mercury Dead Animal Waste (3% Oxygen & Dry Gas)

Sampling Location: Incinerator Incinerator Exhaust

Test Heavy Metals & Hg 3											
Stack Profile:	Circular	Units	Gas velocity (as Measured. Adjusted for Smooth Walls):				45.2755	m/sec			
Diameter:	0.30	m	Gas velocity ( Reference Conditions):				7.7906	m/sec *			
			Volumetric Flowrate ( as Measured):				3.2003	m <sup>3</sup> /sec			
Area of sample plane:	0.071	m <sup>2</sup>	Volumetric Flowrate ( Reference Conditions):				0.5507	m <sup>3</sup> /sec *			
Moisture Content:	11.29	%	Sample Date:				15/02/2024				
Stack Temperature:	343	°C	Sample Period:				19:45 - 20:45				
Barometric Pressure:	1015	mbar	Sample Volume:				0.644	m <sup>3</sup>			
Measured Oxygen:	13.16	%	Isokinetic Rate ( 95% < ISOKx > 115%):				108.49	%			
*Reference Conditions: (273K, 101.3kPa, 3% Oxygen, Dry Gas)											
Trace Element	Symbol	Mass ( mg )			ECL/24/429 - 432			Emission Rate ( g/hr )*	Uncertainty (%)	ECL/24/433 - 436	
					Concentration ( mg/m <sup>3</sup> )*					Blank	
		Particulate Phase	Vapour Phase	Total Element Phase	Particulate Phase	Vapour Phase	Total Element Phase			Mass ( mg )	Conc. ( mg/m <sup>3</sup> )
Antimony	Sb	0.0070	0.00021	0.0072	0.011	0.00032	<b>0.011</b>	0.022	15	0.00070	0.0011
Arsenic	As	0.0032	0.00022	0.0034	0.0050	0.00034	<b>0.0053</b>	0.011	12	0.00076	0.0012
Cadmium	Cd	0.0011	0.00015	0.0012	0.0017	0.00023	<b>0.0034</b>	0.0068	12	0.0022	0.0034
Chromium	Cr	0.020	0.00069	0.020	0.031	0.0011	<b>0.032</b>	0.063	13	0.0015	0.0023
Cobalt	Co	0.00050	0.00015	0.00065	0.00078	0.00023	<b>0.0010</b>	0.0020	11	0.00060	0.00094
Copper	Cu	0.046	0.00042	0.046	0.071	0.00065	<b>0.072</b>	0.14	13	0.0013	0.0020
Lead	Pb	0.061	0.0028	0.064	0.095	0.0044	<b>0.099</b>	0.20	13	0.0039	0.0061
Manganese	Mn	0.0063	0.00069	0.0070	0.0098	0.0011	<b>0.011</b>	0.022	15	0.0066	0.010
Mercury	Hg	0.00018	0.00037	0.00055	0.00027	0.00057	<b>0.00085</b>	0.0017	10	0.00037	0.00058
Nickel	Ni	0.0066	0.00040	0.0070	0.010	0.00062	<b>0.011</b>	0.022	12	0.00086	0.0013
Thallium	Tl	0.00050	0.00015	0.00065	0.00078	0.00023	<b>0.0010</b>	0.0020	12	0.00050	0.00078
Vanadium	V	0.00050	0.000074	0.00057	0.00078	0.00011	<b>0.0018</b>	0.0035	12	0.0012	0.0018
Mercury		0.00018	0.00037	0.00055	0.00027	0.00057	<b>0.00085</b>	0.0017	6	0.00037	0.00058
Cadmium & Thallium		0.0016	0.00030	0.0019	0.0025	0.00046	<b>0.0044</b>	0.0088	3	0.0027	0.0042
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium		0.15	0.0057	0.16	0.23	0.0088	<b>0.24</b>	0.48	4	0.017	0.027

Blank<10% of ELV  
 Blank>10% of ELV!  
 Blank>10% of ELV!

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m<sup>3</sup>) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.



Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

### Table 10b – Heavy Metals Efficiencies & Mercury Dead Animal Waste (3% Oxygen & Dry Gas)

<b>Metals groups have been selected. Efficiencies will only be displayed for individual elements if the group total concentration is greater than 30% of the associated ELV.</b>				
<b>Recovery in the final impinger must be &lt;10% of the total combined element mass (i.e. filter, probe rinse &amp; impingers) to pass - ONLY if the element makes up &gt;1% of the total mass of all metals collected</b>				
Trace Element	Symbol	Final Impinger (%)	<10% ?	<1% of Total?
Antimony	Sb	N/A	N/A	NO
Arsenic	As	N/A	N/A	NO
Cadmium	Cd	N/A	N/A	NO
Chromium	Cr	N/A	N/A	NO
Cobalt	Co	N/A	N/A	YES
Copper	Cu	N/A	N/A	NO
Lead	Pb	N/A	N/A	NO
Manganese	Mn	N/A	N/A	NO
Mercury	Hg	N/A	N/A	NO
Nickel	Ni	N/A	N/A	NO
Thallium	Tl	N/A	N/A	NO
Vanadium	V	N/A	N/A	YES

Combined Groups	ELV mg/m <sup>3</sup>	Result <30% ELV?
Mercury	0.02	YES
Cadmium & Thallium	0.015	YES
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium	0.15	NO

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632

: R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date. : 20th December 2024

## Table 11 -- Chlorinated Dioxins & Furans Dead Animal Waste (3% Oxygen & Dry Gas)

### Data Recorded from Incinerator - Stack Incinerator Exhaust

Emission Parameter	Units	Chlorinated D & F T2		
Stack Diameter	metres	0.3		
-	-	-		
Area of sample plane	m <sup>2</sup>	0.071		
Moisture Content	%	6.95		
Moisture Expanded Uncertainty	%(Relative)	6.19		
Stack Temperature	°C	663		
Oxygen Concentration	%	10.13		
Gas velocity (as Measured)	m/sec	39.4163		
Gas velocity (Reference Conditions)	m/sec*	6.4861		
Volumetric Flowrate (as Measured)	m <sup>3</sup> /sec	2.7862		
Volumetric Flowrate (Reference)	m <sup>3</sup> /sec*	0.4585		
<b>Sample Date</b>				
16/02/2024				
<b>Sample Period</b>				
10:40 - 11:40				
Sample Reference				
ECL/24/0405 - 0407				
Sample Volume (Reference Conditions)	m <sup>3</sup> *	0.74		
Isokinetic Sampling Rate	%	108.27		
Species	Sample Reference: ECL/24/0405 - 0407		Blank Reference: ECL/24/0408 - 0410	
	Conc. ng/m <sup>3</sup> *	TEQ ng/m <sup>3</sup> *	Conc. ng/m <sup>3</sup> *	TEQ ng/m <sup>3</sup> *
Chlorinated Dioxins 2,3,7,8 Isomers	7.64	0.74	0.0042	0.00047
Total Chlorinated Dioxins Non - Targeted Isomers	0.00	...	0.00	...
Chlorinated Furans 2,3,7,8 Isomers	17.47	2.07	0.0049	0.00066
Total Chlorinated Furans Non - Targeted Isomers	0.00	...	0.00	...
<b>TOTAL</b>	...	<b>2.81</b>	...	<b>0.00113</b>
<b>Range</b>	...	<b>2.81 - 2.81</b>	Blank <10% of ELV?	<b>YES</b>
<b>% Uncertainty</b>	...	<b>15</b>		

\*Reference Conditions 273K, 101.3kPa, 3% Oxygen, Dry Gas. NB: For each congener, where the blank concentration exceeds or equals the measured concentration, the blank value has been substituted. Refer to the table of individual congeners for more detailed information.

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Table 11b – Chlorinated Dioxins & Furans Dead Animal Waste (3% Oxygen & Dry Gas)

**Data Recorded from Incinerator - Stack Incinerator Exhaust on the 16/02/24, 10:40 - 11:40**

Species	Blank Reference: ECL/24/0408 - 0410 TEQ ng/m <sup>3</sup> *	EEC Toxic Equivalent Factor (TEF)	Sample Ref.: ECL/24/0405 - 0407		WHO Humans & Mammals (TEF)	Humans & Mammals TEQ ng/m <sup>3</sup> *	WHO Fish (TEF)	Fish TEQ ng/m <sup>3</sup> *	WHO Birds (TEF)	Birds TEQ ng/m <sup>3</sup> *
			Concentration ng/m <sup>3</sup> *	TEQ ng/m <sup>3</sup> *						
<b>Chlorinated Dioxins - 2,3,7,8 Isomers</b>										
2,3,7,8 - TCDD	0.00019	1	0.22	0.22	1	0.22	1	0.22	1	0.22
1,2,3,7,8 - PCDD	0.00013	0.5	0.69	0.35	1	0.69	1	0.69	1	0.69
1,2,3,4,7,8 - HxCDD	0.000043	0.1	0.38	0.038	0.1	0.038	0.5	0.19	0.05	0.019
1,2,3,6,7,8 - HxCDD	0.000047	0.1	0.51	0.051	0.1	0.051	0.01	0.0051	0.01	0.0051
1,2,3,7,8,9 - HxCDD	0.000051	0.1	0.56	0.056	0.1	0.056	0.01	0.0056	0.1	0.056
1,2,3,4,6,7,8 - HpCDD	0.000005	0.01	2.51	0.025	0.01	0.025	0.001	0.0025	0.001	0.0025
OCDD	0.000002	0.001	2.77	0.0028	0.0001	0.00028	0	...	0	...
<b>Total Chlorinated Dioxins - Non - Targeted Isomers</b>										
TCDD	...	0	0.000000	...	0	...	0	...	0	...
PCDD	...	0	0.000000	...	0	...	0	...	0	...
HxCDD	...	0	0.000000	...	0	...	0	...	0	...
HpCDD	...	0	0.000000	...	0	...	0	...	0	...
<b>Chlorinated Furans - 2,3,7,8 Isomers</b>										
2,3,7,8 - TCDF	0.000036	0.1	1.62	0.16	0.1	0.16	0.05	0.081	1	1.62
1,2,3,7,8 - PCDF	0.000018	0.05	1.57	0.078	0.05	0.078	0.05	0.078	0.1	0.16
2,3,4,7,8 - PCDF	0.00050	0.5	2.50	1.25	0.5	1.25	0.5	1.25	1	2.50
1,2,3,4,7,8 - HxCDF	0.000026	0.1	1.55	0.16	0.1	0.16	0.1	0.16	0.1	0.16
1,2,3,6,7,8 - HxCDF	0.000022	0.1	1.80	0.18	0.1	0.18	0.1	0.18	0.1	0.18
2,3,4,6,7,8 - HxCDF	0.000022	0.1	1.77	0.18	0.1	0.18	0.1	0.18	0.1	0.18
1,2,3,7,8,9 - HxCDF	0.000024	0.1	0.18	0.018	0.1	0.018	0.1	0.018	0.1	0.018
1,2,3,4,6,7,8 - HpCDF	0.000006	0.01	3.89	0.039	0.01	0.039	0.01	0.039	0.01	0.039
1,2,3,4,7,8,9 - HpCDF	0.000009	0.01	0.70	0.0070	0.01	0.0070	0.01	0.0070	0.01	0.0070
OCDF	0.000001	0.001	1.89	0.0019	0.0001	0.00019	0.0001	0.00019	0.0001	0.00019
<b>Total Chlorinated Furans - Non - Targeted Isomers</b>										
TCDF	...	0	0.000000	...	0	...	0	...	0	...
PCDF	...	0	0.000000	...	0	...	0	...	0	...
HxCDF	...	0	0.000000	...	0	...	0	...	0	...
HpCDF	...	0	0.000000	...	0	...	0	...	0	...
<b>TOTAL</b>	<b>0.0011</b>	...	...	<b>2.81</b>	...	<b>3.15</b>	...	<b>3.10</b>	...	<b>5.85</b>
<b>Range</b>	...	...	...	<b>2.81 - 2.81</b>	...	<b>3.15 - 3.15</b>	...	<b>3.1 - 3.1</b>	...	<b>5.85 - 5.85</b>
<b>% Uncertainty</b>	...	...	...	<b>15</b>	...	<b>14</b>	...	<b>15</b>	...	<b>16</b>

\*Reference Conditions 273K, 101.3kPa, 3% Oxygen, Dry Gas. NB: For each congener, where the blank concentration exceeds or equals the measured concentration, the blank value has been substituted. This is presented as shaded cells. Where the Limit of Detection applies, concentrations are presented in italics.

Environmental Compliance Limited

Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632

: R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

## VELOCITY TRAVERSE PROFILES







**Environmental Compliance Limited**

Selibon N.V.  
Permit No  
Variation No  
Report Ref

: ...  
: ...  
: P5632 : R001

Installation Name  
Visit Details  
Survey Dates  
Report Issue Date.

: Incinerator Exhaust  
: Emissions Survey – February 2024  
: 12th – 16th February 2024  
: 20th December 2024

## **FIELD CALIBRATION AND SAMPLING DATA**



Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Horiba Calibration Summary (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Light Medical Waste 13/02/2024

Horiba PG 350 E Ranges:				
NO as				
	NO <sub>2</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
	1025	6250	25	20
Units	mg/m <sup>3</sup>	mg/m <sup>3</sup>	%Vol	%Vol
<b>Zero Values (Direct)</b>				
Mean Initial Direct Zero	0.00	-0.14	0.01	0.00
Mean Confirmation Direct Zero	0.00	-0.03	0.01	0.03
Difference in Direct Zero	0.00	0.12	0.01	0.03
Repeatability at Zero	4.10	2.50	0.20	0.20
<2 x Repeatability at Zero?	YES	YES	YES	YES
<b>Pre Zero Values (System)</b>				
Mean Pre Test Zero	0.00	0.11	-0.01	0.01
% of Measurement Range?	0.00%	0.00%	-0.05%	0.05%
Detection Limit (LOD)	0.00	0.47	0.20	0.00
<b>Applied Span:</b>				
	NO	CO	O <sub>2</sub>	CO <sub>2</sub>
Actual Applied Span Concentration	623.41	376.38	15.05	17.95
<b>Pre Test System Zero Values</b>				
Mean Pre Test System Zero	0.00	0.11	-0.01	0.01
Difference ≤ ± 2% of Span Value?	0.00%	0.03%	0.09%	0.05%
<b>Post Test Direct Zero Values</b>				
Mean Post Test Direct Zero	0.00	-0.94	-0.07	0.03
% of Certified Range?	0.00%	-0.02%	-0.28%	0.17%
Zero Drift ≤ ± 5% of Applied Span?	0.00%	0.21%	0.50%	0.17%
<b>Pre Test System Span Values</b>				
Mean Pre Test System Span	620.95	374.90	15.00	17.89
Difference ≤ ± 2% of Span Value ?	0.39%	0.39%	0.31%	0.36%
<b>Post Test Direct Span Values</b>				
Mean Post Test Direct Span	625.97	371.62	14.89	17.94
Span Drift ≤ ± 5% Span Value?	0.41%	1.26%	1.08%	0.04%

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Horiba Calibration Summary (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Medium Bin Medical Waste 14/02/2024

Horiba PG 350 E Ranges:				
NO as				
	NO <sub>2</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
	1025	6250	25	20
Units	mg/m <sup>3</sup>	mg/m <sup>3</sup>	%Vol	%Vol
<b>Zero Values (Direct)</b>				
Mean Initial Direct Zero	0.00	-0.14	0.01	0.00
Mean Confirmation Direct Zero	0.00	-0.03	0.01	0.03
Difference in Direct Zero	0.00	0.12	0.01	0.03
Repeatability at Zero	4.10	2.50	0.20	0.20
<2 x Repeatability at Zero?	YES	YES	YES	YES
<b>Pre Zero Values (System)</b>				
Mean Pre Test Zero	0.00	0.11	-0.01	0.01
% of Measurement Range?	0.00%	0.00%	-0.05%	0.05%
Detection Limit (LOD)	0.00	0.47	0.20	0.00
<b>Applied Span:</b>				
	NO	CO	O <sub>2</sub>	CO <sub>2</sub>
Actual Applied Span Concentration	623.41	376.38	15.05	17.95
<b>Pre Test System Zero Values</b>				
Mean Pre Test System Zero	0.00	0.11	-0.01	0.01
Difference ≤ ± 2% of Span Value?	0.00%	0.03%	0.09%	0.05%
<b>Post Test Direct Zero Values</b>				
Mean Post Test Direct Zero	0.00	-0.81	-0.10	0.05
% of Certified Range?	0.00%	-0.01%	-0.41%	0.24%
Zero Drift ≤ ± 5% of Applied Span?	0.00%	0.18%	0.72%	0.25%
<b>Pre Test System Span Values</b>				
Mean Pre Test System Span	620.95	374.90	15.00	17.89
Difference ≤ ± 2% of Span Value ?	0.39%	0.39%	0.31%	0.36%
<b>Post Test Direct Span Values</b>				
Mean Post Test Direct Span	625.67	373.10	15.01	18.02
Span Drift ≤ ± 5% Span Value?	0.36%	0.87%	0.24%	0.36%

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Horiba Calibration Summary (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Dead Animal Waste 15/02/2024

Horiba PG 350 E Ranges:				
NO as				
	NO <sub>2</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
	1025	6250	25	20
Units	mg/m <sup>3</sup>	mg/m <sup>3</sup>	%Vol	%Vol
<b>Zero Values (Direct)</b>				
Mean Initial Direct Zero	0.00	-0.14	0.01	0.00
Mean Confirmation Direct Zero	0.00	-0.03	0.01	0.03
Difference in Direct Zero	0.00	0.12	0.01	0.03
Repeatability at Zero	4.10	2.50	0.20	0.20
<2 x Repeatability at Zero?	YES	YES	YES	YES
<b>Pre Zero Values (System)</b>				
Mean Pre Test Zero	0.00	0.11	-0.01	0.01
% of Measurement Range?	0.00%	0.00%	-0.05%	0.05%
Detection Limit (LOD)	0.00	0.47	0.20	0.00
<b>Applied Span:</b>				
	NO	CO	O <sub>2</sub>	CO <sub>2</sub>
Actual Applied Span Concentration	623.41	376.38	15.05	17.95
<b>Pre Test System Zero Values</b>				
Mean Pre Test System Zero	0.00	0.11	-0.01	0.01
Difference ≤ ± 2% of Span Value?	0.00%	0.03%	0.09%	0.05%
<b>Post Test Direct Zero Values</b>				
Mean Post Test Direct Zero	0.00	-0.51	-0.07	0.03
% of Certified Range?	0.00%	-0.01%	-0.29%	0.17%
Zero Drift ≤ ± 5% of Applied Span?	0.00%	0.10%	0.51%	0.17%
<b>Pre Test System Span Values</b>				
Mean Pre Test System Span	620.95	374.90	15.00	17.89
Difference ≤ ± 2% of Span Value ?	0.39%	0.39%	0.31%	0.36%
<b>Post Test Direct Span Values</b>				
Mean Post Test Direct Span	625.25	375.86	15.06	18.02
Span Drift ≤ ± 5% Span Value?	0.30%	0.14%	0.04%	0.38%

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Horiba Calibration Summary (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Dead Animal Waste 16/02/2024

Horiba PG 350 E Ranges:				
NO as				
	NO <sub>2</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
	1025	6250	25	20
Units	mg/m <sup>3</sup>	mg/m <sup>3</sup>	%Vol	%Vol
<b>Zero Values (Direct)</b>				
Mean Initial Direct Zero	0.00	-0.14	0.01	0.00
Mean Confirmation Direct Zero	0.00	-0.03	0.01	0.03
Difference in Direct Zero	0.00	0.12	0.01	0.03
Repeatability at Zero	4.10	2.50	0.20	0.20
<2 x Repeatability at Zero?	YES	YES	YES	YES
<b>Pre Zero Values (System)</b>				
Mean Pre Test Zero	0.00	0.11	-0.01	0.01
% of Measurement Range?	0.00%	0.00%	-0.05%	0.05%
Detection Limit (LOD)	0.00	0.47	0.20	0.00
<b>Applied Span:</b>				
	NO	CO	O <sub>2</sub>	CO <sub>2</sub>
Actual Applied Span Concentration	623.41	376.38	15.05	17.95
<b>Pre Test System Zero Values</b>				
Mean Pre Test System Zero	0.00	0.11	-0.01	0.01
Difference ≤ ± 2% of Span Value?	0.00%	0.03%	0.09%	0.05%
<b>Post Test Direct Zero Values</b>				
Mean Post Test Direct Zero	0.00	-0.30	-0.08	0.05
% of Certified Range?	0.00%	0.00%	-0.31%	0.27%
Zero Drift ≤ ± 5% of Applied Span?	0.00%	0.04%	0.56%	0.29%
<b>Pre Test System Span Values</b>				
Mean Pre Test System Span	620.95	374.90	15.00	17.89
Difference ≤ ± 2% of Span Value ?	0.39%	0.39%	0.31%	0.36%
<b>Post Test Direct Span Values</b>				
Mean Post Test Direct Span	625.28	374.25	15.02	17.96
Span Drift ≤ ± 5% Span Value?	0.30%	0.57%	0.22%	0.04%

Selbion N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Light Medical Waste Particulates, Hydrogen Fluoride / Hydrogen Chloride

Environmental Compliance Limited		PARTICULATEDATA SAMPLING PROFORMA							Date of Measurement		13/02/2024			
ECU/TPD/	027 & 081	Time taken to change Ports?							0	Start Time	10:15	End Time	11:15	
Client	Selbion N.V.	Stack Profile	Circular	Console Id	U010	Barometer Id	204	Test Duration	60	Impinger 1	DI H2O	Solution	SOL_NO	
Site	ACL Lagan - Bonaire	Stack Area (m²)	0.07	Pump Id	U010	Nozzle Id	402	SOU	5061	DI Water	5061	Acetone	4532	
Location	Incinerator	Barometric Pressure (mb)	1015	Probe Id	1328	Nozzle size	7.08	Start Weight (g)	660.6	End Weight (g)	674.6	Total weight (g)	14	
Stack ID	Incinerator Exhaust	Static Pres. (mm H <sub>2</sub> O)	8.2	DDM Yd	1.0074	Filter Id	4505-259199	Impinger 2	DI H2O	SOU	5061	If moisture was not measured end gas was dried before entering the gas meter. Impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.		
Test No.	TPM / HCl & HF	Pilot coefficient	0.84	AH1	40.96	Pilot ID	692	Start Weight (g)	591.8	End Weight (g)	598.2	Total weight (g)	6.4	
Job No.	P5632	Probe Heater Setting (°C)	160	Impinger Id	660	Hot Box ID	978	Impinger3	DI H2O	SOU	5061	Item Name		
ECL Site Staff	SH & LPH	Hot Box Setting (°C)	160	Balance Id	368	Slice < 50% Spent at End of Test?	YES	Start Weight (g)	593	End Weight (g)	596.1	Total weight (g)	3.1	
Sample	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total	Original K Factor Settings	Impinger 4	Empty	SOU		Item Name		
Start Volume	2833896.4						Meter Temp.	Start Weight (g)	553.1	End Weight (g)	557.2	Total weight (g)	4.1	
Final Volume	2835915.8						%Moisture	2.00	Impinger 5	Silica	SOU	Item Name		
Total Volume	1119.2	0.0	0.0	0.0	0.0	0.0	1119.2	Impinger 6		SOU	Item Name			
Leak Check	First	Second	Third	Fourth	Fifth			Start Weight (g)	561.8	End Weight (g)	568.2	Total weight (g)	6.4	
Leak rate U/min	0.2						Dry O <sub>2</sub> ( % Atmospheric)	16.53	Impinger 7		SOU	Item Name		
Vacuum "Hg	15						Dry Carbon Dioxide %	3.21	Start Weight (g)	596.1	End Weight (g)	598.2	Total weight (g)	2.1
Time of Check	10:13						Reference Oxygen Percentage	11	Impinger 8		SOU	Item Name		
Set Rate U/min	20								Start Weight (g)	593	End Weight (g)	596.1	Total weight (g)	3.1
Leak < 2%?	YES								Impinger 9		SOU	Item Name		
Traverse Point	A1	A1	A1	A1	A1	A1	A1	A1	Impinger 10		SOU	Item Name		
TimePoint (mins)	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40	Impinger 11		SOU	Item Name		
AP (mm H2O)	11.00	12.20	10.00	10.60	10.60	10.40	10.80	9.90	Impinger 12		SOU	Item Name		
K factor	2.90	2.90	3.20	3.70	3.50	4.20	4.40	2.80	Impinger 13		SOU	Item Name		
ΔH (Orifice)	31.90	35.38	32.00	38.48	37.10	43.68	47.52	27.44	Impinger 14		SOU	Item Name		
Meter (Tm in)	32.00	33.00	34.00	34.00	35.00	35.00	35.00	35.00	Impinger 15		SOU	Item Name		
Meter (Tm out)	32.00	33.00	34.00	34.00	35.00	35.00	35.00	35.00	Impinger 16		SOU	Item Name		
Stack Temp (T <sub>st</sub> )	371.00	365.00	301.00	232.00	251.00	172.00	151.00	392.00	Impinger 17		SOU	Item Name		
Impinger T Outlet	18.00	17.00	15.00	16.00	17.00	17.00	18.00	16.00	Impinger 18		SOU	Item Name		
Vacuum ( " Hg)	2.00	5.00	7.50	8.00	8.50	9.00	9.50	7.10	Impinger 19		SOU	Item Name		

## Light Medical Waste Sulphur Dioxide

Environmental Compliance Limited		NON ISOKINETIC SAMPLING PROFORMA							Date of Measurement		13/02/2024		
ECU/TPD/	039	Time taken to change Ports?							0	Start Time	12:25	End Time	13:25
Client	Selbion N.V.	Stack Profile	Circular	Console Id	U010	Barometer Id	204	Test Duration	60	Impinger 1	3% H2O2	Item Name	
Site	ACL Lagan - Bonaire	Stack Area (m²)	0.07	Pump Id	U010	Nozzle Id	n/a	SOU	5058	Start Weight (g)	505.1	End Weight (g)	517.2
Location	Incinerator	Barometric Pressure (mb)	1015	Probe Id	1328	Nozzle size	n/a	Impinger 2	3% H2O2	Start Weight (g)	587.4	End Weight (g)	593.8
Stack ID	Incinerator Exhaust	Static Pres. (mm H <sub>2</sub> O)	8.2	DDM Yd	1.0074	Filter Id	QMA	Impinger 3	3% H2O2	Start Weight (g)	505.8	End Weight (g)	517.2
Test No.	Sulphur Dioxide 1	Pilot coefficient	n/a	AH1	40.96	Pilot ID	n/a	Impinger 4	Empty	Start Weight (g)	582	End Weight (g)	585.1
Job No.	P5632	Probe Heater Setting (°C)	160	Impinger Id	660	Hot Box ID	978	Impinger 5	Silica	Start Weight (g)	557.1	End Weight (g)	563.5
ECL Site Staff	SH & LPH	Hot Box Setting (°C)	160	Balance Id	368	Slice < 50% Spent at End of Test? Y/N	YES	Impinger 6		Start Weight (g)	553.1	End Weight (g)	557.2
Sample	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total	Required Sample Flowrate U/min	3	Impinger 7		Start Weight (g)	557.1	
Start Volume	2835770.2						ΔH Entered Below	1	Impinger 8		Start Weight (g)	557.1	
Final Volume	2837792.0							6	Impinger 9		Start Weight (g)	557.1	
Total Volume	960.8	0.0	0.0	0.0	0.0	0.0		15	Impinger 10		Start Weight (g)	557.1	
Leak Check	First	Second	Third	Fourth	Fifth			25	Impinger 11		Start Weight (g)	557.1	
Leak rate U/min	0	0					Dry O <sub>2</sub> ( % Atmospheric)	17.19	Impinger 12		Start Weight (g)	557.1	
Vacuum "Hg	15	10					Dry Carbon Dioxide %	2.55	Impinger 13		Start Weight (g)	557.1	
Time of Check	12:10	13:27					Dry Carbon Monoxide ppm	18.75	Impinger 14		Start Weight (g)	557.1	
Set Rate U/min	20	18.02							Impinger 15		Start Weight (g)	557.1	
Leak < 2%?	YES	YES							Impinger 16		Start Weight (g)	557.1	
Traverse Point	A1	A1	A1	A1	A1	A1	A1	A1	Impinger 17		Start Weight (g)	557.1	
TimePoint (mins)	0 - 10	10 - 20	20 - 30	30 - 40	40 - 50	50 - 60			Impinger 18		Start Weight (g)	557.1	
AP (mm H2O)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	Impinger 19		Start Weight (g)	557.1	
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	Impinger 20		Start Weight (g)	557.1	
ΔH (Orifice)	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	Impinger 21		Start Weight (g)	557.1	
Meter (Tm in)	35.00	36.00	37.00	38.00	38.00	38.00	37.00	37.00	Impinger 22		Start Weight (g)	557.1	
Meter (Tm out)	35.00	36.00	37.00	38.00	38.00	38.00	37.00	37.00	Impinger 23		Start Weight (g)	557.1	
Stack Temp (T <sub>st</sub> )	416.00	252.00	159.00	134.00	108.00	433.00	250.33	250.33	Impinger 24		Start Weight (g)	557.1	
Impinger T Outlet	14.00	13.00	11.00	13.00	15.00	17.00	13.83	13.83	Impinger 25		Start Weight (g)	557.1	
Vacuum ( " Hg)	2.00	2.50	3.00	4.00	5.00	7.50	4.00	4.00	Impinger 26		Start Weight (g)	557.1	

Selbion N.V.
Permit No : ...
Variation No : ...
Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust
Visit Details : Emissions Survey - February 2024
Survey Dates : 12th - 16th February 2024
Report Issue Date : 20th December 2024

Light Medical Waste
Heavy Metals & Mercury

Table with columns for METALS DATA SAMPLING PROFORMA, Date of Measurement (13/02/2024), and various sampling parameters including Client (Selbion N.V.), Site (ACL Lagan - Bonaire), and multiple rows of data for different traverse points and impinger results.

Medium Bin Medical Waste
Particulates, Hydrogen Fluoride / Hydrogen Chloride

Table with columns for PARTICULATE DATA SAMPLING PROFORMA, Date of Measurement (14/02/2024), and various sampling parameters including Client (Selbion N.V.), Site (ACL Lagan - Bonaire), and multiple rows of data for different traverse points and impinger results.

Environmental Compliance Limited

Selbion N.V.
Permit No : ...
Variation No : ...
Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust
Visit Details : Emissions Survey - February 2024
Survey Dates : 12th - 16th February 2024
Report Issue Date. : 20th December 2024

Medium Bin Medical Waste Sulphur Dioxide

Environmental Compliance Limited NON ISOKINETIC SAMPLING PROFORMA Date of Measurement 14/02/2024. Table with columns for Client, Site, Location, Stack ID, Test No, Job No, ECL Site Staff, and various measurement parameters like Stack Profile, Circular, Conical, Pump, Probe, DGM Yd, AHF, AHF, AHF, Balance ID, etc.

Medium Bin Medical Waste Heavy Metals & Mercury

METALS DATA SAMPLING PROFORMA Date of Measurement 14/02/2024. Table with columns for Client, Site, Location, Stack ID, Test No, Job No, ECL Site Staff, and various measurement parameters like Stack Profile, Circular, Conical, Pump, Probe, DGM Yd, AHF, AHF, AHF, Balance ID, etc.

Environmental Compliance Limited

Selbon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Medium Bin Medical Waste  
 Chlorinated Dioxins & Furans

DIOXIN & FURANS DATA SAMPLING PROFORMA										Date of Measurement		15/02/2024	
ECL/TPD/		Time taken to change Ports?				Start Time		End Time					
31		10				09:40		14:50					
Client		Selbon N.V.		Stack Profile		Circular		Console ID		U010			
Site		ACL Lagan - Bonaire		Stack Area (m²)		0.071		Pump ID		U010			
Location		Incinerator		Barometric Pressure (mb)		1015		Probe ID		1328			
Stack ID		Incinerator Exhaust		Static Pres. (mm H <sub>2</sub> O)		17.8		DGM Yd		1.0074			
Test No.		TPM / HCL & HF 3		Pilot coefficient		0.84		DH @		40.96			
Job No		P5632		Probe Heater Setting (°C)		120		Impinger ID		660			
Operators		SH & LPH		Hot Box Setting (°C)		120		Balance ID		368			
								XAD Therm ID		938			
Sample		Leak 1		Leak 2		Leak 3		Leak 4		Leak 5			
Start Volume		2848024.2		2853485.2		2853508.0		2853515.6		2853515.6			
Final Volume		2848950.0		2853496.4		2853515.6		2853515.6		2853515.6			
Total Volume		6925.8		11.2		7.6		0.0		0.0			
Leak Check		First		Second		Third		Fourth		Fifth			
Leak rate (l/min)		0		0.2		0.4		0.4		0.0			
Vacuum (°Hg)		20		20		20		20		20			
Time of Check		09:05		13:35		13:39		14:52					
Set Rate (l/min)		20		26.64		26.64		23.09					
Leak < 4%?		YES		YES		YES		YES		YES			
Original K Factor Settings Meter Temp. 40 Stack Temp. 500 %Moisture 4.20 K factor 0.7 Reference Oxygen Percentage 11 Dry Carbon Dioxide % 4.24 Dry O <sub>2</sub> (Atmospheric) 15.19 Dry Carbon Dioxide % 4.24													
Additional Moisture Weighings Impinger 1 XAD Solution SOL NO Start Weight (g) 486.4 End Weight (g) 492 Total weight (g) 5.18 Impinger 2 Condenser Start Weight (g) 562.9 End Weight (g) 720.4 Total weight (g) 157.5 Impinger 3 Empty Start Weight (g) 554.6 End Weight (g) 553.1 Total weight (g) -1.5 Impinger 4 Silica Start Weight (g) 803.4 End Weight (g) 807.5 Total weight (g) 4.1 Impinger 5 Start Weight (g) 540.9 End Weight (g) 540.9 Total weight (g) 0 Impinger 6 Start Weight (g) 591 End Weight (g) 591 Total weight (g) 0 Impinger 7 Start Weight (g) 591 End Weight (g) 591 Total weight (g) 0 Impinger 8 Start Weight (g) 591 End Weight (g) 591 Total weight (g) 0 Total (g) 165.9													
PRE-Sample PITOT Visual Inspection Time 09:01 Pass ? (Y/N) Y PRE-Sample PITOT Leak Check Time 09:03 Pass ? (Y/N) Y Post-Sample Blockage Check (L-type) Time 09:01 Pass ? (Y/N) Y Post-Sample Blockage Check (H-type) Time 09:03 Pass ? (Y/N) Y Post-Sample PITOT Leak Check Time 14:50 Pass ? (Y/N) Y													

Dead Animal Waste  
 Particulates, Hydrogen Fluoride / Hydrogen Chloride

PARTICULATE DATA SAMPLING PROFORMA										Date of Measurement		15/02/2024	
ECL/TPD/		Time taken to change Ports?				Start Time		End Time					
027 & 081		0				16:00		17:00					
Client		Selbon N.V.		Stack Profile		Circular		Console ID		U010			
Site		ACL Lagan - Bonaire		Stack Area (m²)		0.07		Pump ID		U010			
Location		Incinerator		Barometric Pressure (mb)		1015		Probe ID		1328			
Stack ID		Incinerator Exhaust		Static Pres. (mm H <sub>2</sub> O)		24.2		DGM Yd		1.0074			
Test No.		TPM / HCL & HF 3		Pilot coefficient		0.84		AH @		40.96			
Job No		P5632		Probe Heater Setting (°C)		160		Impinger ID		660			
ECL Site Staff		SH & LPH		Hot Box Setting (°C)		160		Balance ID		668			
Sample		Leak 1		Leak 2		Leak 3		Leak 4		Leak 5			
Start Volume		2859922.4		2857488.6		2857488.6		2857488.6		2857488.6			
Final Volume		1526.2		0.0		0.0		0.0		0.0			
Total Volume		1526.2		0.0		0.0		0.0		0.0			
Leak Check		First		Second		Third		Fourth		Fifth			
Leak rate (l/min)		0.2		0.0		0.0		0.0		0.0			
Vacuum (°Hg)		18		15.59		15.59		15.59		15.59			
Time of Check		15:59		15:59		15:59		15:59		15:59			
Set Rate (l/min)		26		26		26		26		26			
Leak < 4%?		YES		YES		YES		YES		YES			
Original K Factor Settings Meter Temp. 20 Stack Temp. 385 %Moisture 4.20 K factor 0.8 Reference Oxygen Percentage 11 Dry Carbon Dioxide % 1.80													
Additional Moisture Weighings Impinger 1 DI H2O Start Weight (g) 5061 End Weight (g) 646.3 Total weight (g) 751.4 Impinger 2 DI H2O Start Weight (g) 715.1 End Weight (g) 756.1 Total weight (g) 41 Impinger 3 DI H2O Start Weight (g) 5061 End Weight (g) 626.3 Total weight (g) 24 Impinger 4 Empty Start Weight (g) 558.2 End Weight (g) 558.2 Total weight (g) 2.4 Impinger 5 Silica Start Weight (g) 808.7 End Weight (g) 810.8 Total weight (g) 2.1 Impinger 6 Start Weight (g) 591 End Weight (g) 591 Total weight (g) 0 Impinger 7 Start Weight (g) 591 End Weight (g) 591 Total weight (g) 0 Impinger 8 Start Weight (g) 591 End Weight (g) 591 Total weight (g) 0 Total (g) 144.60													
PRE-Sample PITOT Visual Inspection Time 15:48 Pass ? (Y/N) Y PRE-Sample PITOT Leak Check Time 15:50 Pass ? (Y/N) Y Post-Sample Blockage Check (L-type) Time 15:48 Pass ? (Y/N) Y Post-Sample Blockage Check (H-type) Time 15:50 Pass ? (Y/N) Y Post-Sample PITOT Leak Check Time 17:04 Pass ? (Y/N) Y													





Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Dead Animal Waste  
 Chlorinated Dioxins & Furans

DIOXIN & FURANS DATA SAMPLING PROFORMA										Date of Measurement		16/02/2024	
ECU/TPD	Time taken to change Ports?			Start Time		End Time							
31	0			10:40		11:40							
Client	Selibon N.V.	Stack Profile	Circular	Console ID	U010	Barometer ID	204	Impinger 1	XAD	Rinse Solutions used			
Site	ACL Lagan - Bonaire	Stack Area (m²)	0.071	Pump ID	U010	Nozzle ID	402	TRAP ID		Solution	SOL_NO		
Location	Incinerator	Barometric Pressure (mb)	1015	Probe ID	1328	Nozzle size	6.09	Start Weight (g)	220.54	DCM	4846		
Stack ID	Incinerator Exhaust	Static Pres. (mm H <sub>2</sub> O)	24.2	DGM Yd	1.0074	Filter ID	GFA	End Weight (g)	221.9	Acetone	4932		
Test No.	090000010-1716	Pilot coefficient	0.84	DH @	40.96	Pilot ID	602	Total weight (g)	1.36	Toluene	4931		
Job No	P5632	Probe Heater Setting (°C)	120	Impinger ID	660	Hot Box ID	978	Impinger 2	Condenser				
Operators	SH & LPH	Hot Box Setting (°C)	120	Balance ID	368	XAD Therm ID	938	Start Weight (g)	362.4	Additional Moisture Weighings			
Sample	Leak 1	Leak 2	Leak 3	Leak 4	Leak 5	Total	Original K Factor Settings	End Weight (g)	406.3	Item Name			
Start Volume	2862118.0						Meter Temp.	500	43.9	Start Weight (g)			
Final Volume	2863484.4						Stack Temp	4.20		End Weight (g)			
Total Volume	1366.4	0.0	0.0	0.0	0.0	0.0	%Moisture	11		Total weight (g)			
Leak Check	First	Second	Third	Fourth	Fifth		Smooth Walls	Yes		Item Name			
Leak rate l/min	0.2	0.2					Dry O <sub>2</sub> (%) (Atmospheric)	10.13		Start Weight (g)			
Vacuum "Hg	20	15					Dry Carbon Dioxide %	8.14		End Weight (g)	0		
Time of Check	10:15	11:42					K factor	0.9		Item Name			
Se Rate l/min	25	22.77					Reference Oxygen Percentage	11		Start Weight (g)			
Leak < 4%?	YES	YES					Leak check ALWAYS needs to be performed when moving between sample ports Leak check IS ALWAYS required on completion of the sample.						
Traverse Point	A1	A1	A1	A1	A1	A1	A1	A1	Total	Impinger 3	Empty		
TimePointStart	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40		Start Weight (g)	554.6		
DP (mm H <sub>2</sub> O)	42.0	40.0	41.0	40.0	42.0	38.0	38.0	40.0	41.5	End Weight (g)	562.1		
K factor	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90		Total weight (g)	7.5		
DH (cm/s)	37.80	38.00	39.60	43.20	37.80	34.20	34.20	36.00	37.4	Impinger 4	Silica		
Meter (l/min)	30.00	32.00	33.00	34.00	35.00	36.00	36.00	37.00	34.1	Start Weight (g)	817.6		
Stack Temp (°C)	559.00	699.00	722.00	748.00	778.00	674.00	639.00	638.00	682.1	End Weight (g)	823.4		
Impinger T (°C)	16.00	14.00	14.00	15.00	15.00	15.00	14.00	13.00	14.5	Total weight (g)	5.8		
Vacuum (mm Hg)	7.50	10.00	11.00	11.50	12.00	12.00	12.50	12.50	11.1	Impinger 5			
XAD Temperature (°C)	13.00	11.00	12.00	13.00	13.00	13.00	14.00	11.00	12.5	Start Weight (g)			
Traverse Point	A1	A1	A1	A1	A1	A1	A1	A1	Total	End Weight (g)	0		
TimePointStart	40 - 45	45 - 50	50 - 55	55 - 60					45.5	Total weight (g)	0		
DP (mm H <sub>2</sub> O)	44.0	46.0	46.0	46.0					41.0	Impinger 6			
K factor	0.90	0.90	0.90	0.90					37.8	Start Weight (g)			
DH (cm/s)	39.60	41.40	41.40	41.40					37.8	End Weight (g)			
Meter (l/min)	37.0	38.0	38.0	38.0					34.1	Total weight (g)			
Stack Temp (°C)	638.0	629.0	623.0	611.0					625.3	Impinger 7			
Impinger T (°C)	11.0	11.0	12.0	13.0					11.8	Start Weight (g)			
Vacuum (mm Hg)	12.5	13.0	13.5	13.5					13.1	End Weight (g)			
XAD Temperature (°C)	9.00	10.00	10.00	11.00					10.0	Total weight (g)			
Traverse Point									Total	Impinger 8			
TimePointStart										Start Weight (g)			
DP (mm H <sub>2</sub> O)										End Weight (g)			
K factor										Total weight (g)			
DH (cm/s)										Impinger 9			
Meter (l/min)										Start Weight (g)			
Stack Temp (°C)										End Weight (g)			
Impinger T (°C)										Total weight (g)			
Vacuum (mm Hg)										PRE-Sample PTOT Visual Inspection			
XAD Temperature (°C)										Time	10:06		
										Pass ? (Y/N)	Y		
										Pass (c 5%) ?			
										PRE-Sample PTOT Leak Check			
										Time	10:08		
										Pass ? (Y/N)	Y		
										Pass (c 5%) ?			
										POST-Sample PTOT Visual Inspection			
										Time	11:44		
										Pass ? (Y/N)	Y		
										Pass (c 5%) ?			
										POST-Sample PTOT Leak Check			
										Time	11:46		
										Pass ? (Y/N)	Y		

Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

## LABORATORY ANALYSIS RESULTS

Laboratory analysis for Particulates, Hydrogen Chloride, Hydrogen Fluoride, Sulphur Dioxide, Heavy Metals & Mercury was subcontracted to RPS laboratories, a UKAS Accredited Testing Laboratory, Number 0605.

RPS DO hold UKAS & MCERTS accreditation for this analysis.

As required by the MCERTS Performance Standard for Organisations, the analysis results are shown below.

Laboratory analysis for Dioxins & Furans was subcontracted to Marchwood, a UKAS Accredited Testing Laboratory, Number 1668.

Marchwood DO hold UKAS & MCERTS accreditation for this analysis.

As required by the MCERTS Performance Standard for Organisations, the analysis results are shown below.

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Customer Sample No	ECL/24/0437	ECL/24/0438	ECL/24/0439	ECL/24/0440	ECL/24/0441	ECL/24/0442	ECL/24/1144
RPS Sample No	270094	270095	270096	270097	270098	270099	270100
Sample Matrix	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION
Sampling Date	13/02/2024	13/02/2024	14/02/2024	15/02/2024	13/02/2024	14/02/2024	15/02/2024

Determinand	CAS No	Codes	SOP	RL	Units							
volume of sample supplied		U	N/A	n/a	ml	370	186	410	545	275	271	246
hydrogen chloride	7647-01-0	UM	C27	0.05	ug/mL	437	< 0.05	205	15.2	< 0.05	< 0.05	< 0.05
hydrogen fluoride	7664-39-3	UM	C27	0.05	ug/mL	2.43	< 0.05	3.84	6.07	< 0.05	< 0.05	< 0.05

Customer Sample No	ECL/24/0443	ECL/24/0444	ECL/24/0445	ECL/24/0446	ECL/24/0447	ECL/24/0448	ECL/24/1145
RPS Sample No	270101	270102	270103	270104	270105	270106	270107
Sample Matrix	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION
Sampling Date	13/02/2024	13/02/2024	14/02/2024	15/02/2024	13/02/2024	14/02/2024	15/02/2024

Determinand	CAS No	Codes	SOP	RL	Units							
volume of sample supplied		U	N/A	n/a	ml	330	116	416	466	291	296	241
sulphur dioxide	7446-09-5	UM	C27	0.05	ug/mL	29.9	0.70	16.5	1350	0.62	0.61	0.60

Customer Sample No	ECL/24/0411 - 259199	ECL/24/0412	ECL/24/0413 - 259202	ECL/24/0414	ECL/24/0415 - 259203	ECL/24/0416	ECL/24/0417 - 259198	ECL/24/0418	ECL/24/0419 - 259200	ECL/24/0420	ECL/24/1142 - 260267	ECL/24/1143
RPS Sample No	270066	270067	270068	270069	270070	270071	270072	270073	270074	270075	270076	270077
Sample Matrix	FILTER	SOLUTION	FILTER	SOLUTION	FILTER	SOLUTION	FILTER	SOLUTION	FILTER	SOLUTION	FILTER	SOLUTION
Sampling Date	13/02/2024	13/02/2024	14/02/2024	14/02/2024	15/02/2024	15/02/2024	13/02/2024	13/02/2024	14/02/2024	14/02/2024	15/02/2024	15/02/2024

Determinand	CAS No	Codes	SOP	RL	Units							
particulates		UM	D9	0.04	mg	168	102	40.0	3.50	4.01	0.41	
particulates		UM	D9	0.5	mg	26.1	14.1	6.2	< 0.5	< 0.5	< 0.5	

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Customer Sample No	ECL/24/0421	ECL/24/0422	ECL/24/0423	ECL/24/0424	ECL/24/0425	ECL/24/0426	ECL/24/0427	ECL/24/0428	ECL/24/0429	ECL/24/0430	ECL/24/0431	ECL/24/0432	ECL/24/0433	ECL/24/0434	ECL/24/0435	ECL/24/0436
RPS Sample No	270078	270079	270080	270081	270082	270083	270084	270085	270086	270087	270088	270089	270090	270091	270092	270093
Sample Matrix	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION
Sampling Date	13/02/2024	13/02/2024	13/02/2024	13/02/2024	14/02/2024	14/02/2024	14/02/2024	14/02/2024	15/02/2024	15/02/2024	15/02/2024	15/02/2024	13/02/2024	13/02/2024	13/02/2024	13/02/2024

Determinand	CAS No	Codes	SOP	RL	Units																
volume of sample supplied		U	N/A	n/a	ml																
antimony	7440-36-0	UM	M31	0.4	ug	62.9	286	336	175	42.6	284	767	190	5.7	194	604	134	< 0.4	162	254	269
antimony	7440-36-0		M31	0.2	ug	1.9				3.4					1.3				< 0.2		
antimony	7440-36-0		M31	0.2	ug/L			35.0	< 0.2			1.9	< 0.2		0.3		< 0.2			< 0.2	< 0.2
arsenic	7440-38-2	UM	M31	0.2	ug	0.9				0.6				2.7				0.3			
arsenic	7440-38-2		M31	0.3	ug		< 0.3				0.3				0.5				< 0.3		
arsenic	7440-38-2		M31	0.3	ug/L		< 0.3	< 0.3	< 0.3		0.9	1.0	< 0.3		0.5	< 0.3	< 0.3		1.8	< 0.3	< 0.3
cadmium	7440-43-9	UM	M31	0.2	ug	1.3				0.9				0.5					1.8		
cadmium	7440-43-9		M31	0.3	ug	< 0.3				< 0.3				0.6					< 0.3		
cadmium	7440-43-9		M31	0.2	ug/L		< 0.2	< 0.2	< 0.2		< 0.2	< 0.2	< 0.2		< 0.2	< 0.2			< 0.2	< 0.2	< 0.2
chromium	7440-47-3	UM	M31	0.3	ug	8.5				94.1				8.3					1.1		
chromium	7440-47-3		M31	0.3	ug		2.0				5.2				11.5				< 0.3		
chromium	7440-47-3		M31	0.2	ug/L			0.8	< 0.2		1.0	< 0.2			1.1	< 0.2			< 0.2	< 0.2	< 0.2
cobalt	7440-48-4	UM	M31	0.2	ug	0.4				1.1				< 0.2				< 0.2		< 0.2	< 0.2
cobalt	7440-48-4		M31	0.3	ug		< 0.3				< 0.3				< 0.3				< 0.3		
cobalt	7440-48-4		M31	0.2	ug/L		< 0.2	< 0.2	< 0.2		< 0.2	< 0.2			< 0.2	< 0.2			< 0.2	< 0.2	< 0.2
copper	7440-50-8	UM	M31	0.2	ug	303				53.6				40.0					0.7		
copper	7440-50-8		M31	0.4	ug		9.7				2.3				6.0				< 0.4	< 0.4	< 0.4
copper	7440-50-8		M31	0.4	ug/L			3.7	< 0.4		1.7	4.6			0.6	< 0.4				< 0.4	< 0.4
lead	7439-92-1	UM	M31	0.3	ug	25.0				10.5				54.1					3.6		
lead	7439-92-1		M31	0.2	ug		1.7				0.4				7.1				0.2		
lead	7439-92-1		M31	0.2	ug/L			5.6	< 0.2		2.4	< 0.2			4.6	< 0.2			6.3	< 0.2	< 0.2
manganese	7439-96-5	UM	M31	0.2	ug	14.6				19.5				3.2					6.3		
manganese	7439-96-5		M31	0.2	ug		7.0				3.6				3.1				< 0.2		
manganese	7439-96-5		M31	0.2	ug/L			1.7	< 0.2		1.2	< 0.2			1.1	< 0.2			< 0.2	< 0.2	< 0.2
mercury	7439-97-6	UM	M112	0.03	ug	0.03				0.08				0.08					< 0.03		
mercury	7439-97-6		M112	0.5	ug/l			< 0.5	< 0.5			< 0.5	< 0.5			< 0.5	< 0.5			< 0.5	< 0.5
mercury	7439-97-6		M112	0.5	ug/l		< 0.50				< 0.50				< 0.50				< 0.50		
nickel	7440-02-0	UM	M31	0.5	ug	6.7				34.8				4.2					0.6		
nickel	7440-02-0		M31	0.1	ug		16.1				3.6				2.4				< 0.1		
nickel	7440-02-0		M31	0.3	ug/L			1.7	< 0.3		0.4	3.1			0.6	< 0.3				< 0.3	< 0.3
thallium	7440-28-0	UM	M31	0.2	ug	< 0.2				< 0.2				0.3					< 0.2		
thallium	7440-28-0		M31	0.2	ug		< 0.2				< 0.2				< 0.2				< 0.2		
thallium	7440-28-0		M31	0.2	ug/L			< 0.2	< 0.2		< 0.2	< 0.2			< 0.2	< 0.2			< 0.2	< 0.2	< 0.2
vanadium	7440-62-2	UM	M31	0.2	ug	0.5				2.4				0.3					0.9		
vanadium	7440-62-2		M31	0.2	ug		0.3				0.5				< 0.2				< 0.2		
vanadium	7440-62-2		M31	0.1	ug/L			0.2	< 0.1		0.2	< 0.1			< 0.1	< 0.1			< 0.1	< 0.1	< 0.1

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

### 465386 Dioxin Results

Sample Type : Stack  
 MSS Sample Ref : 465386  
 Customer Sample Ref : ECL/24/0402 -ECL/24/0404  
 Sample Condition : Non-Conforming<sup>(1)</sup>  
 Test Method : 2002b

Congener	LOD	Detected	Lower Bound	Upper Bound	Recovery	Sampling Recovery	UKAS
Dioxins/Furans	ng/Sample	ng/Sample	ng/Sample	ng/Sample	%	%	
2378-TCDD	0.0176	6.39	6.39	6.39	87		M
12378-PeCDD	0.0140	10.0	5.02	5.02	97		M
123478-HxCDD	0.00740	2.64	0.264	0.264	86		M
123678-HxCDD	0.00758	2.85	0.285	0.285	79		M
123789-HxCDD	0.00817	4.05	0.405	0.405			M
1234678-HpCDD	0.00519	4.72	0.0472	0.0472	85		M
OCDD	0.0040	1.73	0.00173	0.00173	61		M
<b>Dioxins Total</b>			<b>12.4</b>	<b>12.4</b>			M
2378-TCDF	0.0212	40.4	4.04	4.04	79		M
12378-PeCDF	0.0140	38.0	1.90	1.90		106	M
23478-PeCDF	0.0147	35.7	17.8	17.8	82		M
123478-HxCDF	0.0127	18.0	1.80	1.80	81		M
123678-HxCDF	0.0113	19.0	1.90	1.90	83		M
234678-HxCDF	0.0114	10.9	1.09	1.09	86		M
123789-HxCDF	0.0130	0.879	0.0879	0.0879		104	M
1234678-HpCDF	0.00402	13.6	0.136	0.136	81		M
1234789-HpCDF	0.00589	1.96	0.0196	0.0196		90	M
OCDF	0.00215	1.71	0.00171	0.00171	58		M
<b>Furans Total</b>			<b>28.8</b>	<b>28.8</b>			M
<b>Dioxin/Furan Total</b>			<b>41.2</b>	<b>41.2</b>			M

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

### 465387 Dioxin Results

Sample Type : Stack  
 MSS Sample Ref : 465387  
 Customer Sample Ref : ECL/24/0405 - ECL/24/0407  
 Sample Condition : Non-Conforming<sup>(1)</sup>  
 Test Method : 2002b

Congener	LOD	Detected	Lower Bound	Upper Bound	Recovery	Sampling Recovery	UKAS
Dioxins/Furans	ng/Sample	ng/Sample	ng/Sample	ng/Sample	%	%	
2378-TCDD	0.0116	0.163	0.163	0.163	108		M
12378-PeCDD	0.00655	0.514	0.257	0.257	121		M
123478-HxCDD	0.00617	0.278	0.0278	0.0278	91		M
123678-HxCDD	0.00590	0.378	0.0378	0.0378	91		M
123789-HxCDD	0.00683	0.411	0.0411	0.0411			M
1234678-HpCDD	0.00379	1.86	0.0186	0.0186	69		M
OCDD	0.0041	2.05	0.00205	0.00205	62		M
<b>Dioxins Total</b>			<b>0.548</b>	<b>0.548</b>			M
2378-TCDF	0.0209	1.20	0.120	0.120	90		M
12378-PeCDF	0.0139	1.16	0.0582	0.0582		105	M
23478-PeCDF	0.0127	1.85	0.925	0.925	107		M
123478-HxCDF	0.00901	1.15	0.115	0.115	87		M
123678-HxCDF	0.00950	1.33	0.133	0.133	80		M
234678-HxCDF	0.00791	1.31	0.131	0.131	90		M
123789-HxCDF	0.00996	0.130	0.0130	0.0130		92	M
1234678-HpCDF	0.00344	2.88	0.0288	0.0288	67		M
1234789-HpCDF	0.00428	0.521	0.00521	0.00521		90	M
OCDF	0.00386	1.40	0.00140	0.00140	53		M
<b>Furans Total</b>			<b>1.53</b>	<b>1.53</b>			M
<b>Dioxin/Furan Total</b>			<b>2.08</b>	<b>2.08</b>			M

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

### 465388 Dioxin Results

Sample Type : Stack  
 MSS Sample Ref : 465388  
 Customer Sample Ref : ECL/24/0408 -ECL/24/0410  
 Sample Condition : Non-Conforming<sup>(1)</sup>  
 Test Method : 2002b

Congener	LOD	Detected	Lower Bound	Upper Bound	Recovery	Sampling Recovery	UKAS
Dioxins/Furans	ng/Sample	ng/Sample	ng/Sample	ng/Sample	%	%	
2378-TCDD	0.00014	< 0.00014	0.0000	0.00014	119		M
12378-PeCDD	0.00019	< 0.00019	0.0000	0.00009	116		M
123478-HxCDD	0.00032	< 0.00032	0.0000	0.00003	100		M
123678-HxCDD	0.00035	< 0.00035	0.0000	0.00004	94		M
123789-HxCDD	0.00038	< 0.00038	0.0000	0.00004			M
1234678-HpCDD	0.00038	< 0.00038	0.0000	0.00000	88		M
OCDD	0.0014	< 0.00135	0.0000	0.00000	86		M
<b>Dioxins Total</b>			<b>0.0000</b>	<b>0.00035</b>			M
2378-TCDF	0.00027	< 0.00027	0.0000	0.00003	86		M
12378-PeCDF	0.00026	< 0.00026	0.0000	0.00001		107	M
23478-PeCDF	0.00027	0.00074	0.00037	0.00037	97		M
123478-HxCDF	0.00019	< 0.00019	0.0000	0.00002	80		M
123678-HxCDF	0.00016	< 0.00016	0.0000	0.00002	85		M
234678-HxCDF	0.00016	< 0.00016	0.0000	0.00002	88		M
123789-HxCDF	0.00018	< 0.00018	0.0000	0.00002		89	M
1234678-HpCDF	0.00045	< 0.00045	0.0000	0.00000	71		M
1234789-HpCDF	0.00065	< 0.00065	0.0000	0.00001		92	M
OCDF	0.00056	< 0.00056	0.0000	0.00000	82		M
<b>Furans Total</b>			<b>0.00037</b>	<b>0.00049</b>			M
<b>Dioxin/Furan Total</b>			<b>0.00037</b>	<b>0.00084</b>			M



Environmental Compliance Limited

Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632

: R001

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date. : 20th December 2024

## UNCERTAINTY CALCULATIONS

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Combustion Gases (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Measurement Uncertainty – Light Medical Waste**  
 Measurement Uncertainty Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Minimum Certified Range (R <sub>i</sub> )			
			NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{d,s}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.094	0.056	0.0057	0.074
Repeatability Standard Deviation (span) <sup>(3)</sup>	$u_r$	Normal ( Divisor = 1 )	2.08	2.37	0.26	0.18
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$	Rectangular ( Divisor = $\sqrt{3}$ )	1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	$u_t$	Rectangular ( Divisor = $\sqrt{3}$ )	0.051	0.057	0.014	0.029
Interferents <sup>(1)</sup>	$u_i$	Rectangular ( Divisor = $\sqrt{3}$ )	0.52	0.87	0.010	0.55
Uncertainty of Reference Gas <sup>(6)</sup>	$u_{ref}$	Rectangular ( Divisor = $\sqrt{3}$ )	10.80	6.52	0.15	0.31
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	Rectangular ( Divisor = $\sqrt{3}$ )	0.40	0.50	0.020	0.40
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.10	0.10	0.10	0.10

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m<sup>3</sup> / %Vol inc additional uncertainty of 2% for gas blending
- Expressed as a percentage of the certified range

Measurement Uncertainty Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{lof}$	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.58	0.26	0.014	0.12
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.073	0.024	0.00082	0.0085
Repeatability Standard Deviation (span)	$u_r$	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	2.08	2.37	0.26	0.18
Losses / leakage in the sample system	$u_{loss}$	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.42	0.85	0.027	0.04
Temperature dependant span drift	$u_t$	$u(x_i) = \frac{u_t \times R_i}{100} \times \sqrt{\frac{(x_{i,max} - x_{adj})^2 + (x_{i,min} - x_{adj})^2 + (x_{i,max} - x_{adj})(x_{i,min} - x_{adj}) + (x_{i,min} - x_{adj})^2}{3}}$	0.13	0.080	0.0067	0.011
Interferents	$u_i$	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.40	0.38	0.0014	0.55
Uncertainty of Reference Gas	$u_{ref}$	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	6.23	3.76	0.087	0.18
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.23	0.29	0.012	0.23
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	$u(x_i) = \frac{u_{sg} \times R_i}{\sqrt{3}} =$	0.058	0.058	0.058	0.06
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{sg}^2}$	6.77	4.56	0.28	0.37
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	13.53	9.12	0.56	0.74
Applied Span Concentration			623.41	376.38	15.05	17.95
Measured Span Concentration, STP Dry Gas			624.08	373.03	14.95	17.92
Expanded measurement uncertainty as % of Applied Span			2%	2%	4%	4%

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Combustion Gases (NOx, CO, CO<sub>2</sub> & O<sub>2</sub>) Uncertainty of Measurement Results – Light Medical Waste @ Reference Conditions 273K, 101.3kPa, Dry Gas & 3%Oxygen

### Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R)			
				NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{df}$	Rectangular	$\sqrt{3}$	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{ds}$			0.094	0.056	0.0057	0.074
Losses / leakage in the sample system <sup>(4)</sup>	$u_{lss}$			1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(3)</sup>	$u_t$			0.051	0.057	0.014	0.029
Interferents <sup>(5)</sup>	$u_i$			0.52	0.87	0.010	0.55
Effect of Voltage Fluctuation <sup>(6)</sup>	$u_v$			0.40	0.50	0.020	0.40
Sample Gas Pressure/ Flow <sup>(7)</sup>	$u_{sp}$			0.10	0.10	0.10	0.10

Notes:

For rectangular distributions,  $u(x_i) = \frac{u \times R}{\sqrt{3}}$

For  $u(x_i) = \Delta x_i \sqrt{\frac{1}{3} \left[ \frac{(x_{i,max} - x_{i,min})^2}{(x_{i,max} - x_{i,min})^2 + (x_{i,max} - x_{i,min})^2 + (x_{i,max} - x_{i,min})^2} \right]}$ , when  $|x_{i,max} - x_{i,min}| = |x_{i,max} - x_{i,min}|$  then  $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum (x_i - \bar{x})^2}{n-1}}$

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO	CO	O <sub>2</sub>	CO <sub>2</sub>
				0 - 134 mg/m <sup>3</sup>	0 - 75 mg/m <sup>3</sup>	0 - 25 %Vol	0 - 20 %Vol
Lack of fit	$u_{df}$	Rectangular	$\sqrt{3}$	0.58	0.26	0.014	0.12
Span drift	$u_{ds}$			0.073	0.024	0.00082	0.0085
Temperature dependant span drift	$u_t$			0.13	0.084	0.0070	0.0066
Interferents	$u_i$			0.40	0.38	0.0014	0.064
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			0.31	0.22	0.0029	0.046
Sample Gas Pressure/ Flow <sup>(7)</sup>	$u_{sp}$			0.077	0.043	0.014	0.012

### Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO	CO	O <sub>2</sub>	CO <sub>2</sub>
			0 - 134 mg/m <sup>3</sup>	0 - 75 mg/m <sup>3</sup>	0 - 25 %Vol	0 - 20 %Vol
Losses / leakage in the sample system	$u_{lss}$	13/02/24 09:45 - 10:14	4.48	231.46	0.029	0.012
		13/02/24 10:15 - 10:44	4.57	197.13	0.028	0.013
		13/02/24 10:45 - 11:14	7.83	102.97	0.033	0.0080
		13/02/24 11:15 - 11:44	5.28	171.18	0.037	0.0017
		13/02/24 11:45 - 12:14	2.84	121.80	0.037	0.00071
		13/02/24 12:15 - 12:44	4.38	181.24	0.031	0.0093
		13/02/24 12:45 - 13:14	3.21	128.73	0.037	0.0011
		13/02/24 13:15 - 13:44	5.84	183.81	0.023	0.020
		13/02/24 13:45 - 14:14	9.59	103.67	0.034	0.0059
		13/02/24 14:15 - 14:44	3.39	152.76	0.020	0.025
		13/02/24 14:45 - 15:14	6.42	44.93	0.032	0.0085
		13/02/24 15:15 - 15:44	5.93	130.43	0.036	0.0031
		Standard Error of Measured Value	$u_{SE}$	13/02/24 09:45 - 10:14	8.75	823.73
13/02/24 10:15 - 10:44	8.33			785.93	0.89	0.64
13/02/24 10:45 - 11:14	10.91			301.42	0.54	0.46
13/02/24 11:15 - 11:44	1.84			21.94	0.050	0.040
13/02/24 11:45 - 12:14	0.21			4.66	0.0065	0.0058
13/02/24 12:15 - 12:44	8.12			740.16	0.87	0.62
13/02/24 12:45 - 13:14	1.20			23.10	0.043	0.033
13/02/24 13:15 - 13:44	10.37			989.67	0.94	0.67
13/02/24 13:45 - 14:14	4.63			36.71	0.12	0.097
13/02/24 14:15 - 14:44	5.58			820.16	0.74	0.54
13/02/24 14:45 - 15:14	3.16			19.10	0.20	0.16
13/02/24 15:15 - 15:44	1.40			4.26	0.047	0.040

**Effect on Uncertainty Caused by Oxygen**

$$u_{Corr, O_2} = \frac{20.9\% - O_2}{(20.9\% - O_{2,measured}) - (20.9\% - O_{2,measured})} \times (\text{Uncertainty of } O_2 \text{ Measurement}) = 0.215$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.0510 \quad u_{f_{O_2}} = \frac{u_{Corr, O_2}}{f_{O_2}} \times 100 = 20.48\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C.

$$u(x_i) = C \cdot u_i \quad \text{where } C_i = \frac{\partial f}{\partial x_i}$$

### Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 350 E Uncertainty	Date & Time	NOx (as NO <sub>2</sub> )	CO	O <sub>2</sub>	CO <sub>2</sub>
		0 - 134 mg/m <sup>3</sup>	0 - 75 mg/m <sup>3</sup>	0 - 25 %Vol	0 - 20 %Vol
Measured Concentration	13/02/24 09:45 - 10:14	243.87	11732.38	15.72	3.75
Expanded Uncertainty as Percentage of Measured Concentration		22%	25%	24%	45%
Measured Concentration	13/02/24 10:15 - 10:44	249.17	9992.12	15.26	4.01
Expanded Uncertainty as Percentage of Measured Concentration		22%	26%	24%	38%
Measured Concentration	13/02/24 10:45 - 11:14	426.76	5219.24	17.71	2.47
Expanded Uncertainty as Percentage of Measured Concentration		21%	24%	21%	44%
Measured Concentration	13/02/24 11:15 - 11:44	287.67	8676.88	19.99	0.51
Expanded Uncertainty as Percentage of Measured Concentration		21%	21%	20%	58%
Measured Concentration	13/02/24 11:45 - 12:14	111.16	6174.06	20.35	0.22
Expanded Uncertainty as Percentage of Measured Concentration		21%	21%	20%	>100%
Measured Concentration	13/02/24 12:15 - 12:44	238.78	9186.91	16.87	2.89
Expanded Uncertainty as Percentage of Measured Concentration		22%	26%	23%	48%
Measured Concentration	13/02/24 12:45 - 13:14	175.14	6525.19	20.16	0.35
Expanded Uncertainty as Percentage of Measured Concentration		21%	21%	20%	80%
Measured Concentration	13/02/24 13:15 - 13:44	318.26	9316.88	12.59	6.13
Expanded Uncertainty as Percentage of Measured Concentration		22%	30%	25%	30%
Measured Concentration	13/02/24 13:45 - 14:14	522.31	5254.88	18.28	1.84
Expanded Uncertainty as Percentage of Measured Concentration		21%	21%	21%	27%
Measured Concentration	13/02/24 14:15 - 14:44	184.70	7743.34	10.64	7.80
Expanded Uncertainty as Percentage of Measured Concentration		22%	30%	25%	25%
Measured Concentration	13/02/24 14:45 - 15:14	349.72	2277.23	17.38	2.65
Expanded Uncertainty as Percentage of Measured Concentration		21%	21%	21%	26%
Measured Concentration	13/02/24 15:15 - 15:44	323.22	6611.16	19.42	0.97
Expanded Uncertainty as Percentage of Measured Concentration		21%	21%	20%	35%

$$u_c = \sqrt{u_{df}^2 + u_{ds}^2 + u_t^2 + u_{lss}^2 + u_i^2 + u_v^2 + u_{sp}^2 + u_{f_{O_2}}^2}$$

$$\text{Expanded uncertainty (at 95\% confidence)} \quad U_{95} = 2 \times u_c$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be >100%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Combustion Gases (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Measurement Uncertainty – Medium Bin Medical Waste**

Measurement Uncertainty Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Minimum Certified Range (R <sub>i</sub> )			
			NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{d,s}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.094	0.056	0.0057	0.074
Repeatability Standard Deviation (span) <sup>(3)</sup>	$u_r$	Normal ( Divisor = 1 )	2.14	1.36	0.03	0.37
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$	Rectangular ( Divisor = $\sqrt{3}$ )	1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	$u_t$	Rectangular ( Divisor = $\sqrt{3}$ )	0.051	0.057	0.014	0.029
Interferents <sup>(1)</sup>	$u_i$	Rectangular ( Divisor = $\sqrt{3}$ )	0.52	0.87	0.010	0.55
Uncertainty of Reference Gas <sup>(6)</sup>	$u_{ref}$	Rectangular ( Divisor = $\sqrt{3}$ )	10.80	6.52	0.15	0.31
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	Rectangular ( Divisor = $\sqrt{3}$ )	0.40	0.50	0.020	0.40
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.10	0.10	0.10	0.10

Note:

$$\text{when } (x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj}), \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m<sup>3</sup> / %Vol inc additional uncertainty of 2% for gas blending
- Expressed as a percentage of the certified range

Measurement Uncertainty Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{lof}$	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.58	0.26	0.014	0.12
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.073	0.024	0.00082	0.0085
Repeatability Standard Deviation (span)	$u_r$	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	2.14	1.36	0.03	0.37
Losses / leakage in the sample system	$u_{loss}$	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.42	0.85	0.027	0.04
Temperature dependant span drift	$u_t$	$u(x_i) = \frac{u_t \times R_i}{100} \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj})}{3}}$	0.15	0.093	0.0077	0.012
Interferents	$u_i$	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.40	0.38	0.0014	0.55
Uncertainty of Reference Gas	$u_{ref}$	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	6.23	3.76	0.087	0.18
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.23	0.29	0.012	0.23
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	$u(x_i) = \frac{u_{sg} \times R_i}{\sqrt{3}} =$	0.058	0.058	0.058	0.06
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{sg}^2}$	6.78	4.13	0.11	0.49
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	13.57	8.26	0.23	0.97
Applied Span Concentration			623.41	376.38	15.05	17.95
Measured Span Concentration, STP Dry Gas			623.64	374.00	15.01	17.95
Expanded measurement uncertainty as% of Applied Span			2%	2%	2%	5%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Combustion Gases (NOx, CO, CO<sub>2</sub> & O<sub>2</sub>) Uncertainty of Measurement Results – Medium Bin Medical Waste @ Reference Conditions 273K, 101.3kPa, Dry Gas & 3%Oxygen (Part 1)

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R <sub>i</sub> )			
				NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{fit}$	Rectangular	$\sqrt{3}$	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{sd}$			0.094	0.056	0.0057	0.074
Losses / leakage in the sample system <sup>(4)</sup>	$u_{lls}$			1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(3)</sup>	$u_t$			0.051	0.057	0.014	0.029
Interferents <sup>(5)</sup>	$u_i$			0.52	0.87	0.010	0.55
Effect of Voltage Fluctuation <sup>(6)</sup>	$u_v$			0.40	0.50	0.020	0.40
Sample Gas Pressure/ Flow <sup>(7)</sup>	$u_{sp}$			0.10	0.10	0.10	0.10

Notes:

For rectangular distributions,  $u(x_i) = \frac{u \times R}{\sqrt{3}}$

For  $u(x_i) = \Delta x \sqrt{\frac{(x_{i,max} - x_{i,min})^2 + (x_{i,max} - x_{i,ref})^2 + (x_{i,min} - x_{i,ref})^2}{3}}$ , when  $|x_{i,max} - x_{i,ref}| = |x_{i,min} - x_{i,ref}|$  then  $u(x_i) = \frac{\Delta x}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{fit}$	Rectangular	$\sqrt{3}$	0.58	0.26	0.014	0.12
Span drift	$u_{sd}$			0.073	0.024	0.00082	0.0085
Temperature dependant span drift	$u_t$			0.13	0.081	0.0067	0.0066
Interferents	$u_i$			0.40	0.38	0.0014	0.064
Effect of Voltage Fluctuation <sup>(1)</sup>	$u_v$			0.31	0.22	0.0029	0.046
Sample Gas Pressure/ Flow <sup>(7)</sup>	$u_{sp}$			0.077	0.043	0.014	0.012

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Losses / leakage in the sample system	$u_{lls}$	14/02/24 09:15 - 09:44	3.73	97.78	0.031	0.0093
		14/02/24 09:45 - 10:14	5.50	126.59	0.031	0.0094
		14/02/24 10:15 - 10:44	5.17	91.04	0.030	0.011
		14/02/24 10:45 - 11:14	4.78	82.45	0.030	0.011
		14/02/24 11:15 - 11:44	6.10	54.39	0.031	0.0099
		14/02/24 11:45 - 12:14	4.55	54.29	0.030	0.011
		14/02/24 12:15 - 12:44	4.07	46.50	0.034	0.0057
		14/02/24 12:45 - 13:14	3.24	36.48	0.034	0.0056
		14/02/24 13:15 - 13:44	2.69	72.89	0.031	0.0090
		14/02/24 13:45 - 14:14	4.00	48.50	0.031	0.0092
Standard Error of Measured Value	$u_{SE}$	14/02/24 09:15 - 09:44	6.23	393.44	0.74	0.51
		14/02/24 09:45 - 10:14	4.52	532.85	0.61	0.42
		14/02/24 10:15 - 10:44	4.44	517.35	0.54	0.36
		14/02/24 10:45 - 11:14	2.02	382.26	0.49	0.34
		14/02/24 11:15 - 11:44	5.79	151.50	0.45	0.34
		14/02/24 11:45 - 12:14	4.16	227.60	0.45	0.31
		14/02/24 12:15 - 12:44	2.86	30.58	0.31	0.22
		14/02/24 12:45 - 13:14	3.52	20.82	0.41	0.31
		14/02/24 13:15 - 13:44	4.85	357.31	0.72	0.53
		14/02/24 13:45 - 14:14	4.62	104.35	0.51	0.38
14/02/24 14:15 - 14:44	5.01	12.11	0.19	0.15		
14/02/24 14:45 - 15:14	5.62	58.04	0.23	0.23		

**Effect on Uncertainty Caused by Oxygen**

$$u_{O_2}^{corr} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured})} \times (\text{Uncertainty of } O_2 \text{ Measured}) = 0.221$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.0477 \quad u_{f_{O_2}} = \frac{u_{O_2}^{corr} \times 100}{f_{O_2}} = 21.12\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C.

$\therefore u(x_i) = C \cdot u$ , where  $C = \frac{\partial x}{\partial u}$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 350 E Uncertainty	Date & Time	NOx (as NO <sub>2</sub> ) 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Measured Concentration	14/02/24 09:15 - 09:44	203.19	4966.53	16.79	2.89
Expanded Uncertainty as Percentage of Measured Concentration		22%	27%	23%	42%
Measured Concentration	14/02/24 09:45 - 10:14	299.80	6416.43	16.87	2.93
Expanded Uncertainty as Percentage of Measured Concentration		22%	27%	22%	37%
Measured Concentration	14/02/24 10:15 - 10:44	281.86	4614.66	16.31	3.44
Expanded Uncertainty as Percentage of Measured Concentration		22%	31%	22%	31%
Measured Concentration	14/02/24 10:45 - 11:14	260.49	4179.21	16.37	3.36
Expanded Uncertainty as Percentage of Measured Concentration		22%	28%	22%	31%
Measured Concentration	14/02/24 11:15 - 11:44	332.26	2757.03	16.67	3.07
Expanded Uncertainty as Percentage of Measured Concentration		22%	24%	22%	32%
Measured Concentration	14/02/24 11:45 - 12:14	247.68	2751.77	16.13	3.45
Expanded Uncertainty as Percentage of Measured Concentration		22%	27%	22%	29%
Measured Concentration	14/02/24 12:15 - 12:44	221.73	2357.00	18.52	1.78
Expanded Uncertainty as Percentage of Measured Concentration		22%	22%	21%	36%
Measured Concentration	14/02/24 12:45 - 13:14	176.70	1848.96	18.45	1.75
Expanded Uncertainty as Percentage of Measured Concentration		22%	22%	22%	44%
Measured Concentration	14/02/24 13:15 - 13:44	146.44	3694.55	16.89	2.81
Expanded Uncertainty as Percentage of Measured Concentration		22%	29%	23%	44%
Measured Concentration	14/02/24 13:45 - 14:14	218.01	2458.14	16.94	2.85
Expanded Uncertainty as Percentage of Measured Concentration		22%	23%	22%	35%
Measured Concentration	14/02/24 14:15 - 14:44	419.14	1920.76	17.64	2.42
Expanded Uncertainty as Percentage of Measured Concentration		22%	22%	21%	27%
Measured Concentration	14/02/24 14:45 - 15:14	461.92	2747.17	17.45	2.68
Expanded Uncertainty as Percentage of Measured Concentration		22%	22%	21%	29%

Combined Standard Uncertainty  $u_c = \sqrt{u_{fit}^2 + u_{sd}^2 + u_t^2 + u_i^2 + u_v^2 + u_{sp}^2 + u_{lls}^2 + u_{SE}^2}$

Expanded uncertainty (at 95% confidence)  $U_{95} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be >100%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Combustion Gases (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Uncertainty of Measurement Results – Medium Bin Medical Waste @ Reference Conditions 273K, 101.3kPa, Dry Gas & 3%Oxygen (Part 2)**

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R <sub>i</sub> )			
				NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	<i>u<sub>lof</sub></i>	Rectangular	$\sqrt{3}$	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	<i>u<sub>ds</sub></i>			0.094	0.056	0.0057	0.074
Losses / leakage in the sample system <sup>(4)</sup>	<i>u<sub>loss</sub></i>			1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	<i>u<sub>t</sub></i>			0.051	0.057	0.014	0.029
Interferents <sup>(1)</sup>	<i>u<sub>i</sub></i>			0.52	0.87	0.010	0.55
Effect of Voltage Fluctuation <sup>(7)</sup>	<i>u<sub>v</sub></i>			0.40	0.50	0.020	0.40
Sample Gas Pressure/ Flow <sup>(7)</sup>	<i>u<sub>sg</sub></i>			0.10	0.10	0.10	0.10

Notes:

For rectangular distributions,  $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For  $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj})}{3}}$ , when  $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$ , then  $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	<i>u<sub>lof</sub></i>	Rectangular	$\sqrt{3}$	0.58	0.26	0.014	0.12
Span drift	<i>u<sub>ds</sub></i>			0.073	0.024	0.00082	0.0085
Temperature dependant span drift	<i>u<sub>t</sub></i>			0.13	0.081	0.0067	0.0066
Interferents	<i>u<sub>i</sub></i>			0.40	0.38	0.0014	0.064
Effect of Voltage Fluctuation <sup>(7)</sup>	<i>u<sub>v</sub></i>			0.31	0.22	0.0029	0.046
Sample Gas Pressure/ Flow <sup>(7)</sup>	<i>u<sub>sg</sub></i>			0.077	0.043	0.014	0.012

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Losses / leakage in the sample system	<i>u<sub>loss</sub></i>	14/02/24 15:15 - 15:44	9.06	58.35	0.033	0.0076
Standard Error of Measured Value	<i>u<sub>SE</sub></i>	14/02/24 15:15 - 15:44	5.60	36.08	0.23	0.18

**Effect on Uncertainty Caused by Oxygen**

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.311$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.0123 \quad u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 30.76\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$\therefore u(x_i) = C_i u_i$  where  $C_i = \frac{\partial f}{\partial x_i}$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 350 E Uncertainty	Date & Time	NO <sub>x</sub> (as NO <sub>2</sub> ) 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Measured Concentration	14/02/24 15:15 - 15:44	493.87	2957.75	17.68	2.37
Expanded Uncertainty as Percentage of Measured Concentration		31%	31%	31%	36%

Combined Standard Uncertainty  $u_c = \sqrt{u_{lof}^2 + u_{ds}^2 + u_t^2 + u_{loss}^2 + u_i^2 + u_v^2 + u_{sg}^2 + u_{f_{O_2}}^2}$

Expanded uncertainty (at 95% confidence)  $U_{Exp} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be >100%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Combustion Gases (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Measurement Uncertainty – Dead Animal Waste (15/02/2024)**

Measurement Uncertainty Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Minimum Certified Range (R <sub>i</sub> )			
			NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{d,s}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.094	0.056	0.0057	0.074
Repeatability Standard Deviation (span) <sup>(3)</sup>	$u_r$	Normal ( Divisor = 1 )	1.89	0.90	0.12	0.37
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$	Rectangular ( Divisor = $\sqrt{3}$ )	1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	$u_t$	Rectangular ( Divisor = $\sqrt{3}$ )	0.051	0.057	0.014	0.029
Interferents <sup>(1)</sup>	$u_i$	Rectangular ( Divisor = $\sqrt{3}$ )	0.52	0.87	0.010	0.55
Uncertainty of Reference Gas <sup>(6)</sup>	$u_{ref}$	Rectangular ( Divisor = $\sqrt{3}$ )	10.80	6.52	0.15	0.31
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	Rectangular ( Divisor = $\sqrt{3}$ )	0.40	0.50	0.020	0.40
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.10	0.10	0.10	0.10

Note:

$$\text{when } (x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj}), \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m<sup>3</sup> / %Vol inc additional uncertainty of 2% for gas blending
- Expressed as a percentage of the certified range

Measurement Uncertainty Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{lof}$	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.58	0.26	0.014	0.12
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.073	0.024	0.00082	0.0085
Repeatability Standard Deviation (span)	$u_r$	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	1.89	0.90	0.12	0.37
Losses / leakage in the sample system	$u_{loss}$	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.42	0.85	0.027	0.04
Temperature dependant span drift	$u_t$	$u(x_i) = \frac{u_t \times R_i}{100} \times \sqrt{\frac{(x_{i,max} - x_{adj})^2 + (x_{i,min} - x_{adj})^2 + (x_{i,max} - x_{adj})(x_{i,min} - x_{adj})}{3}} =$	0.15	0.093	0.0077	0.012
Interferents	$u_i$	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.40	0.38	0.0014	0.55
Uncertainty of Reference Gas	$u_{ref}$	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	6.23	3.76	0.087	0.18
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.23	0.29	0.012	0.23
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	$u(x_i) = \frac{u_{sg} \times R_i}{\sqrt{3}} =$	0.058	0.058	0.058	0.06
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{sg}^2} =$	6.71	4.00	0.17	0.49
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	13.42	8.00	0.33	0.98
Applied Span Concentration			623.41	376.38	15.05	17.95
Measured Span Concentration, STP Dry Gas			623.41	375.45	15.03	17.96
Expanded measurement uncertainty as% of Applied Span			2%	2%	2%	5%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Combustion Gases (NOx, CO, CO<sub>2</sub> & O<sub>2</sub>) Uncertainty of Measurement Results – Dead Animal Waste @ Reference Conditions 273K, 101.3kPa, Dry Gas & 3%Oxygen (15/02/2024)

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R)			
				NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{kf}$	Rectangular	$\sqrt{3}$	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{ds}$			0.094	0.056	0.0057	0.074
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$			1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	$u_t$			0.051	0.057	0.014	0.029
Interferents <sup>(6)</sup>	$u_i$			0.52	0.87	0.010	0.55
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			0.40	0.50	0.020	0.40
Sample Gas Pressure/ Flow <sup>(8)</sup>	$u_{sp}$			0.10	0.10	0.10	0.10

Notes:

For rectangular distributions,  $u(x_i) = \frac{u \times R}{\sqrt{3}}$

For  $u(x_i) = \Delta x \sqrt{\frac{(x_{i,max} - x_{i,ref})^2 + (x_{i,min} - x_{i,ref})^2 + (x_{i,max} - x_{i,min})^2}{3}}$ , when  $|x_{i,max} - x_{i,ref}| = |x_{i,min} - x_{i,ref}|$ , then  $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum (x_i - \bar{x})^2}{n-1}}$

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{kf}$	Rectangular	$\sqrt{3}$	0.58	0.26	0.014	0.12
Span drift	$u_{ds}$			0.073	0.024	0.00082	0.0085
Temperature dependant span drift	$u_t$			0.13	0.081	0.0067	0.0066
Interferents	$u_i$			0.40	0.38	0.0014	0.064
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			0.31	0.22	0.0029	0.046
Sample Gas Pressure/ Flow <sup>(8)</sup>	$u_{sp}$			0.077	0.043	0.014	0.012

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Losses / leakage in the sample system	$u_{loss}$	15/02/24 16:00 - 16:29	6.37	104.92	0.035	0.0041
		15/02/24 16:30 - 16:59	6.13	45.15	0.033	0.0066
		15/02/24 17:00 - 17:29	6.28	19.96	0.023	0.020
		15/02/24 17:30 - 17:59	7.19	34.94	0.022	0.022
		15/02/24 18:00 - 18:29	5.85	3.58	0.011	0.036
		15/02/24 18:30 - 18:59	7.84	38.48	0.013	0.035
		15/02/24 19:00 - 19:29	13.59	5.52	0.027	0.015
		15/02/24 19:30 - 19:59	8.93	37.74	0.027	0.015
		15/02/24 20:00 - 20:29	6.05	9.99	0.024	0.019
		15/02/24 20:30 - 20:59	12.93	26.70	0.030	0.011
Standard Error of Measured Value	$u_{SE}$	15/02/24 16:00 - 16:29	4.48	47.05	0.13	0.11
		15/02/24 16:30 - 16:59	15.11	22.12	0.63	0.48
		15/02/24 17:00 - 17:29	13.62	125.89	0.92	0.70
		15/02/24 17:30 - 17:59	25.90	184.41	1.38	1.04
		15/02/24 18:00 - 18:29	6.47	62.27	0.69	0.54
		15/02/24 18:30 - 18:59	20.93	501.33	0.83	0.60
		15/02/24 19:00 - 19:29	11.81	33.28	0.59	0.43
		15/02/24 19:30 - 19:59	19.27	107.12	0.94	0.72
		15/02/24 20:00 - 20:29	4.43	14.29	0.12	0.090
		15/02/24 20:30 - 20:59	4.60	53.77	0.25	0.19

Effect on Uncertainty Caused by Oxygen  $u_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times 100} \times (\text{Uncertainty of } O_2 \text{ Measured at } 20.9\%)$

$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.3553$   $u_{O_2} = \frac{u_{O_2,measured} \times 100}{f_{O_2}} = 4.30\%$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_i})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C.

$\therefore u(x_i) = C \times u_c$  where  $C_i = \frac{\partial f}{\partial x_i}$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 350 E Uncertainty	Date & Time	NOx (as NO2) 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Measured Concentration	15/02/24 16:00 - 16:29	347.09	5317.99	19.13	1.27
Expanded Uncertainty as Percentage of Measured Concentration		6%	6%	5%	28%
Measured Concentration	15/02/24 16:30 - 16:59	334.02	2288.80	18.03	2.05
Expanded Uncertainty as Percentage of Measured Concentration		11%	6%	8%	48%
Measured Concentration	15/02/24 17:00 - 17:29	342.12	1011.91	12.36	6.27
Expanded Uncertainty as Percentage of Measured Concentration		10%	26%	16%	23%
Measured Concentration	15/02/24 17:30 - 17:59	391.55	1770.92	12.17	6.71
Expanded Uncertainty as Percentage of Measured Concentration		14%	22%	23%	32%
Measured Concentration	15/02/24 18:00 - 18:29	318.54	181.55	6.10	11.15
Expanded Uncertainty as Percentage of Measured Concentration		7%	69%	23%	11%
Measured Concentration	15/02/24 18:30 - 18:59	427.28	1850.34	6.90	10.85
Expanded Uncertainty as Percentage of Measured Concentration		11%	52%	24%	12%
Measured Concentration	15/02/24 19:00 - 19:29	740.55	279.74	14.70	4.76
Expanded Uncertainty as Percentage of Measured Concentration		6%	24%	9%	20%
Measured Concentration	15/02/24 19:30 - 19:59	486.63	1912.88	14.91	4.51
Expanded Uncertainty as Percentage of Measured Concentration		10%	13%	13%	33%
Measured Concentration	15/02/24 20:00 - 20:29	329.60	506.42	13.22	5.91
Expanded Uncertainty as Percentage of Measured Concentration		6%	8%	5%	7%
Measured Concentration	15/02/24 20:30 - 20:59	704.51	1353.35	16.53	3.35
Expanded Uncertainty as Percentage of Measured Concentration		6%	10%	5%	15%

Combined Standard Uncertainty  $u_c = \sqrt{u_{kf}^2 + u_{ds}^2 + u_t^2 + u_{loss}^2 + u_i^2 + u_v^2 + u_{sp}^2 + u_{O_2}^2}$

Expanded uncertainty (at 95% confidence)  $U_{95} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be >100%



Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Combustion Gases (NO<sub>x</sub>, CO, CO<sub>2</sub> & O<sub>2</sub>) Measurement Uncertainty – Dead Animal Waste (16/02/2024)**

Measurement Uncertainty Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Minimum Certified Range (R <sub>i</sub> )			
			NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{d,s}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.094	0.056	0.0057	0.074
Repeatability Standard Deviation (span) <sup>(3)</sup>	$u_r$	Normal ( Divisor = 1 )	1.98	0.80	0.05	0.22
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$	Rectangular ( Divisor = $\sqrt{3}$ )	1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	$u_t$	Rectangular ( Divisor = $\sqrt{3}$ )	0.051	0.057	0.014	0.029
Interferents <sup>(1)</sup>	$u_i$	Rectangular ( Divisor = $\sqrt{3}$ )	0.52	0.87	0.010	0.55
Uncertainty of Reference Gas <sup>(6)</sup>	$u_{ref}$	Rectangular ( Divisor = $\sqrt{3}$ )	10.80	6.52	0.15	0.31
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	Rectangular ( Divisor = $\sqrt{3}$ )	0.40	0.50	0.020	0.40
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.10	0.10	0.10	0.10

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Expressed as standard uncertainty in units of measurement i.e. mg/m<sup>3</sup> / %Vol inc additional uncertainty of 2% for gas blending
- Expressed as a percentage of the certified range

Measurement Uncertainty Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{lof}$	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.58	0.26	0.014	0.12
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.073	0.024	0.00082	0.0085
Repeatability Standard Deviation (span)	$u_r$	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	1.98	0.80	0.05	0.22
Losses / leakage in the sample system	$u_{loss}$	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.42	0.85	0.027	0.04
Temperature dependant span drift	$u_t$	$u(x_i) = \frac{u_t \times R_i}{100} \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,min})^2}{3}}$	0.15	0.093	0.0077	0.012
Interferents	$u_i$	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.40	0.38	0.0014	0.55
Uncertainty of Reference Gas	$u_{ref}$	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	6.23	3.76	0.087	0.18
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.23	0.29	0.012	0.23
Effect of Sample Gas Flow / Pressure <sup>(7)</sup>	$u_{sg}$	$u(x_i) = \frac{u_{sg} \times R_i}{\sqrt{3}} =$	0.058	0.058	0.058	0.06
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{sg}^2}$	6.74	3.98	0.12	0.39
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	13.48	7.96	0.24	0.78
Applied Span Concentration			623.41	376.38	15.05	17.95
Measured Span Concentration, STP Dry Gas			623.84	374.49	15.01	17.92
Expanded measurement uncertainty as % of Applied Span			2%	2%	2%	4%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Combustion Gases (NOx, CO, CO<sub>2</sub> & O<sub>2</sub>) Uncertainty of Measurement Results – Dead Animal Waste @ Reference Conditions 273K, 101.3kPa, Dry Gas & 3%Oxygen (16/02/2024)**

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R <sub>i</sub> )			
				NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular	$\sqrt{3}$	0.75	0.61	0.10	1.00
Span drift <sup>(2)</sup>	$u_{ds}$			0.094	0.056	0.0057	0.074
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$			1.84	1.97	0.18	0.32
Temperature dependant span drift <sup>(5)</sup>	$u_t$			0.051	0.057	0.014	0.029
Interferents <sup>(1)</sup>	$u_i$			0.52	0.87	0.010	0.55
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			0.40	0.50	0.020	0.40
Sample Gas Pressure/ Flow <sup>(7)</sup>	$u_{sg}$			0.10	0.10	0.10	0.10

Notes:

For rectangular distributions,  $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For  $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2}{3}}$ , when  $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$ , then  $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Lack of fit	$u_{lof}$	Rectangular	$\sqrt{3}$	0.58	0.26	0.014	0.12
Span drift	$u_{ds}$			0.073	0.024	0.00082	0.0085
Temperature dependant span drift	$u_t$			0.065	0.041	0.0034	0.0066
Interferents	$u_i$			0.40	0.38	0.0014	0.064
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			0.31	0.22	0.0029	0.046
Sample Gas Pressure/ Flow <sup>(7)</sup>	$u_{sg}$			0.077	0.043	0.014	0.012

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Losses / leakage in the sample system	$u_{loss}$	16/02/24 10:40 - 11:09	4.82	2.57	0.015	0.030
		16/02/24 11:10 - 11:39	6.67	1.04	0.022	0.022
Standard Error of Measured Value	$u_{SE}$	16/02/24 10:40 - 11:09	11.03	29.95	0.90	0.68
		16/02/24 11:10 - 11:39	10.70	1.63	0.16	0.098

**Effect on Uncertainty Caused by Oxygen**  $u_{Corr, O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.028$

$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.7743$   $u_{f_{O_2}} = \frac{u_{Corr, O_2}}{f_{O_2}} \times 100 = 1.55\%$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$\therefore u(x_i) = C_i u_i$  where  $C_i = \frac{\partial f}{\partial x_i}$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 350 E Uncertainty	Date & Time	NOx (as NO2) 0 - 134 mg/m <sup>3</sup>	CO 0 - 75 mg/m <sup>3</sup>	O <sub>2</sub> 0 - 25 %Vol	CO <sub>2</sub> 0 - 20 %Vol
Measured Concentration	16/02/24 10:40 - 11:09	262.39	130.32	8.34	9.42
Expanded Uncertainty as Percentage of Measured Concentration		9%	46%	22%	15%
Measured Concentration	16/02/24 11:10 - 11:39	363.66	52.88	11.83	6.92
Expanded Uncertainty as Percentage of Measured Concentration		7%	8%	3%	5%

Combined Standard Uncertainty  $u_c = \sqrt{u_{lof}^2 + u_{ds}^2 + u_t^2 + u_{loss}^2 + u_i^2 + u_v^2 + u_{sg}^2}$

Expanded uncertainty (at 95% confidence)  $U_{Exp} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be >100%

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Particulates, HF & HCl Uncertainty – (Light Medical Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
TPM / HCL & HF 1								
Particulates	168.00	26.10	194.10	0.10	0.50	0.0500	0.25	0.25
Hydrogen Chloride	...	161.70	161.70	...	21.02	...	10.51	10.51
Hydrogen Fluoride	...	0.91	0.91	...	0.12	...	0.0590	0.0590
...	...	...	...	...	...	...	...	...

TPM / HCL & HF 1			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	1.12	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.01	...	...	...	...
Meter Temperature (T <sub>m</sub> )	307.92	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	35.81	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.31	mmHg	up <sub>b</sub>	3.8	mmHg
ΔH + ps (p <sub>m</sub> )	101.85	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	16.53	% by volume	uO <sub>2,m</sub> = σ/√n	0.53	% by volume
Moisture Content (H <sub>2</sub> O)	4.66	% by volume	uH <sub>2</sub> O	0.19	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub>, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

TPM / HCL & HF 1:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up<sub>b</sub>) & measured temperature of dry gas uncertainty component (uT<sub>m, dry</sub>)

TPM / HCL & HF 1:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.898$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.90	0.90	0.0000864	0.0000216
up <sub>b</sub>	0.90	0.89	0.00118	0.00441
uT <sub>m</sub>	0.90	0.89	0.00292	0.00437
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00526$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

TPM / HCL & HF 1:

$$V_{std} = V_{measured} \times f_s = 1.005$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
Effect of uV <sub>std</sub>	1.01	1.00	1.12	0.00588
Effect of uV <sub>m</sub>	1.01	1.00	0.90	0.000898

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00663$$

Uncertainty of Oxygen Correction Factor (%):-

TPM / HCL & HF 1:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 4.10$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.17$$

$$uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 4.12\%$$

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	TPM / HCL & HF 1:			uM mg/Nm <sup>3</sup>
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	
Particulates	792.84	790.76	4.08	1.04
Hydrogen Chloride	702.50	616.75	4.08	42.88
Hydrogen Fluoride	3.95	3.46	4.08	0.24
Ammonia	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	TPM / HCL & HF 1:
	uL mg/Nm <sup>3</sup>
Particulates	9.14
Hydrogen Chloride	7.62
Hydrogen Fluoride	0.0428
Ammonia	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	TPM / HCL & HF 1:			uVstp mg/Nm <sup>3</sup>
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	
Particulates	797.06	786.61	788.04	5.23
Hydrogen Chloride	664.01	655.30	656.49	4.35
Hydrogen Fluoride	3.73	3.68	3.69	0.0245
Ammonia	...	...	...	...

Measurement Uncertainty of Determinand (excluding correction for oxygen)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	TPM / HCL & HF 1:				Uncertainty as Percentage of ELV
	Measurement Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration	
Particulates	10.58	21.17	791.80	2.67	587.92
Hydrogen Chloride	43.76	87.53	659.63	13.27	
Hydrogen Fluoride	0.25	0.49	3.71	13.27	
Ammonia	...	...	...	...	

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	TPM / HCL & HF 1:		
	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> )
Particulates	2.67	4.12	4.91
Hydrogen Chloride	13.27	4.12	13.89
Hydrogen Fluoride	13.27	4.12	13.89
Ammonia	...	...	...

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Sulphur Dioxide Uncertainty - (Light Medical Waste)**

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert ( % ) K=2	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
Sulphur Dioxide 1								
...	...	...	...	...	...	...	...	...
Sulphur Dioxide	...	9.95	9.95	...	1.29	...	0.65	0.65
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...
...	...	...	...	...	...	...	...	...

Sulphur Dioxide 1			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	0.96	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.01	...	...	...	...
Meter Temperature (T <sub>m</sub> )	310.00	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	25.00	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.31	mmHg	up <sub>b</sub>	3.8	mmHg
ΔH + ps (p <sub>m</sub> )	101.74	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	17.19	% by volume	uO <sub>2,m</sub> = σ/√n	0.66	% by volume
Moisture Content (H <sub>2</sub> O)	4.97	% by volume	uH <sub>2</sub> O	0.21	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub> where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

Sulphur Dioxide 1:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up<sub>b</sub>) & measured temperature of dry gas uncertainty component (uT<sub>m Dry</sub>)

Sulphur Dioxide 1:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.891$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.89	0.89	0.0000858	0.0000215
up <sub>b</sub>	0.90	0.89	0.00117	0.00438
uT <sub>m</sub>	0.90	0.89	0.00287	0.00431
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{u(\Delta H)}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00515$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

Sulphur Dioxide 1:

$$V_{std} = V_{measured} \times f_s = 0.856$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
Effect of uV <sub>std</sub>	0.86	0.85	0.96	0.00495
Effect of uV <sub>m</sub>	0.86	0.86	0.89	0.000891

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00482$$

Uncertainty of Oxygen Correction Factor (%):-

Sulphur Dioxide 1:

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 4.82$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.23$$

$$uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 4.85\%$$

**Environmental Compliance Limited**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)**

Determinand	Sulphur Dioxide 1:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
...	...	...	...	...
Sulphur Dioxide	59.66	52.37	5.63	3.64
...	...	...	...	...

**Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)**

Determinand	Sulphur Dioxide 1:
	uL mg/Nm <sup>3</sup>
...	...
Sulphur Dioxide	0.65
...	...

**Uncertainty in final measurement @ Reference Conditions due to uVstp**

Determinand	Sulphur Dioxide 1:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
...	...	...	...	...
Sulphur Dioxide	56.33	55.70	65.45	0.32
...	...	...	...	...

**Combined Uncertainty excluding oxygen contribution**

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	Sulphur Dioxide 1:			
	Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
...	...	...	...	...
Sulphur Dioxide	3.71	7.42	56.01	13.25
...	...	...	...	...

**Combined Uncertainty including oxygen contribution**

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (Ucombined)
...	...	...	...
Sulphur Dioxide	13.25	4.85	14.11
...	...	...	...

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Heavy Metals Uncertainty - (Light Medical Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{\text{phase}}(\text{mg/m}^3) = \frac{u_{\text{method}} \times \text{Mass}_{\text{pg}}}{200000} \quad u_{\text{mass}} = \sqrt{\sum (u_{\text{particulate}})^2 + (u_{\text{vapour}})^2}$$

Metal	Particulate mg	Vapour mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Standard Uncertainty of Measured	
			Particulate Phase	Vapour Phase	Particulate Phase mg/m <sup>3</sup>	Vapour Phase mg/m <sup>3</sup>	Symbol	mg/m <sup>3</sup>
Antimony	64.800	11.795	15	16	0.00486	0.000944	uMSb	0.00495
Arsenic	1.200	0.153	11	12	0.0000660	9.198E-06	uMAs	0.0000666
Cadmium	1.600	0.102	12	10	0.0000960	5.110E-06	uMCd	0.0000961
Chromium	10.500	0.304	12	10	0.000630	0.0000152	uMCr	0.000630
Cobalt	0.700	0.102	12	10	0.0000420	5.110E-06	uMCo	0.0000423
Copper	312.700	1.313	12	10	0.0188	0.0000657	uMCu	0.0188
Lead	26.700	1.917	13	16	0.00174	0.000153	uMPb	0.00174
Manganese	21.600	0.606	16	10	0.00173	0.0000303	uMMn	0.00173
Mercury	0.173	0.256	10	12	8.650E-06	0.0000153	uMHg	0.0000176
Nickel	22.800	0.624	12	9	0.00137	0.0000281	uMNI	0.00137
Thallium	0.400	0.102	14	14	0.0000280	7.154E-06	uMTI	0.0000289
Vanadium	0.800	0.0847	12	9	0.0000480	3.812E-06	uMV	0.0000482

			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	2.427	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.007	...	...	...	...
Meter Temperature (T <sub>m</sub> )	314.13	K	uT <sub>m</sub>	1.5	K
Average Differential Pressure (ΔH)	39.37	mmH <sub>2</sub> O	uDH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.31	mmHg	uP <sub>s</sub>	3.8	mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	101.89	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	16.65	% by volume	uO <sub>2,m</sub> = σ/√n	0.38	% by volume
Moisture Content (H <sub>2</sub> O)	4.42	% by volume	uH <sub>2</sub> O	0.13	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP<sub>s</sub>) & measured

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{T_m}}{T_m} \times Y_d = 0.880$$

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.880	0.880	0.0000847	0.0000212
uP <sub>s</sub>	0.885	0.876	0.00115	0.00432
uT <sub>m</sub>	0.885	0.876	0.00280	0.00420
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00497$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

$$V_{std} = V_{measured} \times f_s = 2.137$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty m <sup>3</sup>
Effect of uV <sub>std</sub>	2.149	2.125	2.427	0.0121
Effect of uV <sub>m</sub>	2.138	2.136	0.880	0.000880

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0293$$

Uncertainty of oxygen correction factor (uf<sub>o2</sub>)

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 2.33$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.18$$

$$\therefore uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 7.66\%$$

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Metal	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
Antimony	0.0889	0.0781	1.091	0.00540
Arsenic	0.00155	0.00140	1.091	0.0000727
Cadmium	0.00196	0.00175	1.091	0.000105
Chromium	0.0125	0.0111	1.091	0.000687
Cobalt	0.000921	0.000829	1.091	0.0000461
Copper	0.363	0.322	1.091	0.0205
Lead	0.0331	0.0293	1.091	0.00190
Manganese	0.0261	0.0223	1.091	0.00189
Mercury	0.000487	0.000448	1.091	0.0000192
Nickel	0.0270	0.0241	1.091	0.00149
Thallium	0.000579	0.000516	1.091	0.0000315
Vanadium	0.00102	0.000912	1.091	0.0000525

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system

Metal	uL mg/Nm <sup>3</sup>
Antimony	0.000965
Arsenic	0.0000170
Cadmium	0.0000214
Chromium	0.000136
Cobalt	0.0000101
Copper	0.00395
Lead	0.000360
Manganese	0.000280
Mercury	5.397E-06
Nickel	0.000295
Thallium	6.325E-06
Vanadium	0.0000111

Uncertainty in final measurement @ Reference Conditions due to uVstp

Metal	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
Antimony	0.0847	0.0824	0.0391	0.00114
Arsenic	0.00150	0.00146	0.000691	0.0000202
Cadmium	0.00188	0.00183	0.000869	0.0000254
Chromium	0.0119	0.0116	0.00552	0.000161
Cobalt	0.000887	0.000863	0.000410	0.0000120
Copper	0.347	0.338	0.160	0.00469
Lead	0.0316	0.0308	0.0146	0.000428
Manganese	0.0246	0.0239	0.0113	0.000332
Mercury	0.000474	0.000461	0.000219	6.402E-06
Nickel	0.0259	0.0252	0.0120	0.000350
Thallium	0.000555	0.000540	0.000256	7.503E-06
Vanadium	0.000978	0.000952	0.000452	0.0000132

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Metal	Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
Antimony	0.00560	0.0112	0.0835	13.414
Arsenic	0.0000773	0.000155	0.00148	10.480
Cadmium	0.000110	0.000220	0.00186	11.850
Chromium	0.000719	0.00144	0.0118	12.204
Cobalt	0.0000487	0.0000975	0.000875	11.140
Copper	0.0214	0.0427	0.342	12.475
Lead	0.00198	0.00396	0.0312	12.693
Manganese	0.00193	0.00387	0.0242	15.973
Mercury	0.0000209	0.0000419	0.000467	8.963
Nickel	0.00156	0.00312	0.0255	12.220
Thallium	0.0000330	0.0000660	0.000548	12.054
Vanadium	0.0000553	0.000111	0.000965	11.460

$$u_{combined} = \sqrt{\sum (uf_{v_2})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Metal	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> )	New Combined Uncertainty mg/Nm <sup>3</sup>
Antimony	13.414	7.660	15.447	0.006453
Arsenic	10.480	7.660	12.981	0.000096
Cadmium	11.850	7.660	14.110	0.000131
Chromium	12.204	7.660	14.409	0.000849
Cobalt	11.140	7.660	13.520	0.000059
Copper	12.475	7.660	14.639	0.025070
Lead	12.693	7.660	14.825	0.002314
Manganese	15.973	7.660	17.714	0.002145
Mercury	8.963	7.660	11.790	0.000028
Nickel	12.220	7.660	14.422	0.001842
Thallium	12.054	7.660	14.282	0.000039
Vanadium	11.460	7.660	13.784	0.000067

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties ( in mg/m3 ) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.



Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Particulates, HF & HCl Uncertainty – (Medium Bin Medical Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert ( % ) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
TPM / HCL & HF 2								
Particulates	102.00	14.10	116.10	0.10	0.50	0.0500	0.25	0.25
Hydrogen Chloride	...	84.05	84.05	...	10.93	...	5.46	5.46
Hydrogen Fluoride	...	1.57	1.57	...	0.20	...	0.10	0.10
...	...	...	...	...	...	...	...	...

TPM / HCL & HF 2			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	1.12	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.01	...	...	...	...
Meter Temperature (T <sub>m</sub> )	307.75	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	36.28	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	762.06	mmHg	up <sub>b</sub>	3.8	mmHg
ΔH + ps (p <sub>m</sub> )	101.96	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	16.26	% by volume	uO <sub>2,m</sub> = σ/√n	0.46	% by volume
Moisture Content (H <sub>2</sub> O)	4.39	% by volume	uH <sub>2</sub> O	0.18	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub>, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

TPM / HCL & HF 2:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up<sub>b</sub>) & measured temperature of dry gas uncertainty component (uT<sub>m, dry</sub>)

TPM / HCL & HF 2:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.899$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.90	0.90	0.000865	0.000216
up <sub>b</sub>	0.90	0.89	0.00118	0.00441
uT <sub>m</sub>	0.90	0.89	0.00292	0.00438
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{u\Delta H}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100(100-H_2O)}\right)^2} = 0.00527$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

TPM / HCL & HF 2:

$$V_{std} = V_{measured} \times f_s = 1.010$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
Effect of uV <sub>std</sub>	1.02	1.00	1.12	0.00592
Effect of uV <sub>m</sub>	1.01	1.01	0.90	0.000899

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00670$$

Uncertainty of Oxygen Correction Factor (%):-

TPM / HCL & HF 2:

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 3.85$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times \text{Uncertainty of } O_2 \text{ Measurement}} = 0.15$$

$$uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 3.88\%$$

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	TPM / HCL & HF 2:			uM mg/Nm <sup>3</sup>
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	
Particulates	443.88	441.94	3.81	0.97
Hydrogen Chloride	341.48	299.80	3.81	20.84
Hydrogen Fluoride	6.40	5.62	3.81	0.39
Ammonia	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	TPM / HCL & HF 2:
	uL mg/Nm <sup>3</sup>
Particulates	5.11
Hydrogen Chloride	3.70
Hydrogen Fluoride	0.0694
Ammonia	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	TPM / HCL & HF 2:			uVstp mg/Nm <sup>3</sup>
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	
Particulates	445.87	439.99	438.47	2.94
Hydrogen Chloride	322.78	318.53	317.43	2.13
Hydrogen Fluoride	6.05	5.97	5.95	0.0398
Ammonia	...	...	...	...

Measurement Uncertainty of Determinand (excluding correction for oxygen)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	TPM / HCL & HF 2:				Uncertainty as Percentage of ELV
	Measurement Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration	
Particulates	5.98	11.95	442.91	2.70	332.07
Hydrogen Chloride	21.27	42.55	320.64	13.27	
Hydrogen Fluoride	0.40	0.80	6.01	13.27	
Ammonia	...	...	...	...	

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	TPM / HCL & HF 2:		
	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> )
Particulates	2.70	3.88	4.73
Hydrogen Chloride	13.27	3.88	13.83
Hydrogen Fluoride	13.27	3.88	13.83
Ammonia	...	...	...

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Sulphur Dioxide Uncertainty - (Medium Bin Medical Waste)**

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert ( % ) K=2 Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
Sulphur Dioxide 2								
...	...	...	...	...	...	...	...	...
Sulphur Dioxide	...	6.86	6.86	...	0.89	...	0.45	0.45
...	...	...	...	...	...	...	...	...

Sulphur Dioxide 2			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	0.92	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.01	...	...	...	...
Meter Temperature (T <sub>m</sub> )	310.17	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	25.00	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	762.06	mmHg	u <sub>p<sub>b</sub></sub>	3.8	mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	101.84	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	16.13	% by volume	uO <sub>2,m</sub> = σ/√n	0.30	% by volume
Moisture Content (H <sub>2</sub> O)	4.68	% by volume	uH <sub>2</sub> O	0.22	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub>, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

Sulphur Dioxide 2:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (u<sub>p<sub>s</sub></sub>) & measured temperature of dry gas uncertainty component (uT<sub>m dry</sub>)

Sulphur Dioxide 2:

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.891$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.89	0.89	0.0000858	0.0000214
u <sub>p<sub>b</sub></sub>	0.90	0.89	0.00117	0.00438
uT <sub>m</sub>	0.90	0.89	0.00287	0.00431
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00515$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

Sulphur Dioxide 2:

$$V_{std} = V_{measured} \times f_s = 0.817$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
Effect of uV <sub>std</sub>	0.82	0.81	0.92	0.00472
Effect of uV <sub>m</sub>	0.82	0.82	0.89	0.000891

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00439$$

Uncertainty of Oxygen Correction Factor (%):-

Sulphur Dioxide 2:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 3.75$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.14$$

$$uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 3.77\%$$

**Environmental Compliance Limited**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	Sulphur Dioxide 2:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
...	...	...	...	...
Sulphur Dioxide	33.56	29.47	4.59	2.05
...	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	Sulphur Dioxide 2:
	uL mg/Nm <sup>3</sup>
...	...
Sulphur Dioxide	0.36
...	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	Sulphur Dioxide 2:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
...	...	...	...	...
Sulphur Dioxide	31.68	31.35	38.60	0.17
...	...	...	...	...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	Sulphur Dioxide 2:			
	Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
...	...	...	...	...
Sulphur Dioxide	2.09	4.17	31.51	13.25
...	...	...	...	...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (Ucombined)
...	...	...	...
Sulphur Dioxide	13.25	3.77	13.77
...	...	...	...

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Heavy Metals Uncertainty - (Medium Bin Medical Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{phase(mg/m^3)} = \frac{u_{method} \times Mass_{pg}}{200000} \quad u_{mass} = \sqrt{\sum (u_{particulate})^2 + (u_{vapour})^2}$$

Metal	Particulate mg	Vapour mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Standard Uncertainty of Measured	
			Particulate Phase	Vapour Phase	Particulate Phase mg/m <sup>3</sup>	Vapour Phase mg/m <sup>3</sup>	Symbol	mg/m <sup>3</sup>
Antimony	46.000	1.495	15	16	0.00345	0.000120	uMSb	0.00345
Arsenic	0.900	0.824	11	12	0.0000495	0.0000494	uMAs	0.0000700
Cadmium	1.200	0.191	12	10	0.0000720	9.570E-06	uMCd	0.0000726
Chromium	99.300	0.805	12	10	0.00596	0.0000403	uMCr	0.00596
Cobalt	1.400	0.191	12	10	0.0000840	9.570E-06	uMCo	0.0000845
Copper	55.900	2.178	12	10	0.00335	0.000109	uMCu	0.00336
Lead	10.900	1.879	13	16	0.000709	0.000150	uMPb	0.000724
Manganese	23.100	0.958	16	10	0.00185	0.0000479	uMMn	0.00185
Mercury	0.222	0.479	10	12	0.0000111	0.0000287	uMHg	0.0000308
Nickel	38.400	0.896	12	9	0.00230	0.0000403	uMNI	0.00230
Thallium	0.400	0.191	14	14	0.0000280	0.0000134	uMTl	0.0000310
Vanadium	2.900	0.172	12	9	0.000174	7.758E-06	uMV	0.000174

			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	2.466	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.007	...	...	...	...
Meter Temperature (T <sub>m</sub> )	313.38	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	41.07	mmH <sub>2</sub> O	uDH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	762.06	mmHg	uP <sub>s</sub>	3.8	mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	102.00	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	17.35	% by volume	uO <sub>2,m</sub> = σ/√n	0.17	% by volume
Moisture Content (H <sub>2</sub> O)	4.29	% by volume	uH <sub>2</sub> O	0.13	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP<sub>s</sub>) & measured

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.883$$

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.883	0.883	0.0000849	0.0000212
uP <sub>s</sub>	0.888	0.879	0.00115	0.00433
uT <sub>m</sub>	0.888	0.879	0.00282	0.00423
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00500$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

$$V_{std} = V_{measured} \times f_s = 2.179$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty m <sup>3</sup>
Effect of uV <sub>std</sub>	2.191	2.166	2.466	0.0123
Effect of uV <sub>m</sub>	2.180	2.178	0.883	0.000883

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0304$$

Uncertainty of oxygen correction factor (uf<sub>o2</sub>)

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 2.79$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.26$$

$$\therefore uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 9.17\%$$

**Environmental Compliance Limited**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)**

Metal	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
Antimony	0.0652	0.0564	1.280	0.00442
Arsenic	0.00230	0.00212	1.280	0.0000895
Cadmium	0.00187	0.00169	1.280	0.0000929
Chromium	0.136	0.120	1.280	0.00762
Cobalt	0.00214	0.00193	1.280	0.000108
Copper	0.0786	0.0700	1.280	0.00429
Lead	0.0173	0.0154	1.280	0.000927
Manganese	0.0332	0.0284	1.280	0.00237
Mercury	0.000936	0.000857	1.280	0.0000394
Nickel	0.0532	0.0473	1.280	0.00295
Thallium	0.000797	0.000717	1.280	0.0000397
Vanadium	0.00415	0.00371	1.280	0.000223

**Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system**

Metal	uL mg/Nm <sup>3</sup>
Antimony	0.000702
Arsenic	0.0000255
Cadmium	0.0000206
Chromium	0.00148
Cobalt	0.0000235
Copper	0.000858
Lead	0.000189
Manganese	0.000356
Mercury	0.0000104
Nickel	0.000581
Thallium	8.739E-06
Vanadium	0.0000454

**Uncertainty in final measurement @ Reference Conditions due to uVstp**

Metal	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
Antimony	0.0616	0.0599	0.0279	0.000849
Arsenic	0.00224	0.00218	0.00101	0.0000308
Cadmium	0.00181	0.00176	0.000817	0.0000249
Chromium	0.130	0.126	0.0588	0.00179
Cobalt	0.00207	0.00201	0.000935	0.0000285
Copper	0.0754	0.0733	0.0341	0.00104
Lead	0.0166	0.0161	0.00751	0.000229
Manganese	0.0312	0.0304	0.0141	0.000430
Mercury	0.000909	0.000884	0.000412	0.0000125
Nickel	0.0510	0.0496	0.0231	0.000703
Thallium	0.000768	0.000746	0.000347	0.0000106
Vanadium	0.00399	0.00388	0.00180	0.0000550

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Metal	Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
Antimony	0.00455	0.00911	0.0608	14.982
Arsenic	0.0000981	0.000196	0.00221	8.889
Cadmium	0.0000984	0.000197	0.00178	11.052
Chromium	0.00797	0.0159	0.128	12.444
Cobalt	0.000114	0.000229	0.00204	11.227
Copper	0.00450	0.00900	0.0743	12.112
Lead	0.000973	0.00195	0.0164	11.901
Manganese	0.00243	0.00486	0.0308	15.790
Mercury	0.0000426	0.0000852	0.000896	9.507
Nickel	0.00309	0.00617	0.0503	12.276
Thallium	0.0000420	0.0000841	0.000757	11.106
Vanadium	0.000234	0.000468	0.00393	11.904

$$u_{combined} = \sqrt{\sum (u_{f_{o_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Metal	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> )	New Combined Uncertainty mg/Nm <sup>3</sup>
Antimony	14.982	9.170	17.565	0.005338
Arsenic	8.889	9.170	12.771	0.000141
Cadmium	11.052	9.170	14.361	0.000128
Chromium	12.444	9.170	15.458	0.009901
Cobalt	11.227	9.170	14.496	0.000148
Copper	12.112	9.170	15.191	0.005645
Lead	11.901	9.170	15.024	0.001228
Manganese	15.790	9.170	18.259	0.002811
Mercury	9.507	9.170	13.209	0.000059
Nickel	12.276	9.170	15.323	0.003853
Thallium	11.106	9.170	14.402	0.000054
Vanadium	11.904	9.170	15.026	0.000295

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m3) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Dioxins & Furans Uncertainty - (Medium Bin Medical Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

Dioxin	Recovered Mass ng	LOD ng	LAB Method %age	Uncert ( % ) K=2 as Mass (ng)	Standard Uncertainty Symbol	ng
2,3,7,8 - TCDD	6.390	0.000140	30	1.917	u2,3,7,8 - TCDD	0.959
1,2,3,7,8 - PCDD	10.000	0.000190	30	3.000	u1,2,3,7,8 - PCDD	1.500
1,2,3,4,7,8 - HxCDD	2.640	0.000320	30	0.792	u1,2,3,4,7,8 - HxCDD	0.396
1,2,3,6,7,8 - HxCDD	2.850	0.000350	30	0.855	u1,2,3,6,7,8 - HxCDD	0.428
1,2,3,7,8,9 - HxCDD	4.050	0.000380	30	1.215	u1,2,3,7,8,9 - HxCDD	0.608
1,2,3,4,6,7,8 - HpCDD	4.720	0.000380	30	1.416	u1,2,3,4,6,7,8 - HpCDD	0.708
OCDD	1.730	0.00135	30	0.519	uOCDD	0.260
2,3,7,8 - TCDF	40.400	0.000270	30	12.120	u2,3,7,8 - TCDF	6.060
1,2,3,7,8 - PCDF	38.000	0.000260	30	11.400	u1,2,3,7,8 - PCDF	5.700
2,3,4,7,8 - PCDF	35.700	0.000740	30	10.710	u2,3,4,7,8 - PCDF	5.355
1,2,3,4,7,8 - HxCDF	18.000	0.000190	30	5.400	u1,2,3,4,7,8 - HxCDF	2.700
1,2,3,6,7,8 - HxCDF	19.000	0.000160	30	5.700	u1,2,3,6,7,8 - HxCDF	2.850
2,3,4,6,7,8 - HxCDF	10.900	0.000160	30	3.270	u2,3,4,6,7,8 - HxCDF	1.635
1,2,3,7,8,9 - HxCDF	0.879	0.000180	30	0.264	u1,2,3,7,8,9 - HxCDF	0.132
1,2,3,4,6,7,8 - HpCDF	13.600	0.000450	30	4.080	u1,2,3,4,6,7,8 - HpCDF	2.040
1,2,3,4,7,8,9 - HpCDF	1.960	0.000650	30	0.588	u1,2,3,4,7,8,9 - HpCDF	0.294
OCDF	1.710	0.000560	30	0.513	uOCDF	0.257

Measured Values			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	6.907	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.007	...		...	...
Meter Temperature (T <sub>m</sub> )	312.200	K	uT <sub>m</sub>	1.5	K
Average Differential Pressure (ΔH)	53.690	mmH <sub>2</sub> O	uDH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.310	mmHg	uP <sub>b</sub>	3.8	mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	102.026	kPa		...	...
Oxygen content (O <sub>2,m</sub> )	15.194	% by volume	uO <sub>2,m</sub> = σ/√n	0.29	% by volume
Moisture Content (H <sub>2</sub> O)	3.260	% by volume	uH <sub>2</sub> O	0.09	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP<sub>s</sub>) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{T_m}}{13.6} \times Y_d = 0.887$$

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.887	0.887	0.0000852	0.0000213
uP <sub>b</sub>	0.891	0.883	0.00116	0.00435
uT <sub>m</sub>	0.891	0.883	0.00284	0.00426
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00506$$

Uncertainty in volume @ reference conditions due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

$$V_{std} = V_{measured} \times f_s = 6.127$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
	m <sup>3</sup>	m <sup>3</sup>		m <sup>3</sup>
Effect of uV <sub>std</sub>	6.161	6.092	6.907	0.0349
Effect of uV <sub>m</sub>	6.127	6.126	0.887	0.000887

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.2413$$

Uncertainty of oxygen correction factor (ufO<sub>2</sub>)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 3.100 \quad uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} =$$

$$\therefore uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 3.19\%$$

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final dioxin measurement @ reference conditions due to mass uncertainty component (uM)

Dioxin	Maximum ng/Nm <sup>3</sup>	Minimum ng/Nm <sup>3</sup>	Sensitivity	uM ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	3.719	2.749	0.506	0.485
1,2,3,7,8 - PCDD	5.820	4.301	0.506	0.759
1,2,3,4,7,8 - HxCDD	1.536	1.136	0.506	0.200
1,2,3,6,7,8 - HxCDD	1.659	1.226	0.506	0.216
1,2,3,7,8,9 - HxCDD	2.357	1.742	0.506	0.307
1,2,3,4,6,7,8 - HpCDD	2.747	2.030	0.506	0.358
OCDD	1.007	0.744	0.506	0.131
2,3,7,8 - TCDF	23.511	17.378	0.506	3.067
1,2,3,7,8 - PCDF	22.115	16.346	0.506	2.885
2,3,4,7,8 - PCDF	20.776	15.356	0.506	2.710
1,2,3,4,7,8 - HxCDF	10.475	7.743	0.506	1.366
1,2,3,6,7,8 - HxCDF	11.057	8.173	0.506	1.442
2,3,4,6,7,8 - HxCDF	6.343	4.689	0.506	0.827
1,2,3,7,8,9 - HxCDF	0.512	0.378	0.506	0.0667
1,2,3,4,6,7,8 - HpCDF	7.915	5.850	0.506	1.032
1,2,3,4,7,8,9 - HpCDF	1.141	0.843	0.506	0.149
OCDF	0.995	0.736	0.506	0.130

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss in the sample system (uL)

Dioxin	uL ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	0.0373
1,2,3,7,8 - PCDD	0.0584
1,2,3,4,7,8 - HxCDD	0.0154
1,2,3,6,7,8 - HxCDD	0.0167
1,2,3,7,8,9 - HxCDD	0.0237
1,2,3,4,6,7,8 - HpCDD	0.0276
OCDD	0.0101
2,3,7,8 - TCDF	0.236
1,2,3,7,8 - PCDF	0.222
2,3,4,7,8 - PCDF	0.209
1,2,3,4,7,8 - HxCDF	0.105
1,2,3,6,7,8 - HxCDF	0.111
2,3,4,6,7,8 - HxCDF	0.0637
1,2,3,7,8,9 - HxCDF	0.00514
1,2,3,4,6,7,8 - HpCDF	0.0795
1,2,3,4,7,8,9 - HpCDF	0.0115
OCDF	0.00999

Uncertainty in final measurement @ Reference Conditions due to uVstp

Dioxin	Maximum ng/Nm <sup>3</sup>	Minimum ng/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
2,3,7,8 - TCDD	3.366	3.111	0.529	0.128
1,2,3,7,8 - PCDD	5.268	4.869	0.827	0.200
1,2,3,4,7,8 - HxCDD	1.391	1.285	0.218	0.0527
1,2,3,6,7,8 - HxCDD	1.501	1.388	0.236	0.0569
1,2,3,7,8,9 - HxCDD	2.134	1.972	0.335	0.0809
1,2,3,4,6,7,8 - HpCDD	2.487	2.298	0.390	0.0942
OCDD	0.911	0.842	0.143	0.0345
2,3,7,8 - TCDF	21.283	19.670	3.342	0.807
1,2,3,7,8 - PCDF	20.019	18.501	3.144	0.759
2,3,4,7,8 - PCDF	18.807	17.381	2.953	0.713
1,2,3,4,7,8 - HxCDF	9.483	8.764	1.489	0.359
1,2,3,6,7,8 - HxCDF	10.009	9.251	1.572	0.379
2,3,4,6,7,8 - HxCDF	5.742	5.307	0.902	0.218
1,2,3,7,8,9 - HxCDF	0.463	0.428	0.0727	0.0176
1,2,3,4,6,7,8 - HpCDF	7.165	6.622	1.125	0.272
1,2,3,4,7,8,9 - HpCDF	1.033	0.954	0.162	0.0391
OCDF	0.901	0.833	0.141	0.0341

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Dioxin	Combined Uncertainty ng/Nm <sup>3</sup>	Expanded Uncertainty ng/Nm <sup>3</sup>	Measured Concentration ng/Nm <sup>3</sup>	% of Measured Concentration
2,3,7,8 - TCDD	0.503	1.006	3.234	31.106
1,2,3,7,8 - PCDD	0.787	1.574	5.061	31.106
1,2,3,4,7,8 - HxCDD	0.208	0.416	1.336	31.106
1,2,3,6,7,8 - HxCDD	0.224	0.449	1.442	31.106
1,2,3,7,8,9 - HxCDD	0.319	0.638	2.050	31.106
1,2,3,4,6,7,8 - HpCDD	0.371	0.743	2.389	31.106
OCDD	0.136	0.272	0.875	31.106
2,3,7,8 - TCDF	3.180	6.360	20.445	31.106
1,2,3,7,8 - PCDF	2.991	5.982	19.230	31.106
2,3,4,7,8 - PCDF	2.810	5.620	18.066	31.106
1,2,3,4,7,8 - HxCDF	1.417	2.833	9.109	31.106
1,2,3,6,7,8 - HxCDF	1.495	2.991	9.615	31.106
2,3,4,6,7,8 - HxCDF	0.858	1.716	5.516	31.106
1,2,3,7,8,9 - HxCDF	0.0692	0.138	0.445	31.106
1,2,3,4,6,7,8 - HpCDF	1.070	2.141	6.882	31.106
1,2,3,4,7,8,9 - HpCDF	0.154	0.309	0.992	31.106
OCDF	0.135	0.269	0.865	31.106

Total (ng/Nm<sup>3</sup>) 107.551 10.9

$$u_{combined} = \sqrt{\sum (u_{f_{D_i}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Dioxin	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr <sup>2</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>2</sup> Factor (Ucombined)	New Combined Uncertainty ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	31.106	3.190	31.269	0.504
1,2,3,7,8 - PCDD	31.106	3.190	31.269	0.788
1,2,3,4,7,8 - HxCDD	31.106	3.190	31.269	0.208
1,2,3,6,7,8 - HxCDD	31.106	3.190	31.269	0.225
1,2,3,7,8,9 - HxCDD	31.106	3.190	31.269	0.319
1,2,3,4,6,7,8 - HpCDD	31.106	3.190	31.269	0.372
OCDD	31.106	3.190	31.269	0.136
2,3,7,8 - TCDF	31.106	3.190	31.269	3.165
1,2,3,7,8 - PCDF	31.106	3.190	31.269	2.996
2,3,4,7,8 - PCDF	31.106	3.190	31.269	2.814
1,2,3,4,7,8 - HxCDF	31.106	3.190	31.269	1.419
1,2,3,6,7,8 - HxCDF	31.106	3.190	31.269	1.498
2,3,4,6,7,8 - HxCDF	31.106	3.190	31.269	0.859
1,2,3,7,8,9 - HxCDF	31.106	3.190	31.269	0.0693
1,2,3,4,6,7,8 - HpCDF	31.106	3.190	31.269	1.072
1,2,3,4,7,8,9 - HpCDF	31.106	3.190	31.269	0.155
OCDF	31.106	3.190	31.269	0.135



Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty - Adjusted for TEQ / TEF												
Dioxin	TEQ ng/m <sup>3</sup>	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>	WHO Humans & Mammals (TEF)	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>	WHO Fish (TEF)	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>	WHO Birds (TEF)	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	1	1.008	3.234	1	1.008	3.234	1	1.008	3.234	1	1.008	3.234
1,2,3,7,8 - PCDD	0.5	0.788	2.530	1	1.577	5.061	1	1.577	5.061	1	1.577	5.061
1,2,3,4,7,8 - HxCDD	0.1	0.0416	0.134	0.1	0.0416	0.134	0.5	0.208	0.668	0.05	0.0208	0.0668
1,2,3,6,7,8 - HxCDD	0.1	0.0449	0.144	0.1	0.0449	0.144	0.01	0.00449	0.0144	0.01	0.00449	0.0144
1,2,3,7,8,9 - HxCDD	0.1	0.0639	0.205	0.1	0.0639	0.205	0.01	0.00639	0.0205	0.1	0.0639	0.205
1,2,3,4,6,7,8 - HpCDD	0.001	0.00744	0.0239	0.01	0.00744	0.0239	0.001	0.000744	0.00239	0.001	0.000744	0.00239
OCDD	0.001	0.000273	0.000875	0.0001	0.0000273	0.0000875	...	...	...	...	...	...
2,3,7,8 - TCDF	0.1	0.637	2.044	0.1	0.637	2.044	0.05	0.318	1.022	1	6.370	20.445
1,2,3,7,8 - PCDF	0.05	0.300	0.962	0.05	0.300	0.962	0.05	0.300	0.962	0.1	0.599	1.923
2,3,4,7,8 - PCDF	0.5	2.814	9.033	0.5	2.814	9.033	0.5	2.814	9.033	1	5.629	18.066
1,2,3,4,7,8 - HxCDF	0.1	0.284	0.911	0.1	0.284	0.911	0.1	0.284	0.911	0.1	0.284	0.911
1,2,3,6,7,8 - HxCDF	0.1	0.300	0.962	0.1	0.300	0.962	0.1	0.300	0.962	0.1	0.300	0.962
2,3,4,6,7,8 - HxCDF	0.1	0.172	0.552	0.1	0.172	0.552	0.1	0.172	0.552	0.1	0.172	0.552
1,2,3,7,8,9 - HxCDF	0.1	0.0139	0.0445	0.1	0.0139	0.0445	0.1	0.0139	0.0445	0.1	0.0139	0.0445
1,2,3,4,6,7,8 - HpCDF	0.01	0.0214	0.0688	0.01	0.0214	0.0688	0.01	0.0214	0.0688	0.01	0.0214	0.0688
1,2,3,4,7,8,9 - HpCDF	0.01	0.00309	0.00992	0.01	0.00309	0.00992	0.01	0.00309	0.00992	0.01	0.00309	0.00992
OCDF	0.001	0.000270	0.000865	0.0001	0.0000270	0.0000865	0.0001	0.0000270	0.0000865	0.0001	0.0000270	0.0000865
TOTAL	...	3.203	20.859	...	3.482	23.387	...	3.443	22.564	...	8.736	51.564
% Uncertainty	...	...	15.358	...	...	14.889	...	...	15.261	...	...	16.9

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Particulates, HF & HCl Uncertainty – (Dead Animal Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
TPM / HCL & HF 3								
Particulates	40.00	6.20	46.20	0.10	0.50	0.0500	0.25	0.25
Hydrogen Chloride	...	8.28	8.28	...	1.08	...	0.54	0.54
Hydrogen Fluoride	...	3.31	3.31	...	0.43	...	0.22	0.22
...	...	...	...	...	...	...	...	...

TPM / HCL & HF 3			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	1.53	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.01	...	...	...	...
Meter Temperature (T <sub>m</sub> )	306.50	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	58.53	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.31	mmHg	u <sub>p<sub>b</sub></sub>	3.8	mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	102.07	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	18.42	% by volume	uO <sub>2,m</sub> = σ/√n	0.36	% by volume
Moisture Content (H <sub>2</sub> O)	11.54	% by volume	uH <sub>2</sub> O	0.32	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub> where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

TPM / HCL & HF 3:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (u<sub>p<sub>s</sub></sub>) & measured temperature of dry gas uncertainty component (uT<sub>m Dry</sub>)

TPM / HCL & HF 3:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.904$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.90	0.90	0.0000668	0.0000217
u <sub>p<sub>b</sub></sub>	0.91	0.90	0.00118	0.00443
uT <sub>m</sub>	0.91	0.90	0.00295	0.00442
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.00534$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

TPM / HCL & HF 3:

$$V_{std} = V_{measured} \times f_s = 1.380$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
Effect of uV <sub>std</sub>	1.39	1.37	1.53	0.00814
Effect of uV <sub>m</sub>	1.38	1.38	0.90	0.000904

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0125$$

Uncertainty of Oxygen Correction Factor (%):-

TPM / HCL & HF 3:

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 7.21$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times \text{Uncertainty of } O_2 \text{ Measurement}} = 0.52$$

$$uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 7.25\%$$

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	TPM / HCL & HF 3:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
Particulates	242.63	239.97	5.22	1.33
Hydrogen Chloride	46.08	40.45	5.22	2.81
Hydrogen Fluoride	18.40	16.16	5.22	1.12
Ammonia	...	...	...	...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	TPM / HCL & HF 3:
	uL mg/Nm <sup>3</sup>
Particulates	2.79
Hydrogen Chloride	0.50
Hydrogen Fluoride	0.20
Ammonia	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	TPM / HCL & HF 3:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
Particulates	243.50	239.14	174.92	2.18
Hydrogen Chloride	43.66	42.88	31.37	0.39
Hydrogen Fluoride	17.44	17.12	12.53	0.16
Ammonia	...	...	...	...

Measurement Uncertainty of Determinand (excluding correction for oxygen)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	TPM / HCL & HF 3:				Uncertainty as Percentage of ELV
	Measurement Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration	
Particulates	3.78	7.56	241.30	3.13	209.97
Hydrogen Chloride	2.88	5.77	43.27	13.33	
Hydrogen Fluoride	1.15	2.30	17.28	13.33	
Ammonia	...	...	...	...	

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	TPM / HCL & HF 3:		
	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> )
Particulates	3.13	7.25	7.90
Hydrogen Chloride	13.33	7.25	15.17
Hydrogen Fluoride	13.33	7.25	15.17
Ammonia	...	...	...

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Sulphur Dioxide Uncertainty - (Dead Animal Waste)**

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert ( % ) K=2	Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
Sulphur Dioxide 3									
...	...	...	...	...	...	...	...	...	...
Sulphur Dioxide	...	629.10	629.10	...	...	81.78	...	40.89	40.89
...	...	...	...	...	...	...	...	...	...

Sulphur Dioxide 3			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	0.88	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.01	...	...	...	...
Meter Temperature (T <sub>m</sub> )	308.83	k	uT <sub>m</sub>	1.5	k
Average Differential Pressure (ΔH)	25.00	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.31	mmHg	u <sub>p<sub>b</sub></sub>	3.8	mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	101.74	kPa	...	...	...
Oxygen content (O <sub>2,m</sub> )	6.71	% by volume	uO <sub>2,m</sub> = σ/√n	0.69	% by volume
Moisture Content (H <sub>2</sub> O)	13.29	% by volume	uH <sub>2</sub> O	0.39	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub>, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

Sulphur Dioxide 3:

$$f_{s, wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (u<sub>p<sub>b</sub></sub>) & measured temperature of dry gas uncertainty component (uT<sub>m, dry</sub>)

Sulphur Dioxide 3:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.894$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.89	0.89	0.0000862	0.0000215
u <sub>p<sub>b</sub></sub>	0.90	0.89	0.00117	0.00439
uT <sub>m</sub>	0.90	0.89	0.00290	0.00434
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00521$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

Sulphur Dioxide 3:

$$V_{std} = V_{measured} \times f_s = 0.786$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
Effect of uV <sub>std</sub>	0.79	0.78	0.88	0.00458
Effect of uV <sub>m</sub>	0.79	0.79	0.89	0.000894

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00410$$

Uncertainty of Oxygen Correction Factor (%):-

Sulphur Dioxide 3:

$$f_{O_2} = \frac{20.9\% - O_{2, ref}}{20.9\% - O_{2, measured}} = 1.26$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2, ref}}{(20.9\% - O_{2, measured})(20.9\% - O_{2, measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0160$$

$$uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 1.27\%$$

**Environmental Compliance Limited**

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

**Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)**

Determinand	Sulphur Dioxide 3:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
...	...	...	...	...
Sulphur Dioxide	1075.19	943.95	1.60	65.62
...	...	...	...	...

**Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)**

Determinand	Sulphur Dioxide 3:
	uL mg/Nm <sup>3</sup>
...	...
Sulphur Dioxide	11.66
...	...

**Uncertainty in final measurement @ Reference Conditions due to uVstp**

Determinand	Sulphur Dioxide 3:			
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
...	...	...	...	...
Sulphur Dioxide	1014.87	1004.33	1284.18	5.27
...	...	...	...	...

**Combined Uncertainty excluding oxygen contribution**

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	Sulphur Dioxide 3:			
	Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
...	...	...	...	...
Sulphur Dioxide	66.86	133.72	1009.57	13.24
...	...	...	...	...

**Combined Uncertainty including oxygen contribution**

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (Ucombined)
...	...	...	...
Sulphur Dioxide	13.24	1.27	13.31
...	...	...	...

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Heavy Metals Uncertainty - (Dead Animal Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

$$u_{\text{phase (mg/m}^3)} = \frac{u_{\text{method}} \times \text{Mass}_{\text{pg}}}{200000} \quad u_{\text{mass}} = \sqrt{\sum (u_{\text{particulate}})^2 + (u_{\text{vapour}})^2}$$

Metal	Particulate mg	Vapour mg	LAB Method Uncert ( % ) K=2		Standard Uncertainty		Combined Standard Uncertainty of Measured	
			Particulate Phase	Vapour Phase	Particulate Phase mg/m <sup>3</sup>	Vapour Phase mg/m <sup>3</sup>	Symbol	mg/m <sup>3</sup>
Antimony	7.000	0.208	15	16	0.000525	0.0000166	uMSb	0.000525
Arsenic	3.200	0.221	11	12	0.000176	0.0000133	uMAs	0.000177
Cadmium	1.100	0.148	12	10	0.0000660	7.380E-06	uMCd	0.0000664
Chromium	19.800	0.691	12	10	0.00119	0.0000346	uMCr	0.00119
Cobalt	0.500	0.148	12	10	0.0000300	7.380E-06	uMCo	0.0000309
Copper	46.000	0.416	12	10	0.00276	0.0000208	uMCu	0.00276
Lead	61.200	2.805	13	16	0.00398	0.000224	uMPb	0.00398
Manganese	6.300	0.691	16	10	0.000504	0.0000346	uMMn	0.000505
Mercury	0.177	0.369	10	12	8.850E-06	0.0000221	uMHg	0.0000238
Nickel	6.600	0.403	12	9	0.000396	0.0000181	uMNI	0.000396
Thallium	0.500	0.148	14	14	0.0000350	0.0000103	uMTI	0.0000365
Vanadium	0.500	0.0738	12	9	0.0000300	3.321E-06	uMV	0.0000302

				Standard Uncertainty @ 95%			
Sampled Volume (V <sub>m</sub> )	1.645	m <sup>3</sup>		uV <sub>m</sub>	0.001	m <sup>3</sup>	
Meter Correction Factor (Y <sub>d</sub> )	1.007	...			...		
Meter Temperature (T <sub>m</sub> )	308.33	k		uT <sub>m</sub>	1.5	k	
Average Differential Pressure (ΔH)	67.07	mmH <sub>2</sub> O		uDH	0.25	mmH <sub>2</sub> O	
Barometric Pressure (P <sub>b</sub> )	761.31	mmHg		uP <sub>s</sub>	3.8	mmHg	
ΔH + P <sub>s</sub> (P <sub>m</sub> )	102.16	kPa			...		
Oxygen content (O <sub>2,m</sub> )	13.16	% by volume		uO <sub>2,m</sub> = σ/√n	0.33	% by volume	
Moisture Content (H <sub>2</sub> O)	11.29	% by volume		uH <sub>2</sub> O	0.31	% by volume	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP<sub>s</sub>) & measured

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.899$$

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.899	0.899	0.0000863	0.0000216
uP <sub>s</sub>	0.904	0.895	0.00117	0.00440
uT <sub>m</sub>	0.904	0.895	0.00292	0.00437
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00525$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

$$V_{std} = V_{measured} \times f_s = 1.480$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty m <sup>3</sup>
Effect of uV <sub>std</sub>	1.488	1.471	1.645	0.00864
Effect of uV <sub>m</sub>	1.481	1.479	0.899	0.000899

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0142$$

Uncertainty of oxygen correction factor (uf<sub>o2</sub>)

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.28$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.05$$

$$\therefore uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 4.2\%$$

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Ro01

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Metal	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uM mg/Nm <sup>3</sup>
Antimony	0.00669	0.00578	0.864	0.000454
Arsenic	0.00311	0.00281	0.864	0.000153
Cadmium	0.00114	0.00102	0.864	0.0000574
Chromium	0.0187	0.0167	0.864	0.00103
Cobalt	0.000587	0.000533	0.864	0.0000267
Copper	0.0425	0.0377	0.864	0.00239
Lead	0.0588	0.0519	0.864	0.00344
Manganese	0.00648	0.00561	0.864	0.000437
Mercury	0.000493	0.000451	0.864	0.0000206
Nickel	0.00640	0.00571	0.864	0.000343
Thallium	0.000591	0.000528	0.864	0.0000315
Vanadium	0.000522	0.000470	0.864	0.0000261

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system

Metal	uL mg/Nm <sup>3</sup>
Antimony	0.0000719
Arsenic	0.0000342
Cadmium	0.0000125
Chromium	0.000205
Cobalt	6.464E-06
Copper	0.000463
Lead	0.000639
Manganese	0.0000698
Mercury	5.450E-06
Nickel	0.0000699
Thallium	6.464E-06
Vanadium	5.728E-06

Uncertainty in final measurement @ Reference Conditions due to uVstp

Metal	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
Antimony	0.00629	0.00617	0.00421	0.0000599
Arsenic	0.00299	0.00293	0.00200	0.0000285
Cadmium	0.00109	0.00107	0.000729	0.0000104
Chromium	0.0179	0.0175	0.0120	0.000170
Cobalt	0.000565	0.000554	0.000378	5.386E-06
Copper	0.0405	0.0397	0.0271	0.000386
Lead	0.0559	0.0548	0.0374	0.000532
Manganese	0.00610	0.00599	0.00408	0.0000581
Mercury	0.000477	0.000467	0.000319	4.541E-06
Nickel	0.00611	0.00600	0.00409	0.0000582
Thallium	0.000565	0.000554	0.000378	5.386E-06
Vanadium	0.000501	0.000491	0.000335	4.772E-06

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Metal	Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
Antimony	0.000464	0.000927	0.00623	14.881
Arsenic	0.000159	0.000318	0.00296	10.746
Cadmium	0.0000597	0.000119	0.00108	11.062
Chromium	0.00106	0.00212	0.0177	11.983
Cobalt	0.0000280	0.0000560	0.000560	10.003
Copper	0.00246	0.00492	0.0401	12.267
Lead	0.00354	0.00709	0.0553	12.808
Manganese	0.000446	0.000892	0.00604	14.761
Mercury	0.0000218	0.0000436	0.000472	9.237
Nickel	0.000355	0.000709	0.00605	11.714
Thallium	0.0000326	0.0000653	0.000560	11.664
Vanadium	0.0000271	0.0000543	0.000496	10.941

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Metal	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> )	New Combined Uncertainty mg/Nm <sup>3</sup>
Antimony	14.881	4.200	15.463	0.000482
Arsenic	10.746	4.200	11.538	0.000171
Cadmium	11.062	4.200	11.833	0.000064
Chromium	11.983	4.200	12.698	0.001125
Cobalt	10.003	4.200	10.849	0.000030
Copper	12.267	4.200	12.966	0.002601
Lead	12.808	4.200	13.479	0.003729
Manganese	14.761	4.200	15.347	0.000464
Mercury	9.237	4.200	10.147	0.000024
Nickel	11.714	4.200	12.444	0.000377
Thallium	11.664	4.200	12.397	0.000035
Vanadium	10.941	4.200	11.720	0.000029

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m3) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Dioxins & Furans Uncertainty - (Dead Animal Waste)

Site: ACL Lagun - Bonaire  
 Location: Incinerator Exhaust

Dioxin	Recovered Mass ng	LOD ng	LAB Method %age	Uncert ( % ) K=2 as Mass (ng)	Standard Uncertainty Symbol	ng
2,3,7,8 - TCDD	0.163	0.000140	30	0.0489	u2,3,7,8 - TCDD	0.0245
1,2,3,7,8 - PCDD	0.514	0.000190	30	0.154	u1,2,3,7,8 - PCDD	0.0771
1,2,3,4,7,8 - HxCDD	0.278	0.000320	30	0.0834	u1,2,3,4,7,8 - HxCDD	0.0417
1,2,3,6,7,8 - HxCDD	0.378	0.000350	30	0.113	u1,2,3,6,7,8 - HxCDD	0.0567
1,2,3,7,8,9 - HxCDD	0.411	0.000380	30	0.123	u1,2,3,7,8,9 - HxCDD	0.0617
1,2,3,4,6,7,8 - HpCDD	1.860	0.000380	30	0.558	u1,2,3,4,6,7,8 - HpCDD	0.279
OCDD	2.050	0.00135	30	0.615	uOCDD	0.308
2,3,7,8 - TCDF	1.200	0.000270	30	0.360	u2,3,7,8 - TCDF	0.180
1,2,3,7,8 - PCDF	1.160	0.000260	30	0.348	u1,2,3,7,8 - PCDF	0.174
2,3,4,7,8 - PCDF	1.850	0.000740	30	0.555	u2,3,4,7,8 - PCDF	0.278
1,2,3,4,7,8 - HxCDF	1.150	0.000190	30	0.345	u1,2,3,4,7,8 - HxCDF	0.173
1,2,3,6,7,8 - HxCDF	1.330	0.000160	30	0.399	u1,2,3,6,7,8 - HxCDF	0.200
2,3,4,6,7,8 - HxCDF	1.310	0.000160	30	0.393	u2,3,4,6,7,8 - HxCDF	0.197
1,2,3,7,8,9 - HxCDF	0.130	0.000180	30	0.0390	u1,2,3,7,8,9 - HxCDF	0.0195
1,2,3,4,6,7,8 - HpCDF	2.880	0.000450	30	0.864	u1,2,3,4,6,7,8 - HpCDF	0.432
1,2,3,4,7,8,9 - HpCDF	0.521	0.000650	30	0.156	u1,2,3,4,7,8,9 - HpCDF	0.0782
OCDF	1.400	0.000560	30	0.420	uOCDF	0.210

Measured Values		Standard Uncertainty @ 95%	
Sampled Volume (V <sub>m</sub> )	1.366 m <sup>3</sup>	uV <sub>m</sub>	0.001 m <sup>3</sup>
Meter Correction Factor (Y <sub>d</sub> )	1.007 ...		...
Meter Temperature (T <sub>m</sub> )	308.333 K	uT <sub>m</sub>	1.5 K
Average Differential Pressure (ΔH)	38.550 mmH <sub>2</sub> O	uDH	0.25 mmH <sub>2</sub> O
Barometric Pressure (p <sub>b</sub> )	761.310 mmHg	up <sub>b</sub>	3.8 mmHg
ΔH + p <sub>s</sub> (p <sub>m</sub> )	101.878 kPa		...
Oxygen content (O <sub>2,m</sub> )	10.128 % by volume	uO <sub>2,m</sub> = σ/√n	0.50 % by volume
Moisture Content (H <sub>2</sub> O)	6.951 % by volume	uH <sub>2</sub> O	0.22 % by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up<sub>s</sub>) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.897$$

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.897	0.897	0.0000863	0.0000216
up <sub>b</sub>	0.901	0.892	0.00117	0.00440
uT <sub>m</sub>	0.901	0.892	0.00291	0.00436
H <sub>2</sub> O	...	...	...	...

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (up_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100(100 - H_2O)}\right)^2} = 0.00524$$

Uncertainty in volume @ reference conditions due to volume correction factor uncertainty component (uV<sub>std</sub>) & volume uncertainty component (uV<sub>m</sub>)

$$V_{std} = V_{measured} \times f_s = 1.225$$

	Maximum m <sup>3</sup>	Minimum m <sup>3</sup>	Sensitivity	Standard Uncertainty m <sup>3</sup>
Effect of uV <sub>std</sub>	1.233	1.218	1.366	0.00715
Effect of uV <sub>m</sub>	1.226	1.225	0.897	0.000897

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0098$$

Uncertainty of oxygen correction factor (ufO<sub>2</sub>)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.656 \quad uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} =$$

$$\therefore uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 1.68\%$$



Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty in final dioxin measurement @ reference conditions due to mass uncertainty component (uM)

Dioxin	Maximum ng/Nm <sup>3</sup>	Minimum ng/Nm <sup>3</sup>	Sensitivity	uM ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	0.253	0.187	1.351	0.0330
1,2,3,7,8 - PCDD	0.799	0.590	1.351	0.104
1,2,3,4,7,8 - HxCDD	0.432	0.319	1.351	0.0563
1,2,3,6,7,8 - HxCDD	0.587	0.434	1.351	0.0766
1,2,3,7,8,9 - HxCDD	0.639	0.472	1.351	0.0833
1,2,3,4,6,7,8 - HpCDD	2.890	2.136	1.351	0.377
OCDD	3.185	2.354	1.351	0.415
2,3,7,8 - TCDF	1.865	1.378	1.351	0.243
1,2,3,7,8 - PCDF	1.802	1.332	1.351	0.235
2,3,4,7,8 - PCDF	2.874	2.125	1.351	0.375
1,2,3,4,7,8 - HxCDF	1.787	1.321	1.351	0.233
1,2,3,6,7,8 - HxCDF	2.067	1.527	1.351	0.270
2,3,4,6,7,8 - HxCDF	2.035	1.504	1.351	0.265
1,2,3,7,8,9 - HxCDF	0.202	0.149	1.351	0.0263
1,2,3,4,6,7,8 - HpCDF	4.475	3.308	1.351	0.584
1,2,3,4,7,8,9 - HpCDF	0.810	0.598	1.351	0.106
OCDF	2.175	1.608	1.351	0.284

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss in the sample system (uL)

Dioxin	uL ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	0.00254
1,2,3,7,8 - PCDD	0.00802
1,2,3,4,7,8 - HxCDD	0.00434
1,2,3,6,7,8 - HxCDD	0.00590
1,2,3,7,8,9 - HxCDD	0.00641
1,2,3,4,6,7,8 - HpCDD	0.0290
OCDD	0.0320
2,3,7,8 - TCDF	0.0187
1,2,3,7,8 - PCDF	0.0181
2,3,4,7,8 - PCDF	0.0289
1,2,3,4,7,8 - HxCDF	0.0179
1,2,3,6,7,8 - HxCDF	0.0207
2,3,4,6,7,8 - HxCDF	0.0204
1,2,3,7,8,9 - HxCDF	0.00203
1,2,3,4,6,7,8 - HpCDF	0.0449
1,2,3,4,7,8,9 - HpCDF	0.00813
OCDF	0.0218

Uncertainty in final measurement @ Reference Conditions due to uVstp

Dioxin	Maximum ng/Nm <sup>3</sup>	Minimum ng/Nm <sup>3</sup>	Sensitivity	uVstp mg/Nm <sup>3</sup>
2,3,7,8 - TCDD	0.222	0.218	0.180	0.00176
1,2,3,7,8 - PCDD	0.700	0.689	0.567	0.00556
1,2,3,4,7,8 - HxCDD	0.379	0.373	0.307	0.00301
1,2,3,6,7,8 - HxCDD	0.515	0.507	0.417	0.00409
1,2,3,7,8,9 - HxCDD	0.560	0.551	0.453	0.00445
1,2,3,4,6,7,8 - HpCDD	2.533	2.493	2.051	0.0201
OCDD	2.792	2.748	2.260	0.0222
2,3,7,8 - TCDF	1.634	1.608	1.323	0.0130
1,2,3,7,8 - PCDF	1.580	1.555	1.279	0.0125
2,3,4,7,8 - PCDF	2.520	2.480	2.040	0.0200
1,2,3,4,7,8 - HxCDF	1.566	1.541	1.268	0.0124
1,2,3,6,7,8 - HxCDF	1.811	1.783	1.467	0.0144
2,3,4,6,7,8 - HxCDF	1.784	1.756	1.444	0.0142
1,2,3,7,8,9 - HxCDF	0.177	0.174	0.143	0.00141
1,2,3,4,6,7,8 - HpCDF	3.923	3.860	3.176	0.0312
1,2,3,4,7,8,9 - HpCDF	0.710	0.698	0.574	0.00564
OCDF	1.907	1.877	1.544	0.0151

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Dioxin	Combined Uncertainty ng/Nm <sup>3</sup>	Expanded Uncertainty ng/Nm <sup>3</sup>	Measured Concentration ng/Nm <sup>3</sup>	% of Measured Concentration
2,3,7,8 - TCDD	0.0332	0.0664	0.220	30.131
1,2,3,7,8 - PCDD	0.105	0.209	0.694	30.131
1,2,3,4,7,8 - HxCDD	0.0566	0.113	0.376	30.131
1,2,3,6,7,8 - HxCDD	0.0769	0.154	0.511	30.131
1,2,3,7,8,9 - HxCDD	0.0837	0.167	0.555	30.131
1,2,3,4,6,7,8 - HpCDD	0.379	0.757	2.513	30.131
OCDD	0.417	0.835	2.770	30.131
2,3,7,8 - TCDF	0.244	0.489	1.621	30.131
1,2,3,7,8 - PCDF	0.236	0.472	1.567	30.131
2,3,4,7,8 - PCDF	0.377	0.753	2.500	30.131
1,2,3,4,7,8 - HxCDF	0.234	0.468	1.554	30.131
1,2,3,6,7,8 - HxCDF	0.271	0.541	1.797	30.131
2,3,4,6,7,8 - HxCDF	0.267	0.533	1.770	30.131
1,2,3,7,8,9 - HxCDF	0.0265	0.0529	0.176	30.131
1,2,3,4,6,7,8 - HpCDF	0.586	1.172	3.891	30.131
1,2,3,4,7,8,9 - HpCDF	0.106	0.212	0.704	30.131
OCDF	0.285	0.570	1.892	30.131

Total (ng/Nm<sup>3</sup>) 25.110 8.9

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Dioxin	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty Inc O <sub>2</sub> Corr <sup>n</sup> factor (Ucombined)	New Combined Uncertainty ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	30.131	1.680	30.178	0.0332
1,2,3,7,8 - PCDD	30.131	1.680	30.178	0.105
1,2,3,4,7,8 - HxCDD	30.131	1.680	30.178	0.0566
1,2,3,6,7,8 - HxCDD	30.131	1.680	30.178	0.0770
1,2,3,7,8,9 - HxCDD	30.131	1.680	30.178	0.0837
1,2,3,4,6,7,8 - HpCDD	30.131	1.680	30.178	0.379
OCDD	30.131	1.680	30.178	0.417
2,3,7,8 - TCDF	30.131	1.680	30.178	0.244
1,2,3,7,8 - PCDF	30.131	1.680	30.178	0.236
2,3,4,7,8 - PCDF	30.131	1.680	30.178	0.377
1,2,3,4,7,8 - HxCDF	30.131	1.680	30.178	0.234
1,2,3,6,7,8 - HxCDF	30.131	1.680	30.178	0.271
2,3,4,6,7,8 - HxCDF	30.131	1.680	30.178	0.267
1,2,3,7,8,9 - HxCDF	30.131	1.680	30.178	0.0265
1,2,3,4,6,7,8 - HpCDF	30.131	1.680	30.178	0.587
1,2,3,4,7,8,9 - HpCDF	30.131	1.680	30.178	0.106
OCDF	30.131	1.680	30.178	0.285

Environmental Compliance Limited

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : R001

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

Uncertainty - Adjusted for TEQ / TEF												
Dioxin	TEQ ng/m <sup>3</sup>	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>	WHO Humans & Mammals (TEF)	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>	WHO Fish (TEF)	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>	WHO Birds (TEF)	Uncertainty ng/Nm <sup>3</sup>	Conc ng/Nm <sup>3</sup>
2,3,7,8 - TCDD	1	0.0664	0.220	1	0.0664	0.220	1	0.0664	0.220	1	0.0664	0.220
1,2,3,7,8 - PCDD	0.5	0.105	0.347	1	0.209	0.694	1	0.209	0.694	1	0.209	0.694
1,2,3,4,7,8 - HxCDD	0.1	0.0113	0.0376	0.1	0.0113	0.0376	0.5	0.0566	0.188	0.05	0.00566	0.0188
1,2,3,6,7,8 - HxCDD	0.1	0.0154	0.0511	0.1	0.0154	0.0511	0.01	0.00154	0.00511	0.01	0.00154	0.00511
1,2,3,7,8,9 - HxCDD	0.1	0.0167	0.0555	0.1	0.0167	0.0555	0.01	0.00167	0.00555	0.1	0.0167	0.0555
1,2,3,4,6,7,8 - HpCDD	0.01	0.00758	0.0251	0.01	0.00758	0.0251	0.001	0.000758	0.00251	0.001	0.000758	0.00251
OCDD	0.001	0.000835	0.00277	0.0001	0.000835	0.00277	...	...	...	...	...	...
2,3,7,8 - TCDF	0.1	0.0489	0.162	0.1	0.0489	0.162	0.05	0.0244	0.0811	1	0.489	1.621
1,2,3,7,8 - PCDF	0.05	0.0236	0.0784	0.05	0.0236	0.0784	0.05	0.0236	0.0784	0.1	0.0472	0.157
2,3,4,7,8 - PCDF	0.5	0.377	1.250	0.5	0.377	1.250	0.5	0.377	1.250	1	0.754	2.500
1,2,3,4,7,8 - HxCDF	0.1	0.0468	0.155	0.1	0.0468	0.155	0.1	0.0468	0.155	0.1	0.0468	0.155
1,2,3,6,7,8 - HxCDF	0.1	0.0542	0.180	0.1	0.0542	0.180	0.1	0.0542	0.180	0.1	0.0542	0.180
2,3,4,6,7,8 - HxCDF	0.1	0.0534	0.177	0.1	0.0534	0.177	0.1	0.0534	0.177	0.1	0.0534	0.177
1,2,3,7,8,9 - HxCDF	0.1	0.00529	0.0176	0.1	0.00529	0.0176	0.1	0.00529	0.0176	0.1	0.00529	0.0176
1,2,3,4,6,7,8 - HpCDF	0.01	0.0117	0.0389	0.01	0.0117	0.0389	0.01	0.0117	0.0389	0.01	0.0117	0.0389
1,2,3,4,7,8,9 - HpCDF	0.01	0.00212	0.00704	0.01	0.00212	0.00704	0.01	0.00212	0.00704	0.01	0.00212	0.00704
OCDF	0.001	0.000570	0.00189	0.0001	0.000570	0.00189	0.0001	0.000570	0.00189	0.0001	0.000570	0.00189
TOTAL	...	0.411	2.807	...	0.449	3.150	...	0.450	3.101	...	0.930	5.850
% Uncertainty	...	...	14.648	...	...	14.266	...	...	14.520	...	...	15.9

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

# Light Medical Waste

Stack Reference Incinerator Exhaust

## Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H <sub>2</sub> O)	
Pitot Calibration Uncertainty Contribution	0.054	A
Manometer Calibration Uncertainty Contribution	0.054	B
Variation in Actual Pitot reading at sample points	0.20	C
Combined u/c (mm H <sub>2</sub> O) =	<b>Combined u/c (mm H<sub>2</sub>O)</b>	
SQRT (A/ $\sqrt{3}$ ) <sup>2</sup> + (B/ $\sqrt{3}$ ) <sup>2</sup> + (C/ $\sqrt{3}$ ) <sup>2</sup>	0.12	
<b>Expanded Uncertainty of Flow Measurements (mm H<sub>2</sub>O)</b>	<b>0.25</b>	
	<b>Standard u/c (K)</b>	
Temperature Calibration (K)	3.18	D
Variation in Actual Temp reading at sample points	1.50	E
Combined u/c of Temp (K)	<b>Combined u/c (K)</b>	
SQRT ((D/ $\sqrt{3}$ ) <sup>2</sup> + (E/ $\sqrt{3}$ ) <sup>2</sup> )	2.03	
<b>Expanded Uncertainty of Temp Measurements (K)</b>	<b>4.06</b>	
Measured Average Velocity (m/s) at Stack Conds	16.48	
Maximum Average Velocity (m/s) at Stack Conds	16.72	
Standard Uncertainty Velocity at Stack Conditions (%)	1.46	
<b>Expanded Uncertainty Velocity (at Stack Conditions)</b>	<b>2.92 (%)</b>	

## Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m <sup>2</sup> )
Area (m <sup>2</sup> )	0.00071
Measured Average Flowrate (m <sup>3</sup> /s) at Stack Conds	1.17
Maximum Average Flowrate (m <sup>3</sup> /s) at Stack Conds	1.19
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at Stack Conditions (%)	2.47
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at Stack Conditions</b>	<b>4.95 (%)</b>

## Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m <sup>3</sup> /s) at STP Wet	0.50
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Wet	0.51
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Wet	2.69
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Wet</b>	<b>5.39 (%)</b>

## Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.10
Measured Average Flowrate (m <sup>3</sup> /s) at STP Dry	0.48
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Dry	0.49
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Dry	2.80
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Dry</b>	<b>5.59 (%)</b>

## Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.341
Measured Average Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	0.11
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	0.12
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	11.62
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Dry &amp; Ref O<sub>2</sub></b>	<b>23.23 (%)</b>

Selibon N.V.  
 Permit No : ...  
 Variation No : ...  
 Report Ref : P5632 : Root

Installation Name : Incinerator Exhaust  
 Visit Details : Emissions Survey – February 2024  
 Survey Dates : 12th – 16th February 2024  
 Report Issue Date : 20th December 2024

## Medium Bin Medical Waste

**Stack Reference      Incinerator Exhaust**

### Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H <sub>2</sub> O)	
Pitot Calibration Uncertainty Contribution	0.277	A
Manometer Calibration Uncertainty Contribution	0.277	B
Variation in Actual Pitot reading at sample points	3.00	C
Combined u/c (mm H <sub>2</sub> O) =	<b>Combined u/c (mm H<sub>2</sub>O)</b>	
SQRT (A/√3) <sup>2</sup> + (B/√3) <sup>2</sup> + (C/√3) <sup>2</sup>	1.75	
<b>Expanded Uncertainty of Flow Measurements (mm H<sub>2</sub>O)</b>	<b>3.49</b>	
	<b>Standard u/c (K)</b>	
Temperature Calibration (K)	4.21	D
Variation in Actual Temp reading at sample points	4.50	E
Combined u/c of Temp (K)	<b>Combined u/c (K)</b>	
SQRT ((D/√3) <sup>2</sup> + (E/√3) <sup>2</sup> )	3.56	
<b>Expanded Uncertainty of Temp Measurements (K)</b>	<b>7.11</b>	
Measured Average Velocity (m/s) at Stack Conds	42.90	
Maximum Average Velocity (m/s) at Stack Conds	44.42	
Standard Uncertainty Velocity at Stack Conditions (%)	3.54	
<b>Expanded Uncertainty Velocity (at Stack Conditions)</b>	<b>7.09 (%)</b>	

### Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m <sup>3</sup> )
Area (m <sup>2</sup> )	0.00071
Measured Average Flowrate (m <sup>3</sup> /s) at Stack Conds	3.03
Maximum Average Flowrate (m <sup>3</sup> /s) at Stack Conds	3.17
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at Stack Conditions (%)	4.58
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at Stack Conditions</b>	<b>9.16 (%)</b>

### Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m <sup>3</sup> /s) at STP Wet	0.99
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Wet	1.03
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Wet	4.75
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Wet</b>	<b>9.50 (%)</b>

### Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.09
Measured Average Flowrate (m <sup>3</sup> /s) at STP Dry	0.94
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Dry	0.99
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Dry	4.85
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Dry</b>	<b>9.69 (%)</b>

### Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.171
Measured Average Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	0.20
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	0.22
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	9.49
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Dry &amp; Ref O<sub>2</sub></b>	<b>18.97 (%)</b>

Selibon N.V.  
Permit No : ...  
Variation No : ...  
Report Ref : P5632

: ...  
: ...  
: Root

Installation Name : Incinerator Exhaust  
Visit Details : Emissions Survey – February 2024  
Survey Dates : 12th – 16th February 2024  
Report Issue Date : 20th December 2024

# Dead Animal Waste

Stack Reference Incinerator Exhaust

## Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H <sub>2</sub> O)	
Pitot Calibration Uncertainty Contribution	0.380	A
Manometer Calibration Uncertainty Contribution	0.380	B
Variation in Actual Pitot reading at sample points	4.00	C
Combined u/c (mm H <sub>2</sub> O) =	<b>Combined u/c (mm H<sub>2</sub>O)</b>	
SQRT (A/√3) <sup>2</sup> + (B/√3) <sup>2</sup> + (C/√3) <sup>2</sup>	2.33	
<b>Expanded Uncertainty of Flow Measurements (mm H<sub>2</sub>O)</b>	<b>4.66</b>	
	<b>Standard u/c (K)</b>	
Temperature Calibration (K)	3.21	D
Variation in Actual Temp reading at sample points	3.50	E
Combined u/c of Temp (K)	<b>Combined u/c (K)</b>	
SQRT ((D/√3) <sup>2</sup> + (E/√3) <sup>2</sup> )	2.74	
<b>Expanded Uncertainty of Temp Measurements (K)</b>	<b>5.48</b>	
Measured Average Velocity (m/s) at Stack Conds	44.32	
Maximum Average Velocity (m/s) at Stack Conds	45.85	
Standard Uncertainty Velocity at Stack Conditions (%)	3.46	
<b>Expanded Uncertainty Velocity (at Stack Conditions)</b>	<b>6.92 (%)</b>	

## Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m <sup>2</sup> )
Area (m <sup>2</sup> )	0.00071
Measured Average Flowrate (m <sup>3</sup> /s) at Stack Conds	3.13
Maximum Average Flowrate (m <sup>3</sup> /s) at Stack Conds	3.27
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at Stack Conditions (%)	4.49
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at Stack Conditions</b>	<b>8.99 (%)</b>

## Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m <sup>3</sup> /s) at STP Wet	1.34
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Wet	1.40
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Wet	4.72
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Wet</b>	<b>9.43 (%)</b>

## Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.16
Measured Average Flowrate (m <sup>3</sup> /s) at STP Dry	1.17
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Dry	1.23
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Dry	4.91
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Dry</b>	<b>9.81 (%)</b>

## Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.134
Measured Average Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	0.50
Maximum Average Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	0.53
Standard Uncertainty Flowrate (m <sup>3</sup> /s) at STP Dry & Ref Oxygen	6.76
<b>Expanded Uncertainty Flowrate (m<sup>3</sup>/s) at STP Dry &amp; Ref O<sub>2</sub></b>	<b>13.51 (%)</b>